

**40 C.F.R. § 257.95(g) NOTIFICATION FOR STATISTICALLY SIGNIFICANT
LEVELS OF 40 C.F.R. PART 257 APPENDIX IV CONSTITUENTS ABOVE
GROUNDWATER PROTECTION STANDARDS
COFFEEN ASH POND NO. 1**

February 5, 2020

In accordance with Title 40 Code of Federal Regulations (C.F.R.) § 257.95(g), the owner or operator of a Coal Combustion Residuals (CCR) unit must prepare a notification that identifies constituents listed in Appendix IV of 40 C.F.R. Part 257 that have exceeded Groundwater Protection Standards established under 40 C.F.R. § 257.95(h). The notification must be placed in the facility's operating record within 30 days of detection (40 C.F.R. § 257.105(h)(8)).

The following Appendix IV constituent was detected at a Statistically Significant Level above the applicable Groundwater Protection Standard established pursuant to 40 C.F.R. § 257.95(h) during assessment monitoring completed at Coffeen Ash Pond No. 1:

- Cobalt

Coffeen