

Annual CCR Fugitive Dust Control Report

for

Edwards Power Station

Prepared for:



Illinois Power Resources Generating, LLC

**Edwards Power Station
7800 South Cilco Lane
Bartonville, IL 61607**

October, 2019

**Edwards Power Station
ANNUAL CCR FUGITIVE DUST CONTROL REPORT**

Reporting Year: 4th Quarter 2018 through 3rd Quarter 2019

Completed by: Kevin Long Plant Manager
Name Title

This Annual CCR Fugitive Dust Control Report has been prepared for the Edwards Power Station in accordance with 40 CFR 257.80(c). Section 1 provides a description of the actions taken to control CCR fugitive dust at the facility during the reporting year, including a summary of any corrective measures taken. Section 2 provides a record of citizen complaints received concerning CCR fugitive dust at the facility during the reporting year, including a summary of any corrective measures taken.

Section 1 Actions Taken to Control CCR Fugitive Dust

In accordance with the Edwards Power Station CCR Fugitive Dust Control Plan (Plan), the following measures were used to control CCR fugitive dust from becoming airborne at the facility during the reporting year:

CCR Activity	Actions Taken to Control CCR Fugitive Dust
Management of CCR in the facility's CCR units	Maintain CCR inventory levels in the CCR unit at lowest practicable height.
	Wet management of CCR bottom ash and CCR fly ash in the CCR surface impoundment.
	Water or apply chemical dust suppressant on areas of exposed CCR in or near the CCR unit, as necessary.
	Naturally occurring grass vegetation in areas of exposed CCR in the CCR surface impoundment.
Handling of CCR at the facility	Wet sluice CCR bottom ash and fly ash to CCR surface impoundment.
	Pneumatically convey dry CCR fly ash to storage silos in an enclosed system.
	CCR fly ash to be emplaced in an offsite landfill, or on site ash pond, is conditioned before loading into trucks for transport.
	Load CCR transport trucks from the CCR fly ash silos in a covered/contained area.
	Load CCR transport trucks from the CCR fly ash silos using a telescoping chute with vacuum equipment.

**Edwards Power Station
ANNUAL CCR FUGITIVE DUST CONTROL REPORT**

CCR Activity	Actions Taken to Control CCR Fugitive Dust
Handling of CCR at the facility	Perform housekeeping, as necessary, in the fly ash loading area.
	Operate fly ash handling system in accordance with good operating practices.
	Maintain and repair dust controls on the fly ash handling system as necessary.
Transportation of CCR at the facility	CCR to be emplaced in an offsite landfill, or on site ash pond, is conditioned before being loaded into vehicles for transport.
	Cover or enclose trucks used to transport CCR fly ash offsite.
	Limit the speed of vehicles to no more than 15 mph on facility roads.
	Cover or enclose trucks used to transport CCR other than fly ash, as necessary.
	Sweep or rinse off the outside of the trucks transporting CCR, as necessary.
	Water facility roads used to transport CCR, as needed.
	Sweep paved roads, as needed.
Remove CCR, as necessary, deposited on facility road surfaces during transport.	

Based on a review of the Plan and inspections associated with CCR fugitive dust control performed in the reporting year, the control measures identified in the Plan as implemented at the facility effectively minimized CCR from becoming airborne at the facility. The control measures included the use of a water truck for water application on both paved and unpaved roads. No changes to the control measures listed in the Dust Plan were needed in order to control CCR fugitive dust.

In the reporting year, no material changes to site conditions occurred that would require amending the Dust Plan.

Section 2 Record of Citizen Complaints

No citizen complaints were received regarding CCR fugitive dust at Edwards Power Station in the reporting year.