# Annual CCR Fugitive Dust Control Report for Hennepin Power Station

Prepared for:



Dynegy Midwest Generation, LLC

Hennepin Power Station 13498 East 800<sup>th</sup> Street Hennepin, IL 61327

November 2019

# Hennepin Power Station ANNUAL CCR FUGITIVE DUST CONTROL REPORT

Reporting Year: 4 <sup>th</sup> Quarter 2018 through 3 <sup>rd</sup> Quarter 2019	
Completed by:	Managon Douber
	OO
Name	Title

This Annual CCR Fugitive Dust Control Report has been prepared for the Hennepin Power Station in accordance with 40 CFR 257.80(c). Section 1 provides a description of the actions taken to control CCR fugitive dust at the facility during the reporting year, including a summary of any corrective measures taken. Section 2 provides a record of citizen complaints received concerning CCR fugitive dust at the facility during the reporting year, including a summary of any corrective measures taken.

## Section 1 Actions Taken to Control CCR Fugitive Dust

In accordance with the Hennepin Power Station CCR Fugitive Dust Control Plan (Plan), the following measures were used to control CCR fugitive dust from becoming airborne at the facility during the reporting year:

CCR Activity	Actions Taken to Control CCR Fugitive Dust
Management of CCR in the facility's CCR units	CCR to be emplaced in the landfill will be conditioned before emplacement.
	Water dry CCR material from periodic cleanout / maintenance of CCR handling or CCR dust control systems as it is added into the CCR surface impoundments, as necessary.
	Wet management of CCR bottom ash in CCR surface impoundments.
	Water areas of exposed CCR in CCR units, as necessary.
	Naturally occurring grass vegetation in areas of exposed CCR in CCR surface impoundments.
	Apply chemical dust suppressant on areas of exposed CCR in CCR units, as necessary.

# Hennepin Power Station ANNUAL CCR FUGITIVE DUST CONTROL REPORT

CCR Activity	Actions Taken to Control CCR Fugitive Dust
Handling of CCR at the facility	Wet sluice CCR fly ash and CCR bottom ash to CCR surface impoundments.
	Pneumatically convey dry CCR fly ash and FGD ash to storage silos in an enclosed system.
	CCR to be emplaced in the landfill will be conditioned before emplacement.
	Load CCR transport trucks from the CCR fly ash silos in a partially enclosed area.
	Load CCR transport trucks from the CCR fly ash silos using vented spouts.
	Load FGD ash transport trucks from the FGD ash silo using a pug mill or vented spouts, as necessary.
	Perform housekeeping, as necessary, in the fly ash loading area.
	Operate fly ash handling system in accordance with good operating practices.
	Maintain and repair as necessary dust controls on the fly ash handling system.
Transportation of CCR at the facility	CCR to be emplaced in the landfill is conditioned before emplacement.
	Limit the speed of vehicles to no more than 15 mph on facility roads.
	Sweep or rinse off the outside of the trucks transporting CCR, as necessary.
	Remove CCR, as necessary, deposited on facility road surfaces during transport.

Based on a review of the Plan and inspections associated with CCR fugitive dust control performed in the reporting year, the control measures identified in the Plan as implemented at the facility effectively minimized CCR from becoming airborne at the facility. No revisions or additions to control measures identified in the Plan were needed.

No material changes occurred in the reporting year in site conditions potentially resulting in CCR fugitive dust becoming airborne at the facility that warrant an amendment of the Plan.

### Section 2 Record of Citizen Complaints

No citizen complaints were received regarding CCR fugitive dust at Hennepin Power Station in the reporting year.