

2024 Annual Coal Combustion Residuals (CCR) Landfill Inspection Report	
Site Name: Hennepin Power Plant	
Site Address 13498 East 800th Street, Hennepin, Illinois 61327	
Owner/Operator: Dynegy Midwest Generation, LLC	
Owner/Operator Address: 13498 East 800th Street, Hennepin, Illinois 61327	
CCR Unit: CCR Landfill	
40 C.F.R # 257.84 INSPECTION REQUIREMENTS FOR CCR LANDFII	LLS
(b) ANNUAL INSPECTIONS BY A QUALIFIED PROFESSIONAL ENGINEER	
(1) Existing and new CCR Landfills and any lateral expansion of CCR Landfill must be inspected on a periodic basis by a qualified professional engineer to ensure that the design, construction, operation, and maintenance of the CCR unit is consistent with recognized and generally accepted good engineering standards. The inspection must, at a minimum, include:	
(i) A review of available information regarding the status and condition of the CCR unit, including, but not limited to, files available in the operating records (e.g., the results of inspections by a qualified person, and results of previous annual inspections); and	
Qualified person inspection documentation (weekly inspection reports) and previous annual inspection reports were reviewed prior to conducting the inspection.	
(ii) A visual inspection of the CCR unit to identify signs of distress or malfunction of the CCR Unit.	
A visual inspection was performed by Mr. M. Dean Jones, Jr., P.E. on October 10, 2024. The inspection included the CCR landfill slopes and surface, stormwater collection system, perimeter roads, and exterior slopes.	
(2) INSPECTION REPORT. The qualified professional engineer must prepare a report following each inspection that addresses the following	
(i) Any changes in geometry of the structure since the previous annual inspection; Based on available plant records, the landfill geometry was observed to be unchanged.	
(ii) The approximate volume of CCR contained in the unit at the time of the inspection;	
This unit has not received CCR or other permitted wastes. Approximately 7,000 cubic yards of bottom ash were placed during construction over the geomembrane liner as freeze protection for the liner system.	
(iii) Any appearances of an actual or potential structural weakness of the CCR unit, in addition to any existing conditions that are disrupting or have the potential to disrupt the operation and safety of the CCR Unit; and	
Signs of structural weakness in the landfill or conditions that have the potential to disrupt operation of the landfill were not identified during the visual inspection or in the weekly inspection reports. Minor sedimentation in stormwater ditch outfall were observed which are corrected during regular maintenance.	
(iv) Any other change(s) which may have affected the stability or operation of the CCR unit since the previous annual inspection.	
Based on available weekly inspection reports and visual observations during the inspection, no changes were observed that are expected to impact stability or operation of the CCR unit.	
I, M. Dean Jones, Jr., being a Registered Professional Engineer in good standing in the State of Illinois, do hereby certify, to the best of my knowledge, information, and belief, that the information contained in this CCR landfill certification report has been prepared in accordance with the accepted practice of engineering and requirements of 40 C.F.R. # 257.84(b)	
M. Dean Jones, Jr.	Seal:
Printed Name	GEAN
\frown	
Dan Jonen November 6, 2024	RECISTENCED
Signature Date	
062-051317 IL 11/30/2025	LLINOIS
Registration Number State Expiration Date	