

**ANNUAL CCR SURFACE IMPOUNDMENT
INSPECTION REPORT (per 40 CFR 257.83(b)(2))**

Power Station: Joppa Power Station

Owner: Electric Energy, Inc.

CCR Impoundment: East Ash Pond

Date of Inspection: 10/26/2016

Name of Qualified Professional Engineer: James Knutelski, P.E. and Jason Campbell, P.E.

In accordance with 40 CFR § 257.83(b)(1), an existing or new CCR surface impoundment or any lateral expansion of the CCR surface impoundment that is subject to the periodic structural stability assessment requirements under § 257.73(d) or § 257.74(d) must be inspected on a periodic basis (annually per 40 CFR § 257.83(b)(4)) by a qualified professional engineer to ensure that the design, construction, operation, and maintenance of the CCR unit is consistent with recognized and generally accepted good engineering standards. The inspection must, at a minimum, include: (i) A review of available information regarding the status and condition of the CCR unit, including, but not limited to, files available in the operating record (e.g., CCR unit design and construction information required by §§ 257.73(c)(1) and 257.74(c)(1), previous periodic structural stability assessments required under §§ 257.73(d) and 257.74(d), the results of inspections by a qualified person, and results of previous annual inspections); (ii) A visual inspection of the CCR unit to identify signs of distress or malfunction of the CCR unit and appurtenant structures; and (iii) A visual inspection of any hydraulic structures underlying the base of the CCR unit or passing through the dike of the CCR unit for structural integrity and continued safe and reliable operation.

Inspection Report 40 CFR § 257.83(b)(2)

The inspection included a review of available information regarding the status and condition of the CCR unit, including, but not limited to, files available in the operating record, previous periodic structural stability assessments required under §§ 257.73(d) (if any), and the results of inspections by a qualified person and previous annual inspections; a visual inspection of the CCR unit to identify signs of distress or malfunction of the CCR unit and appurtenant structures; and a visual inspection of hydraulic structures (if any) underlying the base of the CCR unit or passing through the dike of the CCR unit for structural integrity and continued safe and reliable operation.

Based on the inspection, the design, construction, operation, and maintenance of the CCR unit is consistent with recognized and generally accepted good engineering standards. The following information is provided in accordance with 40 CFR § 257.83(b)(2).

- i) Have there been any changes in geometry of the impounding structure since the previous annual inspection? If yes, please explain.

Based on a visual inspection of the impoundment and any hydraulic structures present, as well as a review of previous inspection report there are no changes.

- ii) Instrumentation
(Please see following page for instrumentation location map)

Instrument ID #	Type	Maximum recorded reading since previous annual inspection (ft)
See Attached		

iii) Since previous annual inspection:	Approximate Depth / Elevation					
	Elevation (ft)			Depth (ft)		
	Minimum	Present	Maximum	Minimum	Present	Maximum
Impounded Water		375			29	
CCR	375		380	66		71

- iv) Storage capacity of the impounding structure at the time of the inspection (acre-ft): 8900
- v) Approximate volume of the impounded water and CCR at the time of the inspection (acre-ft):2745
- vi) Are there any appearances of an actual or potential structural weakness of the CCR unit, in addition to any existing conditions that are disrupting or have the potential to disrupt the operation and safety of the CCR unit and appurtenant structures?

None

- vii) Are there any other changes which may have affected the stability or operation of the impounding structure since the previous annual inspection?

Since the 2015 inspection, the southeast corner of the embankment foundation has been modified using a deep soil mixing technique to provide additional foundation strength.

I, James Knutelski, P.E, certify under penalty of law that the information submitted in this report was prepared by me or under my direct supervision and that I am a duly Registered Professional Engineer under the laws of the state of Illinois. The information herein is to the best of my knowledge and belief, true, accurate and complete.



James Knutelski
4/18/17

Piezometer		
Number	Type	Max
JOP-B001	VWP	319.9'
JOP-B002	VWP	ABD
JOP-B003	VWP	ABD
JOP-B004	VWP	347.9'
JOP-B005	VWP	363.8'
JOP-B006	VWP	ABD
JOP-B007	VWP	322.4'
JOP-B008	VWP	359.3'
JOP-B009	VWP	362.8'
JOP-B010	VWP	337.8'
JOP-B011	VWP	336.3'
JOP-B012	VWP	346.2'
JOP-B013	VWP	ABD
JOP-B014	VWP	331.5'
JOP-B015	VWP	355.3'
JOP-B016	VWP	351.7'
JOP-B017	VWP	ABD
JOP-B018	VWP	ABD
JOP-B019	VWP	ABD
JOP-B020	VWP	352.0'
JOP-B021	VWP	325.8'
JOP-B022	VWP	ABD
JOP-B023	VWP	364.2'

Legend:

VWP = Vibrating Wire Piezometer

ABD = Abandoned

Joppa

East Ash Pond

Legend

● Feature 1



1000 ft



Google earth