

# **Annual CCR Fugitive Dust Control Report for Joppa Power Station**

*Prepared for:*

---

**Electric Energy, Inc.**


**Joppa Power Station  
2100 Portland Road  
Joppa, IL 62953**

**December 2016**

**Joppa Power Station  
ANNUAL CCR FUGITIVE DUST CONTROL REPORT**

Reporting Year: 4<sup>th</sup> Quarter 2015 through 3<sup>rd</sup> Quarter 2016

Completed by: \_\_\_\_\_

  
Name

12-2-16

\_\_\_\_\_  
Title

This Annual CCR Fugitive Dust Control Report has been prepared for the Joppa Power Station in accordance with 40 CFR 257.80(c). Section 1 provides a description of the actions taken to control CCR fugitive dust at the facility during the reporting year, including a summary of any corrective measures taken. Section 2 provides a record of citizen complaints received concerning CCR fugitive dust at the facility during the reporting year, including a summary of any corrective measures taken.

**Section 1 Actions Taken to Control CCR Fugitive Dust**

In accordance with the Joppa Power Station CCR Fugitive Dust Control Plan (Plan), the following measures were used to control CCR fugitive dust from becoming airborne at the facility during the reporting year:

CCR Activity	Actions Taken to Control CCR Fugitive Dust
Management of CCR in the facility's CCR units	CCR to be emplaced in the landfill will be conditioned before loading into vehicles for transport to the landfill.
	Wet management of CCR in CCR surface impoundments.
	Water areas of exposed CCR in CCR units, as necessary.
	Naturally occurring grass vegetation in areas of exposed CCR in CCR surface impoundments.
	Apply chemical dust suppressant on areas of exposed CCR in CCR units, as necessary.
Handling of CCR at the facility	Wet sluice CCR bottom ash to CCR surface impoundments.
	CCR bottom ash removed from CCR surface impoundments and loaded into trucks for transport remains conditioned during handling.
	Pneumatically convey dry CCR fly ash to storage silos in an enclosed system.
	CCR fly ash to be emplaced in the landfill will be conditioned before loading into trucks for transport to the landfill.

**Joppa Power Station  
ANNUAL CCR FUGITIVE DUST CONTROL REPORT**

CCR Activity	Actions Taken to Control CCR Fugitive Dust
Handling of CCR at the facility	CCR fly ash to be placed in the surface impoundments is conditioned before loading into trucks for transport to the surface impoundments.
	Load CCR dry fly ash to transport trucks from the CCR fly ash silos using a telescoping chute.
	Perform housekeeping, as necessary, in the fly ash loading area.
	Operate fly ash handling system in accordance with good operating practices.
	Maintain and repair as necessary dust controls on the fly ash handling system.
Transportation of CCR at the facility	CCR to be emplaced in the landfill will be conditioned before loaded into vehicles for transport to the landfill.
	CCR fly ash to be placed in the surface impoundments is conditioned before loading into trucks for transport to the surface impoundments
	Cover or enclose trucks used to transport CCR onsite, as necessary.
	Limit the speed of vehicles to no more than 15 mph on facility roads.
	Sweep or rinse off the outside of the trucks transporting CCR, as necessary.
	Cover or enclose trucks used to transport CCR offsite.
	Water CCR haul roads, as necessary.
	Remove CCR deposited on facility road surfaces during transport as necessary.

Based on a review of the Plan and inspections associated with CCR fugitive dust control performed in the reporting year, the control measures identified in the Plan as implemented at the facility effectively minimized CCR from becoming airborne at the facility. No revisions or additions to control measures identified in the Plan were needed.

No material changes occurred in the reporting year in site conditions potentially resulting in CCR fugitive dust becoming airborne at the facility that warrant an amendment of the Plan.

**Section 2 Record of Citizen Complaints**

No citizen complaints were received regarding CCR fugitive dust at Joppa Power Station in the reporting year.

