

Annual CCR Fugitive Dust Control Report
for
Joppa Power Station

Prepared for:

Electric Energy, Inc.

**Joppa Power Station
2100 Portland Road
Joppa, IL 62953**

December 2017

**Joppa Power Station
ANNUAL CCR FUGITIVE DUST CONTROL REPORT**

CCR Activity	Actions Taken to Control CCR Fugitive Dust
Handling of CCR at the facility	CCR fly ash to be placed in the surface impoundments is conditioned before loading into trucks for transport to the surface impoundments.
	Load CCR dry fly ash to transport trucks from the CCR fly ash silos using a telescoping chute.
	Perform housekeeping, as necessary, in the fly ash loading area.
	Operate fly ash handling system in accordance with good operating practices.
	Maintain and repair as necessary dust controls on the fly ash handling system.
Transportation of CCR at the facility	CCR to be emplaced in the landfill will be conditioned before loaded into vehicles for transport to the landfill.
	CCR fly ash to be placed in the surface impoundments is conditioned before loading into trucks for transport to the surface impoundments
	Cover or enclose trucks used to transport CCR onsite, as necessary.
	Limit the speed of vehicles to no more than 15 mph on facility roads.
	Sweep or rinse off the outside of the trucks transporting CCR, as necessary.
	Cover or enclose trucks used to transport CCR offsite.
	Water CCR haul roads, as necessary.
	Remove CCR deposited on facility road surfaces during transport as necessary.

Based on a review of the Plan and inspections associated with CCR fugitive dust control performed in the reporting year, the control measures identified in the Plan as implemented at the facility effectively minimized CCR from becoming airborne at the facility. No revisions or additions to control measures identified in the Plan were needed.

No material changes occurred in the reporting year in site conditions potentially resulting in CCR fugitive dust becoming airborne at the facility that warrant an amendment of the Plan.

Section 2 Record of Citizen Complaints

No citizen complaints were received regarding CCR fugitive dust at Joppa Power Station in the reporting year.