



Cynthia Vodopivec  
Electric Energy, Inc.  
Luminant  
6555 Sierra Dr.  
Irving, TX 75039

September 29, 2020

Sent via email

Mr. Andrew R. Wheeler, EPA Administrator  
Environmental Protection Agency  
1200 Pennsylvania Avenue, N.W.  
Mail Code 5304-P  
Washington, DC 20460

Re: Joppa Power Station Alternative Closure Demonstration

Dear Administrator Wheeler:

Electric Energy, Inc. (Electric Energy) hereby submits this request to the U.S. Environmental Protection Agency (EPA) for approval of a site-specific alternative deadline to initiate closure pursuant to 40 C.F.R. § 257.103(f)(2) for the East Ash Pond located at the Joppa Power Station near Joppa, Illinois. Electric Energy is requesting an extension pursuant to 40 C.F.R. § 257.103(f)(2) so that the East Ash Pond may continue to receive CCR and non-CCR wastestreams after April 11, 2021, and complete closure no later than October 17, 2028.

Enclosed is a demonstration prepared by Burns & McDonnell that addresses all of the criteria in 40 C.F.R. § 257.103(f)(2)(i)-(iv) and contains the documentation required by 40 C.F.R. § 257.103(f)(2)(v). As allowed by the agency, in lieu of hard copies of these documents, electronic files were submitted to Kirsten Hillyer, Frank Behan, and Richard Huggins via email. If you have any questions regarding this submittal, please contact Phil Morris at 618-343-7794 or phil.morris@vistracorp.com.

Sincerely,

A handwritten signature in blue ink that reads 'Cynthia E. Vodopivec'.

Cynthia Vodopivec  
VP - Environmental Health & Safety

Enclosure

cc: Kirsten Hillyer  
Frank Behan  
Richard Huggins

# CCR Surface Impoundment Demonstration for a Site-Specific Alternative to Initiation of Closure Deadline



**Electric Energy, Inc.**

**Joppa Power Station  
Project No. 122702**

**Revision 0  
9/28/2020**

# **CCR Surface Impoundment Demonstration for a Site-Specific Alternative to Initiation of Closure Deadline**

prepared for

**Electric Energy, Inc.  
Joppa Power Station  
Joppa, Illinois**

**Project No. 122702**

**Revision 0  
9/28/2020**

prepared by

**Burns & McDonnell Engineering Company, Inc.  
Kansas City, Missouri**

## INDEX AND CERTIFICATION


**Electric Energy, Inc.  
CCR Surface Impoundment  
Demonstration for a Site-Specific Alternative to Initiation of Closure Deadline  
Project No. 122702**

### Report Index

<u>Chapter Number</u>	<u>Chapter Title</u>	<u>Number of Pages</u>
1.0	Executive Summary	1
2.0	Introduction	2
3.0	Documentation of No Alternative Disposal Capacity	4
6.0	Documentation of Closure Completion Timeframe	3
7.0	Conclusion	1
Appendix A	Site Plan	1

### Certification

I hereby certify, as a Professional Engineer in the state of Illinois, that the information in this document as noted in the above Report Index was assembled under my direct personal charge. This report is not intended or represented to be suitable for reuse by the Electric Energy, Inc. or others without specific verification or adaptation by the Engineer.



*Edward T. Tohill*

Edward T. Tohill, P.E., (Illinois License No. 062-056915)

Date: 09/28/20

*Edward T. Tohill*  
09/28/20  
LIC. EXPIRES 11/30/21

**TABLE OF CONTENTS**

**Page No.**

**1.0 EXECUTIVE SUMMARY ..... 1-1**

**2.0 INTRODUCTION ..... 2-1**

**3.0 DOCUMENTATION OF NO ALTERNATIVE DISPOSAL CAPACITY ..... 3-1**

    3.1 Site-Layout and Wastewater Processes ..... 3-1

    3.2 CCR Wastestreams ..... 3-1

    3.3 Non-CCR Wastestreams ..... 3-3

**4.0 RISK MITIGATION PLAN ..... 4-1**

**5.0 DOCUMENTATION AND CERTIFICATION OF COMPLIANCE ..... 5-1**

    5.1 Owner’s Certification of Compliance - § 257.103(f)(2)(v)(C)(1) ..... 5-1

    5.2 Visual representation of hydrogeologic information - § 257.103(f)(2)(v)(C)(2) 5-2

    5.3 Groundwater monitoring results - § 257.103(f)(2)(v)(C)(3)..... 5-2

    5.4 Description of site hydrogeology including stratigraphic cross-sections -  
        § 257.103(f)(2)(v)(C)(4) ..... 5-2

    5.5 Corrective measures assessment - § 257.103(f)(2)(v)(C)(5) ..... 5-2

    5.6 Remedy selection progress report - § 257.103(f)(2)(v)(C)(6) ..... 5-2

    5.7 Structural stability assessment - § 257.103(f)(2)(v)(C)(7) ..... 5-2

    5.8 Safety factor assessment - § 257.103(f)(2)(v)(C)(8)..... 5-3

**6.0 DOCUMENTATION OF CLOSURE COMPLETION TIMEFRAME ..... 6-1**

**7.0 CONCLUSION ..... 7-1**

**APPENDIX A – SITE PLAN**

**APPENDIX B – WATER BALANCE DIAGRAM**

**ATTACHMENT 1 – RISK MITIGATION PLAN**

**ATTACHMENT 2 – MAP OF GROUNDWATER MONITORING WELL  
LOCATIONS**

**ATTACHMENT 3 – WELL CONSTRUCTION DIAGRAMS AND DRILLING  
LOGS**

**ATTACHMENT 4 – MAPS OF THE DIRECTION OF GROUNDWATER FLOW**

**ATTACHMENT 5 – TABLES SUMMARIZING CONSTITUENT  
CONCENTRATIONS AT EACH MONITORING WELL**

**ATTACHMENT 6 – SITE HYDROGEOLOGY AND STRATIGRAPHIC CROSS-  
SECTIONS OF THE SITE**

**ATTACHMENT 7 – STRUCTURAL STABILITY ASSESSMENT**  
**ATTACHMENT 8 – SAFETY FACTOR ASSESSMENT**  
**ATTACHMENT 9 – ADDENDUM TO THE CLOSURE PLAN (SEPTEMBER  
2020)**

## LIST OF TABLES

	<b><u>Page No.</u></b>
Table 3-1: Joppa CCR Wastestreams .....	3-2
Table 3-2: Joppa Non-CCR Wastestreams .....	3-3
Table 6-1: Joppa East Ash Pond Closure Schedule .....	6-2

## LIST OF ABBREVIATIONS

<b><u>Abbreviation</u></b>	<b><u>Term/Phrase/Name</u></b>
CCR	Coal Combustion Residual
CFR	Code of Federal Regulations
Electric Energy	Electric Energy, Inc.
ELG Rule	Effluent Limitations Guidelines and Standards for the Steam Electric Power Generating Point Source Category
EPA	Environmental Protection Agency
Joppa	Joppa Power Station
RCRA	Resource Conservation and Recovery Act
SWPPP	Stormwater Pollution Prevention Plan



## **1.0 EXECUTIVE SUMMARY**

Electric Energy, Inc. (Electric Energy) submits this request to the U.S. Environmental Protection Agency (EPA) for approval of a site-specific alternative deadline to initiate closure pursuant to 40 C.F.R. § 257.103(f)(2) —“Permanent Cessation of a Coal-Fired Boiler(s) by a Date Certain”— for the East Ash Pond located at the Joppa Power Station (Joppa) in Illinois. The East Ash Pond is a 111-acre CCR surface impoundment used to manage CCR and non-CCR wastestreams at Joppa. As discussed herein, the boilers at the station will retire and the impoundment will complete closure no later than October 17, 2028. Therefore, Electric Energy is requesting an extension pursuant to 40 C.F.R. § 257.103(f)(2) so that the East Ash Pond may continue to receive CCR and non-CCR waste streams after April 11, 2021, and complete closure no later than October 17, 2028.

## 2.0 INTRODUCTION

Joppa is an 802-megawatt coal-fueled electric generating station near Joppa, Illinois, that utilizes the 111-acre East Ash Pond to manage sluiced bottom ash, economizer ash, non-marketable dry fly ash (when not hauled offsite for beneficial use), dredged material from the settling lagoon and cooling water intake, and non-CCR wastewaters. The northern portion of the impoundment was constructed in 1973 and the southern portion between the years of 1977 and 1985. The various non-CCR wastewaters routed to the East Ash Pond originate from the water treatment floor drain, demineralizer regeneration flows, reverse osmosis reject, and stormwater. A site plan is provided on Figure 1 in Appendix A, and the plant water balance diagram is included in Appendix B. Note that the East Ash Pond is referred to as the Ash Pond on the water balance diagram.

On April 17, 2015, the Environmental Protection Agency (“EPA”) issued the federal Coal Combustion Residual (CCR) Rule, 40 C.F.R. Part 257, Subpart D, to regulate the disposal of CCR materials generated at coal-fueled units. The rule is being administered under Subtitle D of the Resource Conservation and Recovery Act (RCRA, 42 U.S.C. § 6901 et seq.). On August 28, 2020, the EPA Administrator issued revisions to the CCR Rule that require all unlined surface impoundments to initiate closure by April 11, 2021, unless an alternative deadline is requested and approved. 40 C.F.R. § 257.101(a)(1) (85 Fed. Reg. 53,516 (Aug. 28, 2020)). Specifically, owners and operators of a CCR surface impoundment may continue to receive CCR and non-CCR wastestreams if the facility will cease operation of the coal-fired boiler(s) and complete closure of the impoundments within certain specified timeframes. 40 C.F.R. § 257.103(f)(2). To qualify for an alternative closure deadline under § 257.103(f)(2), a facility must meet the following four criteria:

1. **§ 257.103(f)(2)(i)** – No alternative disposal capacity is available on-site or off-site. An increase in costs or the inconvenience of existing capacity is not sufficient to support qualification.
2. **§ 257.103(f)(2)(ii)** - Potential risks to human health and the environment from the continued operation of the CCR surface impoundment have been adequately mitigated;
3. **§ 257.103(f)(2)(iii)** - The facility is in compliance with the CCR rule, including the requirement to conduct any necessary corrective action; and
4. **§ 257.103(f)(2)(iv)** - The coal-fired boilers must cease operation and closure of the impoundment must be completed within the following timeframes:
  - a. For a CCR surface impoundment that is 40 acres or smaller, the coal-fired boiler(s) must cease operation and the CCR surface impoundment must complete closure no later than October 17, 2023.

- b. For a CCR surface impoundment that is larger than 40 acres, the coal-fired boiler(s) must cease operation, and the CCR surface impoundment must complete closure no later than October 17, 2028.

Section 257.103(f)(2)(v) sets out the documentation that must be provided to EPA to demonstrate that the four criteria set out above have been met. Therefore, this demonstration is organized based on the documentation requirements of §§ 257.103(f)(2)(v)(A) – (D).

### **3.0 DOCUMENTATION OF NO ALTERNATIVE DISPOSAL CAPACITY**

To demonstrate that the criteria in § 257.103(f)(2)(i) has been met, the following provides documentation that no alternative disposal capacity is currently available on-site or off-site for each CCR and non-CCR wastestream that IPRG seeks to continue placing into the Ash Pond after April 11, 2021. Consistent with the regulations, neither an increase in costs nor the inconvenience of existing capacity was used to support qualification under this criteria. Instead, as EPA explained in the preamble to the proposed Part A revisions, “it would be illogical to require [] facilities [ceasing power generation] to construct new capacity to manage CCR and non-CCR wastestreams.” 84 Fed. Reg. 65,941, 65,956 (Dec. 2, 2019). EPA again reiterated in the preamble to the final revisions that “[i]n contrast to the provision under § 257.103(f)(1), the owner or operator does not need to develop alternative capacity because of the impending closure of the coal fired boiler. Since the coal-fired boiler will shortly cease power generation, it would be illogical to require these facilities to construct new capacity to manage CCR and non-CCR wastestreams.” 85 Fed. Reg. at 53,547. Thus, new construction or the development of new alternative disposal capacity was not considered a viable option for any wastestream discussed below.

#### **3.1 Site-Layout and Wastewater Processes**

The East Ash Pond receives all CCR sluice flows and a portion of the non-CCR wastewater flows onsite. Many of the remaining plant process flows are routed through the Settling Lagoon for treatment, as shown in Appendix B. The Settling Lagoon is not authorized to receive the CCR sluice flows and is not large enough to independently treat the total volume of the plant process water flows. Electric Energy constructed a new off-site CCR landfill in 2009 to receive scrubber by-products; however, the landfill was never made operational and is unable to receive sluiced materials. The landfill is currently unusable due to the deterioration of the landfill cell freeze protection layer and damage to the leachate collection system and cell perimeter berms. Additionally, since the landfill has never been operated, a landfill operator, leachate hauling contractor, and leachate disposal facility have not been retained.

#### **3.2 CCR Wastestreams**

Electric Energy evaluated each CCR wastestream placed in the East Ash Pond at Joppa. For the reasons discussed below in Table 3-1, each of the following CCR wastestreams must continue to be placed in the East Ash Pond at Joppa due to lack of alternative capacity both on and off-site.

**Table 3-1: Joppa CCR Wastestreams**

CCR Wastestreams	Average Flow (MGD)	Alternative Capacity Currently Available? YES/NO	Details
Bottom Ash, Economizer Ash, and non-CCR mill rejects Sluice	0.1	NO	There is no potential alternative for on or off-site disposal of this wet-generated CCR wastestream.
Dry Fly Ash (includes air heater ash)	NA (Dry)	NO	<p>The fly ash is collected dry and is currently conditioned and disposed in the East Ash Pond intermittently when not hauled offsite for beneficial use. Approximately 95% of the fly ash is beneficially reused off-site.</p> <p>The remaining conditioned fly ash is placed in the East Ash Pond, which will facilitate pond closure in the near future. This beneficial reuse of the fly ash will be reflected in the pond closure plan.</p> <p>Electric Energy does not have a CCR landfill or another CCR surface impoundment located onsite that is available or ready to accept this material. Consequently, there are currently no on-site alternatives for this wastestream.</p> <p>As discussed above, the CCR landfill constructed for Joppa in 2009 is inactive and would require significant repairs and/or improvements prior to receiving CCR material. Other offsite landfills are over 40 miles away from the site and Electric Energy does not have a contract with any of these landfills for this material.</p>

For the bottom ash sluice flow, there is no currently available onsite infrastructure to support dry handling of bottom ash or elimination of this wastestream. As stated previously, since Electric Energy has elected to pursue the option to permanently cease the use of the coal fired boilers by a date certain, developing alternative disposal capacity is “illogical,” to use EPA’s words, and also counterproductive to the work to retire the boilers and close the impoundments. As long as Electric Energy continues to wet handle the bottom ash, economizer ash, and mill reject materials, there are no other onsite CCR impoundments to receive and treat these flows and it is not feasible to dispose of the wet-handled material offsite. As EPA explained in the preamble of the 2015 rule, it is not possible for sites that sluice CCR material to an impoundment to eliminate the impoundment and dispose of the material offsite. *See* 80 Fed. Reg. 21,301, 21,423 (Apr. 17, 2015) (“[W]hile it is possible to transport dry ash off-site to [an] alternate disposal facility

that is simply not feasible for wet-generated CCR. Nor can facilities immediately convert to dry handling systems.”). As a result, the conditions at Joppa satisfy the demonstration requirement in § 257.103(f)(2)(i).

Any non-marketable dry fly ash must also be placed in the Joppa East Ash Pond due to lack of existing alternative capacity both on and off-site. Significant modifications would be required to dispose of the non-marketable dry fly ash in the Joppa inactive landfill, including modifications to current plant operations and improvements to the protective cover and the leachate collection and handling system at the landfill. Moreover, since Electric Energy has elected to pursue the option to permanently cease the use of the coal fired boilers by a date certain, developing this alternative disposal capacity would be “illogical,” to use EPA’s words, and also counterproductive to the work to retire the boilers and close the impoundments. Modifications to current plant operations would also be required to use other offsite landfills that are over 40 miles away; and having to transport the material such a distance to an offsite landfill would present safety concerns. Accordingly, the non-marketable fly ash must be placed in the only available onsite disposal location (i.e., the East Ash Pond) when not hauled offsite for beneficial use due to seasonal market impacts. Consequently, in order to continue to operate and generate electricity, Joppa must continue to use the 111-acre CCR surface impoundment to manage the CCR wastestreams discussed above.

### 3.3 Non-CCR Wastestreams

Electric Energy evaluated each non-CCR wastestream placed in the East Ash Pond at Joppa. For the reasons discussed below in Table 3-2, each of the following non-CCR wastestreams must continue to be placed in the East Ash Pond at Joppa due to lack of alternative capacity both on and off-site.

**Table 3-2: Joppa Non-CCR Wastestreams**

Non-CCR Wastestreams	Average Flow (MGD)	Alternative Capacity Currently Available? YES/NO	Details
Settling Lagoon and Cooling Water Intake Dredged Material	Intermittent	NO	The settling lagoon and cooling water intake require dredging to ensure the capacity of the settling lagoon and cooling water flow is maintained. The dredged material is then placed in the East Ash Pond. This stream requires significant retention time for TSS removal to meet the permitted discharge limits. A new treatment system and permit modifications would be required to reroute to a new or existing permitted outfall. There is no on-site alternative for this wastestream.

Non-CCR Wastestreams	Average Flow (MGD)	Alternative Capacity Currently Available? YES/NO	Details
Water Treatment Building Floor Drains (including wash waters and demineralizer regeneration flows)	0.01	NO	Permit modifications would be required, and additional piping would need to be installed to reroute to a new or existing permitted outfall
Reverse Osmosis Reject	0.1	YES	As required by the NPDES permit, this wastestream is currently piped to both the East Ash Pond and settling lagoon. The settling lagoon will serve as the alternative disposal capacity for this wastestream.
Ash Landfill Leachate	Intermittent	NO	As allowed by the NPDES permit, this wastestream would be trucked to the East Ash Pond for disposal. This flow will not occur unless the landfill modifications are completed, and the facility is placed in service.

The reverse osmosis reject wastewater can currently be discharged to the settling lagoon, as allowed by the NPDES permit. The settling lagoon serves as current and practical alternative disposal capacity for this wastestream; therefore, it is not a part of this request.

There is potential to discharge a portion of the remaining non-CCR flows to alternate locations; however, this would require permit modifications and installation of new piping and potentially a new treatment system including non-CCR ponds, clarifiers, and/or storage tank(s). As stated previously, since Electric Energy has elected to pursue the option to permanently cease the use of the coal fired boilers by a certain date, developing alternative disposal capacity is “illogical,” to use EPA’s words, and also counterproductive to the work to retire the boilers and close the impoundments. There is currently no existing installed infrastructure at the plant to support reroute of these flows (except the reverse osmosis reject). For the reasons discussed above, each of the remaining non-CCR wastestreams must continue to be placed in the East Ash Pond due to lack of alternative capacity both on and off-site. Consequently, in order to continue to operate and generate electricity, Joppa must continue to use the 111-acre East Ash Pond to manage the non-CCR wastestreams discussed above.

#### **4.0 RISK MITIGATION PLAN**

To demonstrate that the criteria in § 257.103(f)(2)(ii) has been met, Electric Energy has prepared and attached a Risk Mitigation Plan for the Joppa East Ash Pond (see Attachment 1).



## 5.0 DOCUMENTATION AND CERTIFICATION OF COMPLIANCE


In the Part A rule preamble, EPA reiterates that compliance with the CCR rule is a prerequisite to qualifying for an alternative closure extension, as it “provides some guarantee that the risks at the facility are properly managed and adequately mitigated.” 85 Fed. Reg. at 53,543. EPA further stated that it “must be able to affirmatively conclude that facility meets this criterion prior to any continued operation.” 85 Fed. Reg. at 53,543. Accordingly, EPA “will review a facility’s current compliance with the requirements governing groundwater monitoring systems.” 85 Fed. Reg. at 53,543. In addition, EPA will also “require and examine a facility’s corrective action documentation, structural stability documents and other pertinent compliance information.” 85 Fed. Reg. at 53,543. Therefore, EPA is requiring a certification of compliance and specific compliance documentation be submitted as part of the demonstration. 40 C.F.R. § 257.103(f)(2)(v)(C).

To demonstrate that the criteria in § 257.103(f)(2)(iii) has been met, Electric Energy is submitting the following information as required by § 257.103(f)(2)(v)(C):

### 5.1 Owner’s Certification of Compliance - § 257.103(f)(2)(v)(C)(1)

I hereby certify that, based on my inquiry of those persons who are immediately responsible for compliance with environmental regulations for the East Ash Pond at Joppa, the facility is in compliance with all of the requirements contained in 40 C.F.R. Part 257, Subpart D – Standards for the Disposal of Coal Combustion Residuals in Landfills and Surface Impoundments. The Joppa CCR compliance website is up-to-date and contains all the necessary documentation and notification postings.

**On behalf of Electric Energy:**



Cynthia Vodopivec  
VP - Environmental Health & Safety  
September 28, 2020

## **5.2 Visual representation of hydrogeologic information - § 257.103(f)(2)(v)(C)(2)**

Consistent with the requirements of § 257.103(f)(2)(v)(C)(2)(i) – (iii), Electric Energy has attached the following items to this demonstration:

- Map(s) of groundwater monitoring well locations in relation to the CCR unit (Attachment 2)
- Well construction diagrams and drilling logs for all groundwater monitoring wells (Attachment 3)
- Maps that characterize the direction of groundwater flow accounting for seasonal variations (Attachment 4)

## **5.3 Groundwater monitoring results - § 257.103(f)(2)(v)(C)(3)**

Tables summarizing constituent concentrations at each groundwater monitoring well through the first 2020 semi-annual monitoring period are included as Attachment 5.

## **5.4 Description of site hydrogeology including stratigraphic cross-sections - § 257.103(f)(2)(v)(C)(4)**

A description of the site hydrogeology and stratigraphic cross-sections of the site are included as Attachment 6.

## **5.5 Corrective measures assessment - § 257.103(f)(2)(v)(C)(5)**

Background sampling began at Joppa in late 2015 and continued for eight consecutive quarters. The first semiannual detection monitoring samples were collected in November 2017. The first assessment monitoring samples were collected in June 2018. The results, through the 2020 monitoring period, indicate that the Joppa East Ash Pond is currently in assessment monitoring, with no exceedances of the Appendix IV parameters. Accordingly, an assessment of corrective measures is not currently required at the site. Joppa will continue to conduct groundwater monitoring in accordance with all state and federal requirements.

## **5.6 Remedy selection progress report - § 257.103(f)(2)(v)(C)(6)**

As noted above, an assessment of corrective measures and the resulting selection of remedy is not currently required for the East Ash Pond.

## **5.7 Structural stability assessment - § 257.103(f)(2)(v)(C)(7)**

Pursuant to § 257.73(d), the initial structural stability assessment for the East Ash Pond was prepared in October 2016 and is included as Attachment 7.

### **5.8 Safety factor assessment - § 257.103(f)(2)(v)(C)(8)**

Pursuant to § 257.73(e), the initial safety factor assessment for the East Ash Pond was prepared in October 2016 and is included as Attachment 8.

## 6.0 DOCUMENTATION OF CLOSURE COMPLETION TIMEFRAME

To demonstrate that the criteria in § 257.103(f)(2)(iv) has been met, “the owner or operator must submit the closure plan required by § 257.102(b) and a narrative that specifies and justifies the date by which they intend to cease receipt of waste into the unit in order to meet the closure deadlines.” An addendum to the closure plan for the East Ash Pond is included as Attachment 9.

In order for a CCR surface impoundment over 40 acres to continue to receive CCR and non-CCR wastestreams after the initial April 11, 2021 deadline, the coal-fired boiler(s) at the facility must cease operation and the CCR surface impoundment must complete closure no later than October 17, 2028. As discussed below, Joppa will begin construction of the East Ash Pond closure by October 17, 2025, and cease placing wastestreams into the East Ash Pond by July 17, 2027, in order for closure to be completed by this deadline.

Table 6-1 is included below to summarize the major tasks and durations associated with closing the East Ash Pond in place. These durations are consistent with the durations experienced in the closure of over 500 acres of other CCR impoundments already completed by Electric Energy and its affiliates to date. The design, permitting, and procurement efforts will take place while the unit is still in operation. The first major construction effort will be to modify the pond operations by relocating the influent lines, minimizing the pond water levels, and isolating flow to a smaller portion of the current 111-acre impoundment that can be closed during the last two construction seasons. Electric Energy expects that the impoundment operating area will be reduced to approximately 40-50 acres during this effort. This reduction in footprint may require the addition of chemical feeds to provide adequate treatment with the reduction in residence time; however, it will simultaneously allow for continued operation of the plant to maintain generating capacity for the MISO markets and minimize the risk to the environment both by minimizing the potential for any impacts to groundwater and by opening up a significant portion of the remaining impoundment to allow for dewatering, grading, and closure.

Table 6-1 provides estimates for the estimated durations required to close a portion of the pond footprint after the date noted to begin closure construction (Phase 1), as well as the current estimates for the closure of the active area (Phase 2, remaining 40-50 acres). In order to dewater the closure area, Electric Energy will likely release pond water through the existing Outfall 001 and employ pumps as necessary, and potentially an engineered dewatering system such as wellpoints to aid in stabilizing the material. As the water level is lowered and the material is stabilized, the contractor will work across the pond re-grading the existing CCR material to achieve positive drainage. As grading is completed in certain areas, the contractor

may begin placing the final cover system which will consist of an 18-inch infiltration layer and 6-inch erosion layer in accordance with the requirements of the CCR Rule (or an alternative cover system that meets these minimum standards). The schedule for the Phase 1 cover installation will overlap with the Phase 1 grading schedule and is expected to finish approximately two months after the grading effort is completed. Once cover is placed, the area will be seeded and stabilized. The schedule for seeding and stabilizing will overlap with cover installation and finish approximately one month after the cover system is placed. Closure is essentially completed once the erosion control layer is placed, so the final month of this activity will provide additional float to the schedule.

**Table 6-1: Joppa East Ash Pond Closure Schedule**

Action	Estimated Timeline (Months)
Spec, bid, and Award Engineering Services for CCR Impoundment Closure	3
Finalize CCR unit closure plan and seek IEPA approval for CCR unit closure	12
Obtain environmental permits (based on IEPA approval of closure plan): <ul style="list-style-type: none"> <li>• State Waste Pollution Control Construction/Operating Permit</li> <li>• NPDES Industrial Wastewater Permit Modification</li> <li>• General NPDES Permit for Storm Water Discharges from Construction Site Activities and Storm Water Pollution Prevention Plan (SWPPP)</li> <li>• Proposed 35 Ill. Admin Code 845 operating permit application is due NLT September 2021. Construction permit application is anticipated to be due NLT July 2022.</li> </ul>	21
Spec, bid, and Award Construction Services for CCR Impoundment Closure	3
Begin Construction of Closure Date	October 17, 2025
Minimize Active Area of Impoundment / Dewater Phase 1 Area	6
Regrade CCR Material in Phase 1 Area	12
Install Cover System – Phase 1 area*	7
Establish Vegetation – Phase 1 Area**	2

Action	Estimated Timeline (Months)
Cease Placement of Waste	July 17, 2027
Dewater Impoundment – Phase 2 Area	3
Regrade CCR Material – Phase 2 Area	6
Install Cover System – Phase 2 Area	5
Establish Vegetation, Perform Site Restoration Activities, Complete Closure, and Initiate Post-Closure Care**	2
Total Estimated Time to Complete Closure	75 months
Date by Which Closure Must be Complete	October 17, 2028

\* Activity expected to overlap with grading operations, finishing 2 months after grading is completed.

\*\* Activity expected to overlap with cover system installation, finishing 1 month after cover installation is completed.

## 7.0 CONCLUSION

Based upon the information included in and attached to this demonstration, Electric Energy has demonstrated that the requirements of 40 C.F.R. § 257.103(f)(2) are satisfied for the 111-acre East Ash Pond at Joppa. This CCR surface impoundment is needed to continue to manage the CCR and non-CCR wastestreams identified in Section 3.2 and 3.3 above, is larger than 40 acres, and the boilers at the station will cease coal-fired operation and the East Ash Pond will be closed by the October 17, 2028 deadline. Therefore, this CCR unit qualifies for the site-specific alternative deadline for the initiation of closure authorized by 40 C.F.R. § 257.103(f)(2).

Therefore, it is requested that EPA approve Electric Energy's demonstration and authorize the East Ash Pond at Joppa to continue to receive CCR and non-CCR wastestreams notwithstanding the deadline in § 257.101(a)(1) and to grant the alternative deadline of October 17, 2028, by which to complete closure of the impoundment.

**APPENDIX A – SITE PLAN**







**PRELIMINARY - NOT FOR CONSTRUCTION**


0 400' 800' 1600'

SCALE IN FEET



 date 03/23/2020 designed A. MYERS	<b>LUMINANT</b> <b>JOPPA POWER STATION</b> <b>SITE PLAN</b>	project 122702
		contract -
		dwg <b>FIGURE 1</b> -

**APPENDIX B – WATER BALANCE DIAGRAM**



- Notes:
- Flows shown as: Average (Maximum)
  - Flow units = Million Gallons per Day
  - Outfall Average flows calculated from 2015 NPDES Permit and NPDES Outfall Average Flow Data
  - Maximum flows for Service Water, Circ. Water, Ash Handling, and Sumps calculated from pump maximum capacities
  - Wastewaters from rinsing/flushing:
    - Exteriors of Process Pumps
    - Heat Exchangers Flushing
    - Exteriors of Fans
    - Coal Conveyor Galleries/ Tripper Room
    - Exteriors of Coal Mills
    - I-Beams
    - Exteriors of Boiler & Auxiliary Equipment
    - Exteriors of Air Compressors
    - Floors & Walls
    - Misc. Exteriors of Process Equipment
  - Unnamed tributary of the Ohio River

Legend for water balance:

- a. NPDES Outfall
- b. Intermittent Flows
- c. Avg.(Max.) Flows
- d. Alternate Flows

1	4/12/18	PER FIELD CHANGE BY B.PARKER	CWB	BP	BP
0	1/15/18	RECORD REVISION	CWB	SDB	SDB
NO.	DATE	REVISIONS	BY	CHK'D	APP'D
<b>JOPPA GENERATING STATION</b>					
ELECTRIC ENERGY, INC. JOPPA, ILLINOIS					
DWG. TITLE:					
<b>WATER BALANCE DIAGRAM</b>					
SCALE: NONE			APPROVED BY:		
DATE: 1/15/2018			S.BLUEMNER 1/15/18		
DR. BY: S.BLUEMNER			DRAWING NO.		
CH. BY: S.BLUEMNER			00040552		
FILE NAME:					

**ATTACHMENT 1 – RISK MITIGATION PLAN**

# RISK MITIGATION PLAN - 40 C.F.R. § 257.103(f)(2)(v)(B)

## INTRODUCTION

---

To demonstrate that the criteria in §40 C.F.R. 257.103(f)(2)(ii) has been met, Electric Energy, Inc. (“Electric Energy”) has prepared this Risk Mitigation Plan for the East Ash Pond located at the Joppa Power Station (“Joppa”) in Joppa, Illinois.

- EPA is requiring a risk mitigation plan to “address the potential risk of continued operation of the CCR surface impoundment while the facility moves towards closure of their coal-fired boiler(s), to be consistent with the court’s holding in *USWAG* that RCRA requires EPA to set minimum criteria for sanitary landfills that prevent harm to either human health or the environment.” 85 Fed. Reg. at 53,516, 53,548 (Aug. 28, 2020).

As required by § 257.103(f)(2)(v)(B), the Risk Mitigation Plan must describe the “measures that will be taken to expedite any required corrective action,” and contain the three following elements:

- First, “a discussion of any physical or chemical measures a facility can take to limit any future releases to groundwater during operation.” § 257.103(f)(2)(v)(B)(1). In promulgating this requirement, EPA explained that this “might include stabilization of waste prior to disposition in the impoundment or adjusting the pH of the impoundment waters to minimize solubility of contaminants [and that] [t]his discussion should take into account the potential impacts of these measures on Appendix IV constituents.” 85 Fed. Reg. at 53,548.
- Second, “a discussion of the surface impoundment’s groundwater monitoring data and any found exceedances; the delineation of the plume (if necessary based on the groundwater monitoring data); identification of any nearby receptors that might be exposed to current or future groundwater contamination; and how such exposures could be promptly mitigated.” § 257.103(f)(2)(v)(B)(2).
- Third, “a plan to expedite and maintain the containment of any contaminant plume that is either present or identified during continued operation of the unit.” § 257.103(f)(2)(v)(B)(3). In promulgating this final requirement, EPA explained that “the purpose of this plan is to demonstrate that a plume can be fully contained and to define how this could be accomplished in the most accelerated timeframe feasible to prevent further spread and eliminate any potential for exposures.” 85 Fed. Reg. at 53,549. In addition, EPA stated that “this plan will be based on relevant site data, which may include groundwater chemistry, the variability of local hydrogeology, groundwater elevation and flow rates, and the presence of any surface water features that would influence rate and direction of contamination movement. For example, based on the rate and direction of groundwater flow and potential for diffusion of the plume, this plan could identify the design and spacing of extraction wells necessary to prevent further downgradient migration of contaminated groundwater.” 85 Fed. Reg. at 53,549.

Consistent with these requirements and guidance, Electric Energy plans to continue to mitigate the risks to human health and the environment from the Joppa East Ash Pond as detailed in this Risk Mitigation Plan.

## **1 OPERATIONAL MEASURES TO LIMIT FUTURE RELEASES TO GROUNDWATER– 40 C.F.R. § 257.101(F)(2)(v)(B)(1)**

---

The Joppa Pond is a 111-acre CCR surface impoundment. Consistent with the requirements of the CCR rule, compliance documents on Joppa’s CCR public website reflect the characterization of the Ash Pond as a single unit for purposes of groundwater monitoring and closure activities.

The Joppa CCR surface impoundment receives CCR transport waters from bottom ash and economizer ash plus non-CCR process waters onsite before discharging to the Ohio River via Outfall 001 in accordance with NPDES Permit No. IL0004171.

At Joppa, none of the Appendix IV parameter have reported SSLs, or SSLs above their respective Ground Water Protection Standards (GWPSs) as sampled and analyzed per the CCR surface impoundment’s groundwater monitoring program. Therefore, Joppa’s current physical treatment operation adequately limits potential risks to human health and the environment during operation. Joppa will continue this treatment process for the CCR surface impoundment until such time as closure is required per 40 CFR 257. The facility’s current physical treatment process is discussed below.

### **1.1 CURRENT OPERATION OF PHYSICAL TREATMENT**

---

Fly ash and air heater ash are captured dry. Therefore, current operations do not add fly ash transport waters to the CCR surface impoundment.

As part of normal operations, bottom ash and economizer ash are transported through the sluice lines into the CCR surface impoundment where it is dewatered and transported offsite for beneficial reuse. The CCR surface impoundment is also a wastewater treatment settling system which allows the solids to settle.

Therefore, since fly ash transport water is not conveyed to the CCR surface impoundment and bottom ash solids are removed from the CCR surface impoundment, the current operation of Joppa’s CCR surface impoundment limits future releases to groundwater during operation, and consequently no potential safety impacts or exposure to human health or environmental receptors are expected to result.

If Appendix IV releases are discovered per the facility’s groundwater monitoring program, Electric Energy will test, evaluate, and implement a chemical treatment method (i.e. pH adjustment, coagulation, precipitation, or other method as determined) for the Joppa CCR Impoundment to limit potential risks to human health and the environment during operation

## 2 GROUNDWATER IMPACTS, RECEPTORS, AND POTENTIAL EXPOSURE MITIGATION - 40 C.F.R. § 257.101(F)(2)(V)(B)(2)

---

The Joppa East Ash Pond, with a footprint of approximately 111 acres (Figure 1), currently remains in assessment monitoring. There have been no statistically significant levels (SSLs) of Appendix IV parameter concentrations since assessment monitoring was established on May 9, 2018 in accordance with 40 CFR § 257.95. The most recent summary of groundwater monitoring activities is provided in the “2019 Annual Groundwater Monitoring and Corrective Action Report, Joppa East Ash Pond, Joppa Power Station” (Ramboll, 2020) [see Attachment 1]. A summary of the assessment monitoring program is provided in Table 1. Since there have been no SSLs or GWPS exceedances to date, no plume delineation maps have been necessary.

### Receptors

Should a release to groundwater for one or more Appendix IV parameters occur in the future, the two primary risks to human health and the environment are via groundwater exposure and surface water exposure. Groundwater exposure would be via ingestion or dermal contact, both of which are likely an incomplete exposure pathway for CCR-related constituents originating from the Joppa East Ash Pond. Impacted groundwater potentially migrating to nearby water wells or surface water bodies – specifically the Ohio River bordering Joppa to the south – could be an exposure pathway but does not pose a risk for the reasons discussed below.

There are no surface-water intakes for community water supply (CWS) on the Ohio River identified within a one-mile radius of the Joppa property line. In addition, there are no non-CWS surface water intakes on the Ohio River within 2,500 feet of the site boundary.

There are no potable industrial, commercial, CWS or non-CWS water wells in a downgradient or cross-gradient groundwater flow direction relative to the Joppa East Ash Pond that are at risk of impacts from a release. There is one domestic (private) well within the Village of Joppa that is located potentially downgradient (south) of the East Ash Pond. Although the property on which this well is located may be served by the Village of Joppa’s CWS, the possibility that this well may be used for drinking water cannot be ruled out based on available information. However, since there are currently no exceedances of GWPS(s) for Appendix IV parameters in any monitoring wells at the East Ash Pond, the identified well, or any other wells within a 2,500-foot search radius of the Joppa Power Plant, are not currently at risk.

Ambient groundwater flow in the Uppermost Aquifer beneath the East Ash Pond is southward towards the Ohio River. Groundwater elevations vary seasonally and may fluctuate by about 10 feet. Slight seasonal variation in groundwater flow directions ranging from southeast to southwest are also observed; however, the major component of groundwater flow direction is consistently south toward the Ohio River, which is the primary discharge area for groundwater near Joppa (refer to the description of hydrogeology attached to the alternative closure demonstration letter).

Horizontal hydraulic gradients in the Uppermost Aquifer beneath the East Ash Pond typically range from 0.002 to 0.003 ft/ft. Groundwater flow velocity in the Uppermost Aquifer beneath the East Ash Pond ranges from 0.003 to 0.01 feet per day (ft/day) southward towards the Ohio River (refer to the description of hydrogeology attached to the alternative closure demonstration letter).

Exposure Mitigation

Mitigation of future potential exposures to groundwater contamination from continued operation of the Joppa East Ash Pond is discussed in detail in the following section.



### 3 CONTAMINANT PLUME CONTAINMENT: OPTIONS EVALUATION AND PLAN- 40 C.F.R. § 257.101(F)(2)(V)(B)(3)

---

Appropriate corrective measure(s) to address future potential impacted groundwater associated with the Joppa East Ash Pond are based on impacts to the Uppermost Aquifer. The Uppermost Aquifer consists of unlithified silty sand, sand, and gravel deposits within the McNairy Formation, which is approximately 85 feet thick near the East Ash Pond. The geometric mean horizontal hydraulic conductivity of the McNairy Formation based on field testing of monitoring wells around the East Ash Pond is  $2.4 \times 10^{-4}$  centimeters per second (cm/s). The overlying material (inclusive of both the Equality and Metropolis Formations) is a confining unit of clay, silty clay, sandy clay, and silt with a measured geometric mean hydraulic conductivity of  $5.9 \times 10^{-6}$  centimeters per second (cm/s). No known wells in the area utilize the Equality and Metropolis Formations for groundwater and most wells obtain groundwater from sands and gravels of the McNairy Formation (i.e. Uppermost Aquifer) or underlying Mississippian-age limestone bedrock, which generally occurs at depths greater than 100 feet (refer to the description of hydrogeology attached to the alternative closure demonstration letter).

Since there has been no release of Appendix IV parameters to groundwater above GWPS(s), which would trigger a Corrective Measures Assessment (CMA) under 40 C.F.R. § 257.96 based on specific parameter concentrations and contaminant plume dimensions, several options are evaluated to address potential future plume containments. The evaluation criteria for assessing remedial options are the following: performance; reliability; ease of implementation; potential impacts of the remedies (safety, cross-media, and control of exposure to residual contamination); time required to begin and complete the remedy; and, institutional requirements that may substantially affect implementation of the remedy(s), such as permitting, environmental or public health requirements.

Although future potential source control measures (e.g. closure in place, closure by removal to on-site or off-site landfill, in-situ solidification/stabilization) to mitigate groundwater impacts are typically considered as part of a CMA process upon closure of the Joppa East Ash Pond, the shorter-term options considered for mitigating groundwater impacts relative to a potential future release of one or more Appendix IV parameters at Joppa are as follows:

- Monitored Natural Attenuation (MNA)
- Groundwater Cutoff Wall
- In-Situ Chemical Treatment
- Permeable Reactive Barrier
- Groundwater Extraction

These same groundwater remedial corrective measures will be evaluated for all Appendix IV constituents that present a future risk to human health or the environment.

#### Monitored Natural Attenuation (MNA)

Upon notification of a release of one or more Appendix IV constituent(s) to groundwater, MNA will be evaluated with site-specific characterization data and geochemical analysis as a long term remedial option, combined with source control measures, through application of the USEPA's tiered approach to MNA (USEPA 1999, 2007 and 2015):

1. Demonstrate that the area of groundwater impacts is not expanding.

2. Determine the mechanisms and rates of attenuation.
3. Determine that the capacity of the aquifer is sufficient to attenuate the mass of constituents in groundwater and that the immobilized constituents are stable and will not remobilize.
4. Design a performance monitoring program based on the mechanisms of attenuation and establish contingency remedies (tailored to site-specific conditions) should MNA not perform adequately.

MNA is not regarded as a short-term remedial option for contaminant plume containment, but as a potential long-term option following implementation of shorter term control measures.

#### Groundwater Extraction

This corrective measure includes installation of a series of groundwater pumping wells or trenches to control and extract impacted groundwater. Groundwater extraction captures and contains impacted groundwater and can limit plume expansion and/or off-site migration. Construction of a groundwater extraction system typically includes, but is not limited to, the following primary project components:

- Designing and constructing a groundwater extraction system consisting of a series of extraction wells or trenches located around the perimeter of the contaminant plume and operating at a rate to allow capture of CCR impacted groundwater.
- Designing a system to manage extracted groundwater, which may include modification to the existing NPDES permit, including treatment prior to discharge, if necessary.
- Ongoing inspection and maintenance of the groundwater extraction system.

Installation of a groundwater extraction system, whether wells or trenches, can be expedited with the assumption that there is a good conceptual site model (CSM) of the hydrogeological system around the CCR unit, groundwater flow and transport model, and aquifer test if a well system is the best option for intercepting the groundwater contaminant plume. Upon notification of an SSL exceedance of a GWPS for one or more Appendix IV parameters, an aquifer test will be conducted, and groundwater model developed for designing a groundwater extraction system for optimization of contaminant plume capture.

A schematic of a typical groundwater extraction well is shown on Figure 2. Based on site specific hydrogeology and future potential plume width and depth, a groundwater extraction system will typically consist of one to three extraction wells with pitless adapter's manifolded together with HDPE conveyance pipe to a common tank or lined collection vault prior to treatment at the on-site wastewater treatment plant and discharge via the NPDES permitted outfall.

#### Groundwater Cutoff Wall

Vertical cutoff walls are used to control and/or isolate impacted groundwater. Low permeability cutoff walls can be used to prevent horizontal off-site migration of potentially impacted groundwater. Cutoff walls act as barriers to migration of impacted groundwater and can isolate soils that have been impacted by CCR to prevent contact with unimpacted groundwater. Cutoff walls are often used in conjunction with an interior pumping system to establish a reverse gradient within the cutoff wall. The reverse gradient maintains an inward flow through the wall, keeping it from acting as a groundwater dam and controlling potential end-around or breakout flow of contaminated groundwater.

A commonly used cutoff wall construction technology is the slurry trench method, which consists of excavating a trench and backfilling it with a soil-bentonite mixture, often created with the soils excavated from the trench. The

trench is temporarily supported with bentonite slurry that is pumped into the trench as it is excavated. Excavation for cutoff walls is conducted with conventional hydraulic excavators, hydraulic excavators equipped with specialized booms to extend their reach (*i.e.*, long-stick excavators), or chisels and clamshells, depending upon the depth of the trench and the material to be excavated. For a cutoff wall to be technically feasible, there must be a low-permeability lower confining layer into which the barrier can be keyed, and it must be at a technically feasible depth.

#### Permeable Reactive Barrier

Chemical treatment via a Permeable Reactive Barrier (PRB) is defined as an emplacement of reactive materials in the subsurface designed to intercept a contaminant plume, provide a flow path through the reactive media, and transform or otherwise render the contaminant(s) into environmentally acceptable forms to attain remediation concentration goals downgradient of the barrier (EPRI, 2006).

As groundwater passes through the PRB under natural gradients, dissolved constituents in the groundwater react with the media and are transformed or immobilized. A variety of media have been used or proposed for use in PRBs. Zero-valent iron has been shown to effectively immobilize CCR constituents, including arsenic, chromium, cobalt, molybdenum, selenium and sulfate. Zero-valent iron has not been proven effective for boron, antimony, or lithium (EPRI, 2006).

System configurations include continuous PRBs, in which the reactive media extends across the entire path of the contaminant plume; and funnel-and-gate systems, where barrier walls are installed to control groundwater flow through a permeable gate containing the reactive media. Continuous PRBs intersect the entire contaminant plume and do not materially impact the groundwater flow system. Design may or may not include keying the PRB into a low-permeability unit at depth. Funnel-and-gate systems utilize a system of barriers to groundwater flow (funnels) to direct the contaminant plume through the reactive gate. The barriers, typically some form of cutoff wall, are keyed into a low-permeability unit at depth to prevent short circuiting of the plume. Funnel-and-gate design must consider the residence time to allow chemical reactions to occur. Directing the contaminant plume through the reactive gate can significantly increase the flow velocity, thus reducing residence time.

Design of PRB systems requires rigorous site investigation to characterize the site hydrogeology and to delineate the contaminant plume. A thorough understanding of the geochemical and redox characteristics of the plume is critical to assess the feasibility of the process and select appropriate reactive media. Laboratory studies, including batch studies and column studies using samples of site groundwater, are needed to determine the effectiveness of the selected reactive media at the site (EPRI, 2006).

This is a potential viable option for groundwater corrective measures, to be evaluated further, but is not a short-term solution that can be implemented expeditiously.

#### In-Situ Chemical Treatment

In-situ chemical treatment for inorganics are being tested and applied with increasing frequency. In-situ chemical treatment includes the targeted injection of reactive media into the subsurface to mitigate groundwater impacts. Inorganic contaminants are typically remediated through immobilization by reduction or oxidation followed by precipitation or adsorption (EPRI, 2006). Chemical reactants that have been applied or are in development for application in treating inorganic contaminants include ferrous sulfate, nanoscale zero-valent iron, organo-phosphorus nutrient mixture (PrecipiPHOS™) and sodium dithionite (EPRI, 2006). Zero-valent iron has been shown to effectively immobilize cobalt and molybdenum. Implementation of in-situ chemical treatment requires detailed technical analysis of field hydrogeological and geochemical conditions along with laboratory studies.

This is a potential viable option for groundwater corrective measures, to be evaluated further, but is not a short-term solution that can be implemented expeditiously.

### 3.1 CONTAINMENT PLAN

---

Based on the options evaluated for containment of a future potential groundwater contaminant plume originating from the Joppa East Ash Pond for one or more Appendix IV constituents exceeding their GWPS(s), the most viable short-term option of those evaluated is a groundwater extraction well or recovery trench system, which would allow for capture of impacted groundwater and prevention of further plume migration towards the principal potential receptors, which have been identified as the Ohio River and one domestic (private) well within the Village of Joppa located potentially downgradient of the East Ash Pond.

In circumstances where there is not an immediate concern of endangerment to human health or the environment, other longer-term corrective measures may be more viable. The principal method under consideration for controlling potential future Appendix IV constituent releases is MNA. MNA is a potentially viable corrective measure that will be further evaluated for use at the Joppa East Ash Pond.

Depending on the location, depth, and plume geometry of any future potential Appendix IV exceedances of GWPSs, the specific constituent(s) with exceedances, and distance from potential receptors, the other groundwater corrective measures discussed as part of the corrective options evaluation – groundwater cutoff wall, permeable reactive barrier, and in-situ chemical treatment – are all secondary remedial alternatives available for consideration following the current primary options of groundwater extraction for short-term application and MNA for long-term application.

## 4 REFERENCES

---

Electric Power Research Institute (EPRI), 2006. Groundwater Remediation of Inorganic Constituents at Coal Combustion Product Management Sites, Overview of Technologies, Focusing on Permeable Reactive Barriers. Electric Power Research Institute, Palo Alto, California. Final Report 1012584, October 2006.

Ramboll, 2020. 2019 Annual Groundwater Monitoring and Corrective Action Report, Joppa East Ash Pond, Joppa Power Station. January 31, 2020.

USEPA, 1999. Use of Monitored Natural Attenuation at Superfund, RCRA Corrective Action, and Underground Storage Tank Sites. Directive No. 9200.U-17P. Washington, D.C.: EPA, Office of Solid Waste and Emergency Response.

USEPA, 2007. Monitored Natural Attenuation of Inorganic Contaminants in Ground Water, Volume 1 – Technical Basis for Assessment. EPA/600/R-07/139. National Risk Management Research Laboratory, Office of Research and Development, U.S. Environmental Protection Agency, Cincinnati, Ohio. October 2007.

USEPA, 2015. Use of Monitored Natural Attenuation for Inorganic Contaminants in Groundwater at Superfund Sites. Directive No. 9283.1-36. U.S. Environmental Protection Agency, Office of Solid Waste and Emergency Response. August 2015.

## TABLES

**Table 1 - Assessment Monitoring Program Summary, Joppa East Ash Pond**

Sampling Dates	Analytical Data Receipt Date	Parameters Collected	SSL(s) Appendix IV	SSL(s) Determination Date	ASD Completion Date	CMA Completion / Status
June 19, 2018	August 3, 2018	Appendix III Appendix IV	NA	NA	NA	NA
September 5, 2018	October 23, 2018	Appendix III Appendix IV Detected <sup>1</sup>	None	January 7, 2019	NA	NA
March 27, 2019	April 30, 2019	Appendix III Appendix IV	None	July 29, 2019	NA	NA
September 9, 2019	October 15, 2019	Appendix III Appendix IV Detected <sup>1</sup>	None	January 13, 2020	NA	NA
March 30, 2020	April 28, 2020	Appendix III Appendix IV Detected	None	July 27, 2020	NA	NA

[O: RAB 9/11/20; C: EJT 9/15/20]

**Notes:**

CMA = Corrective Measures Assessment


NA = Not Applicable

1. Groundwater sample analysis was limited to Appendix IV parameters detected in previous events in accordance with 40 C.F.R. Part 257.95(d)(1).

## FIGURES



Y:\Mapping\Projects\22285\MXD\JoppaHGMP\Figure 1\_Site and Well Location Map - Joppa East.mxd Author: stolzsd Date/Time: 9/28/2017 5:23:20 PM



Service Layer Credits: Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

- UPGRADIENT MONITORING WELL LOCATION
- DOWNGRADIENT MONITORING WELL LOCATION
- CCR MONITORED UNIT

DRAWN BY/DATE:  
SDS 9/27/17  
REVIEWED BY/DATE:  
JJW 9/27/17  
APPROVED BY/DATE:  
SJC 9/28/17


SITE AND WELL LOCATION MAP  
 JOPPA EAST ASH POND  
 UNIT ID: 401  
 HYDROGEOLOGIC MONITORING PLAN  
 DYNEGY CCR RULE GROUNDWATER MONITORING  
 JOPPA POWER STATION  
 JOPPA, ILLINOIS

PROJECT NO: 2285.5/1.1

FIGURE NO: 1

Natural Resource Technology  
AN OBG COMPANY

PROJECT: RAMBOLL PROJECT NUMBER DATED: 9/10/2020 5:12 PM DESIGNER: ENGELHSA  
 \\ramboll.sharepoint.com@SSL.DavWWWRoot\sites\vis\tra\Shared Documents\CCR GWD Drawings\CAD\Gradient Control Well.dwg



NOTES  
 1. NOT TO SCALE

## TYPICAL HYDRAULIC GRADIENT CONTROL WELL DETAIL

FIGURE 2

RAMBOLL US CORPORATION  
 A RAMBOLL COMPANY

Electric Energy, Inc.  
 JOPPA EAST ASH POND  
 JOPPA, ILLINOIS



**ATTACHMENT 1**

Prepared for

**Electric Energy, Inc.**

Document type

**2019 Annual Groundwater Monitoring and Corrective Action Report**

Date

**January 31, 2020**

# **2019 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT**

## **JOPPA EAST ASH POND, JOPPA POWER STATION**



Bright ideas. Sustainable change.

**2019 ANNUAL GROUNDWATER MONITORING AND  
CORRECTIVE ACTION REPORT  
JOPPA EAST ASH POND, JOPPA POWER STATION**

Project name **Joppa Power Station**  
Project no. **72757**  
Recipient **Electric Energy, Inc.**  
Document type **Annual Groundwater Monitoring and Corrective Action Report**  
Version **FINAL**  
Date **January 31, 2020**  
Prepared by **Kristen L. Theesfeld**  
Checked by **Nathaniel R. Keller**  
Approved by **Eric J. Tlachac**  
Description **Annual Report in Support of the CCR Rule Groundwater Monitoring Program**


Ramboll  
234 W. Florida Street  
Fifth Floor  
Milwaukee, WI 53204  
USA

T 414-837-3607  
F 414-837-3608  
<https://ramboll.com>



---

**Kristen L. Theesfeld**  
Hydrogeologist



---

**Nathaniel R. Keller**  
Senior Hydrogeologist

## CONTENTS

<b>EXECUTIVE SUMMARY</b>	<b>3</b>
1. <b>Introduction</b>	<b>4</b>
2. <b>Monitoring and Corrective Action Program Status</b>	<b>5</b>
3. <b>Key Actions Completed in 2019</b>	<b>6</b>
4. <b>Problems Encountered and Actions to Resolve the Problems</b>	<b>8</b>
5. <b>Key Activities Planned for 2020</b>	<b>9</b>
6. <b>References</b>	<b>10</b>

## TABLES

Table A	2018-2019 Assessment Monitoring Program Summary (in text)
Table 1	2019 Analytical Results – Groundwater Elevation and Appendix III Parameters
Table 2	2019 Analytical Results – Appendix IV Parameters
Table 3	Statistical Background Values
Table 4	Groundwater Protection Standards

## FIGURES

Figure 1	Monitoring Well Location Map
----------	------------------------------

## **ACRONYMS AND ABBREVIATIONS**

CCR	Coal Combustion Residuals
EAP	East Ash Pond
GWPS	Groundwater Protection Standard
SAP	Sampling and Analysis Plant
SSL	Statistically Significant Level

## EXECUTIVE SUMMARY

This report has been prepared to provide the information required by Title 40 of the Code of Federal Regulations (40 C.F.R.) § 257.90(e) for Joppa East Ash Pond (EAP) located at Joppa Power Station near Joppa, Illinois.

Groundwater is being monitored at Joppa EAP in accordance with the Assessment Monitoring Program requirements specified in 40 C.F.R. § 257.95.

No changes were made to the monitoring system in 2019 (no wells were installed or decommissioned).

No Statistically Significant Levels (SSLs) of 40 C.F.R. Part 257 Appendix IV parameters were determined in 2019 and Joppa EAP remains in the Assessment Monitoring Program.



## 1. INTRODUCTION

This report has been prepared by Ramboll on behalf of Electric Energy, Inc., to provide the information required by 40 C.F.R. § 257.90(e) for Joppa EAP located at Joppa Power Station near Joppa, Illinois.

In accordance with 40 C.F.R. § 257.90(e), the owner or operator of a Coal Combustion Residuals (CCR) unit must prepare an Annual Groundwater Monitoring and Corrective Action Report for the preceding calendar year that documents the status of the Groundwater Monitoring and Corrective Action Program for the CCR unit, summarizes key actions completed, describes any problems encountered, discusses actions to resolve the problems, and projects key activities for the upcoming year. At a minimum, the Annual Report must contain the following information, to the extent available:

1. A map, aerial image, or diagram showing the CCR unit and all background (or upgradient) and downgradient monitoring wells, to include the well identification numbers, that are part of the groundwater monitoring program for the CCR unit.
2. Identification of any monitoring wells that were installed or decommissioned during the preceding year, along with a narrative description of why those actions were taken.
3. In addition to all the monitoring data obtained under §§ 257.90 through 257.98, a summary including the number of groundwater samples that were collected for analysis for each background and downgradient well, the dates the samples were collected, and whether the sample was required by the Detection Monitoring or Assessment Monitoring Programs.
4. A narrative discussion of any transition between monitoring programs (e.g., the date and circumstances for transitioning from Detection Monitoring to Assessment Monitoring in addition to identifying the constituent(s) detected at a Statistically Significant Increase relative to background levels).
5. Other information required to be included in the Annual Report as specified in §§ 257.90 through 257.98.

This report provides the required information for Joppa EAP for calendar year 2019.

## **2. MONITORING AND CORRECTIVE ACTION PROGRAM STATUS**

No changes have occurred to the Monitoring Program status in calendar year 2019, and Joppa EAP remains in the Assessment Monitoring Program in accordance with 40 C.F.R. § 257.95.

### 3. KEY ACTIONS COMPLETED IN 2019

The Assessment Monitoring Program is summarized in Table A. The groundwater monitoring system, including the CCR unit and all background and downgradient monitoring wells is presented in Figure 1. No changes were made to the monitoring system in 2019 (no wells were installed or decommissioned). In general, one groundwater sample was collected from each background and downgradient well during each monitoring event. All samples were collected and analyzed in accordance with the Sampling and Analysis Plan (SAP) (NRT/OBG, 2017a). All monitoring data obtained under 40 C.F.R. §§ 257.90 through 257.98 (as applicable) in 2019 are presented in Tables 1 and 2. Analytical data were evaluated in accordance with the Statistical Analysis Plan (NRT/OBG, 2017b) to determine any SSLs of Appendix IV parameters over Groundwater Protection Standards (GWPSs).

Statistical background values are provided in Table 3 and GWPSs in Table 4.

Analytical results for the June and September 2018 sampling events were provided in the 2018 Annual Groundwater Monitoring and Corrective Action Report.

**Table A – 2018-2019 Assessment Monitoring Program Summary**

Sampling Dates	Analytical Data Receipt Date	Parameters Collected	SSL(s)	SSL(s) Determination Date
June 19, 2018	October 10, 2018	Appendix III Appendix IV	NA	NA
September 5, 2018	October 10, 2018	Appendix III Appendix IV Detected <sup>1</sup>	None	January 7, 2019
March 27, 2019	April 15, 2019	Appendix III Appendix IV	None	July 17, 2019
September 9, 2019	October 15, 2019	Appendix III Appendix IV Detected <sup>1</sup>	NA	TBD

**Notes:**

NA: Not Applicable

TBD: To Be Determined

1. Groundwater sample analysis was limited to Appendix IV parameters detected in previous events in accordance with 40 C.F.R. § 257.95(d)(1).

## **4. PROBLEMS ENCOUNTERED AND ACTIONS TO RESOLVE THE PROBLEMS**

No problems were encountered with the Groundwater Monitoring Program during 2019. Groundwater samples were collected and analyzed in accordance with the SAP (NRT/OBG, 2017a), and all data were accepted.

## 5. KEY ACTIVITIES PLANNED FOR 2020

The following key activities are planned for 2020:

- Continuation of the Assessment Monitoring Program with semi-annual sampling scheduled for the first and third quarters of 2020.
- Complete evaluation of analytical data from the downgradient wells, using GWPSs to determine whether an SSL of Appendix IV parameters has occurred.
- If an SSL is identified, potential alternate sources (i.e., a source other than the CCR unit caused the SSL or that that SSL resulted from error in sampling, analysis, statistical evaluation, or natural variation in groundwater quality) will be evaluated.
  - If an alternate source is demonstrated to be the cause of the SSL, a written demonstration will be completed within 90 days of SSL determination and included in the 2020 Annual Groundwater Monitoring and Corrective Action Report.
  - If an alternate source(s) is not identified to be the cause of the SSL, the applicable requirements of 40 C.F.R. §§ 257.94 through 257.98 (e.g., assessment of corrective measures) as may apply in 2020 will be met, including associated recordkeeping/notifications required by 40 C.F.R. §§ 257.105 through 257.108.

## 6. REFERENCES

Natural Resource Technology, an OBG Company (NRT/OBG), 2017a. Sampling and Analysis Plan, Joppa East Ash Pond, Joppa Power Station, Joppa, Illinois, Project No. 2285, Revision 0, October 17, 2017.

Natural Resource Technology, an OBG Company (NRT/OBG), 2017b, Statistical Analysis Plan, Joppa Power Station, Electric Energy, Inc., October 17, 2017.

## TABLES



**TABLE 1.**  
**2019 ANALYTICAL RESULTS - GROUNDWATER ELEVATION AND APPENDIX III PARAMETERS**  
**2019 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT**  
 JOPPA POWER STATION  
 UNIT ID 401 - JOPPA EAST ASH POND  
 JOPPA, ILLINOIS  
 ASSESSMENT MONITORING PROGRAM

Well Identification Number	Latitude (Decimal Degrees)	Longitude (Decimal Degrees)	Date & Time Sampled	Depth to Groundwater (ft) <sup>1</sup>	Groundwater Elevation (ft NAVD88)	40 C.F.R. Part 257 Appendix III						
						Boron, total (mg/L)	Calcium, total (mg/L)	Chloride, total (mg/L)	Fluoride, total (mg/L)	pH (field) (S.U.)	Sulfate, total (mg/L)	Total Dissolved Solids (mg/L)
						6020A <sup>2</sup>	6020A <sup>2</sup>	9251 <sup>2</sup>	9214 <sup>2</sup>	SM 4500 H+B <sup>2</sup>	9036 <sup>2</sup>	SM 2540C <sup>2</sup>
<b>Background / Upgradient Monitoring Wells</b>												
G01D	37.220429	-88.857179	3/27/2019 17:20	34.50	329.69	<0.025	25.1	8	0.23	6.7	30	310
			9/9/2019 17:37	42.75	321.44	<0.025	25.6	8	0.23	6.4	37	336
G02D	37.220715	-88.853311	3/27/2019 16:33	34.43	329.22	0.0473	38.7	20	0.20	6.6	20	262
			9/9/2019 17:08	42.37	321.28	0.0429	40.3	18	0.21	6.5	20	264
<b>Downgradient Monitoring Wells</b>												
G51D	37.216016	-88.855653	3/27/2019 16:07	34.57	329.28	0.778	34.7	6	<0.10	5.7	125	350
			9/9/2019 16:43	43.83	320.02	0.501	31.3	6	<0.10	5.3	109	320
G52D	37.209626	-88.852943	3/27/2019 17:49	19.68	328.73	<0.025	59.8	13	0.28	6.4	81	376
			9/9/2019 18:08	22.92	325.49	<0.025	52.2	14	0.27	6.0	78	370
G53D	37.215069	-88.849367	3/27/2019 15:00	27.20	328.27	0.269	30.5	12	0.59	6.6	54	272
			9/9/2019 15:12	36.99	318.48	0.385	42.2	18	0.67	6.2	80	364
G54D	37.212264	-88.857485	3/27/2019 15:45	30.73	326.30	1.03	115	22	0.35	6.8	142	510
			9/9/2019 16:00	42.95	314.08	0.614	79.9	<25	0.32	6.4	136	482

[O: RAB 12/23/19, KLT 12/24/19C: ]

**Notes:**  
 40 C.F.R. = Title 40 of the Code of Federal Regulations  
 ft = foot/feet  
 mg/L = milligrams per liter  
 NAVD88 = North American Vertical Datum of 1988  
 S.U. = Standard Units  
 < = concentration is less than the concentration shown, which corresponds to the reporting limit for the method; estimated concentrations below the reporting limit and associated qualifiers are not provided since not utilized in statistics to determine Statistically Significant Increases (SSIs) over background.  
<sup>1</sup>All depths to groundwater were measured on the first day of the sampling event.  
<sup>2</sup>4-digit numbers represent SW-846 analytical methods.

**TABLE 2.**  
**2019 ANALYTICAL RESULTS - APPENDIX IV PARAMETERS**  
**2019 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT**

JOPPA POWER STATION  
UNIT ID 401 - JOPPA EAST ASH POND  
JOPPA, ILLINOIS  
ASSESSMENT MONITORING PROGRAM

Well Identification Number	Latitude (Decimal Degrees)	Longitude (Decimal Degrees)	Date & Time Sampled	40 C.F.R. Part 257 Appendix IV															
				Antimony, total (mg/L)	Arsenic, total (mg/L)	Barium, total (mg/L)	Beryllium, total (mg/L)	Cadmium, total (mg/L)	Chromium, total (mg/L)	Cobalt, total (mg/L)	Fluoride, total (mg/L)	Lead, total (mg/L)	Lithium, total (mg/L)	Mercury, total (mg/L)	Molybdenum, total (mg/L)	Radium 226/228, Combined (pCi/L)	Selenium, total (mg/L)	Thallium, total (mg/L)	
				6020A <sup>1</sup>	6020A <sup>1</sup>	6020A <sup>1</sup>	6020A <sup>1</sup>	6020A <sup>1</sup>	6020A <sup>1</sup>	6020A <sup>1</sup>	6020A <sup>1</sup>	6020A <sup>1</sup>	6020A <sup>1</sup>	6020A <sup>1</sup>	7470A <sup>1</sup>	6020A <sup>1</sup>	903/904 <sup>1</sup>	6020A <sup>1</sup>	6020A <sup>1</sup>
<b>Background / Upgradient Monitoring Wells</b>																			
G01D	37.220429	-88.857179	3/27/2019 17:20	<0.0010	<0.0010	0.129	<0.0010	<0.0010	0.0030	0.0014	0.23	<0.0010	0.0015	<0.00020	<0.0015	0.78	0.0015	<0.0020	
			9/9/2019 17:37 <sup>2</sup>	NA	<0.0010	0.123	NA	NA	0.0044	0.0014	0.23	0.0012	<0.0030	NA	NA	0.79	0.0011	NA	
G02D	37.220715	-88.853311	3/27/2019 16:33	<0.0010	<0.0010	0.235	<0.0010	<0.0010	0.0026	<0.0010	0.20	<0.0010	<0.0015	<0.00020	<0.0015	0.12	0.0030	<0.0020	
			9/9/2019 17:08 <sup>2</sup>	NA	<0.0010	0.208	NA	NA	<0.0015	<0.0010	0.21	<0.0010	<0.0030	NA	NA	0.49	0.0021	NA	
<b>Downgradient Monitoring Wells</b>																			
G51D	37.216016	-88.855653	3/27/2019 16:07	<0.0010	<0.0010	0.0495	<0.0010	<0.0010	0.0016	0.0026	<0.10	<0.0010	0.0059	<0.00020	<0.0015	0.23	0.0050	<0.0020	
			9/9/2019 16:43 <sup>2</sup>	NA	<0.0010	0.0377	NA	NA	<0.0015	0.0017	<0.10	<0.0010	0.0057	NA	NA	0.36	0.0042	NA	
G52D	37.209626	-88.852943	3/27/2019 17:49	<0.0010	0.0064	0.271	<0.0010	<0.0010	<0.0015	0.0069	0.28	<0.0010	0.0028	<0.00020	<0.0015	0.58	<0.0010	<0.0020	
			9/9/2019 18:08 <sup>2</sup>	NA	0.0021	0.254	NA	NA	<0.0015	0.0022	0.27	<0.0010	<0.0030	NA	NA	1.54	<0.0010	NA	
G53D	37.215069	-88.849367	3/27/2019 15:00	<0.0010	<0.0010	0.101	<0.0010	<0.0010	<0.0015	<0.0010	0.59	<0.0010	<0.0015	<0.00020	<0.0015	0.17	<0.0010	<0.0020	
			9/9/2019 15:12 <sup>2</sup>	NA	<0.0010	0.128	NA	NA	<0.0015	0.0020	0.67	<0.0010	<0.0030	NA	NA	0.03	<0.0010	NA	
G54D	37.212264	-88.857485	3/27/2019 15:45	<0.0010	0.0011	0.120	<0.0010	<0.0010	<0.0015	0.0138	0.35	<0.0010	0.0037	<0.00020	<0.0015	0.42	<0.0010	<0.0020	
			9/9/2019 16:00 <sup>2</sup>	NA	<0.0010	0.128	NA	NA	<0.0015	0.0117	0.32	<0.0010	0.0037	NA	NA	0.84	<0.0010	NA	

[O: RAB 12/23/19, C: KLT 12/24/19]

**Notes:**

40 C.F.R. = Title 40 of the Code of Federal Regulations

mg/L = milligrams per liter

NA = Not Analyzed

pCi/L = picoCuries per liter

< = concentration is less than concentration shown, which corresponds to the reporting limit for the method; estimated concentrations below the reporting limit and associated qualifiers are not provided since not utilized in statistics to determine Statistically Significant Levels (SSLs) over Groundwater Protection Standards.

<sup>1</sup>4-digit numbers represent SW-846 analytical methods and 3-digit numbers represent Clean Water Act analytical methods.

<sup>2</sup>Only the parameters detected during the previous sampling events were analyzed during this sampling event, in accordance with 40 C.F.R. § 257.95(d)(1).

**TABLE 3.**  
**STATISTICAL BACKGROUND VALUES**  
**2019 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT**  
 JOPPA POWER STATION  
 UNIT ID 401 - JOPPA EAST ASH POND  
 JOPPA, ILLINOIS  
 ASSESSMENT MONITORING PROGRAM

Parameter	Statistical Background Value (UPL)
<b>40 C.F.R. Part 257 Appendix III</b>	
Boron (mg/L)	0.06
Calcium (mg/L)	46
Chloride (mg/L)	29
Fluoride (mg/L)	0.28
pH (S.U.)	6.2 / 6.9
Sulfate (mg/L)	180
Total Dissolved Solids (mg/L)	526

[O: RAB 12/23/19, C: KLT 12/24/19]

**Notes:**

40 C.F.R. = Title 40 of the Code of Federal Regulations

mg/L = milligrams per liter

S.U. = Standard Units

UPL = Upper Prediction Limit

**TABLE 4.**  
**GROUNDWATER PROTECTION STANDARDS**  
**2019 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT**  
 JOPPA POWER STATION  
 UNIT ID 401 - JOPPA EAST ASH POND  
 JOPPA, ILLINOIS  
 ASSESSMENT MONITORING PROGRAM

Parameter	Groundwater Protection Standard <sup>1</sup>
<b>40 C.F.R. Part 257 Appendix IV</b>	
Antimony (mg/L)	0.006
Arsenic (mg/L)	0.010
Barium (mg/L)	2
Beryllium (mg/L)	0.004
Cadmium (mg/L)	0.005
Chromium (mg/L)	0.10
Cobalt (mg/L)	0.037
Fluoride (mg/L)	4
Lead (mg/L)	0.015
Lithium (mg/L)	0.040
Mercury (mg/L)	0.002
Molybdenum (mg/L)	0.10
Radium 226+228 (pCi/L)	5
Selenium (mg/L)	0.05
Thallium (mg/L)	0.002

[O: RAB 12/23/19, C: KLT 12/24/19]

**Notes:**


40 C.F.R. = Title 40 of the Code of Federal Regulations

mg/L = milligrams per liter

pCi/L = picoCuries per liter

<sup>1</sup>Groundwater Protection Standard is the higher of the Maximum Contaminant Level / Health-Based Level or background.

## FIGURES



- UPGRADIENT MONITORING WELL LOCATION
- DOWNGRADIENT MONITORING WELL LOCATION
- CCR MONITORED UNIT

**MONITORING WELL LOCATION MAP  
JOPPA EAST ASH POND  
UNIT ID:401**

**2019 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT**  
VISTRA CCR RULE GROUNDWATER MONITORING  
JOPPA POWER STATION  
JOPPA, ILLINOIS


**FIGURE 1**

O'BRIEN & GERE ENGINEERS, INC.  
A RAMBOLL COMPANY



**ATTACHMENT 2 – MAP OF GROUNDWATER MONITORING WELL LOCATIONS**

Y:\Mapping\Projects\22285\MXD\JoppaHGMP\Figure 1\_Site and Well Location Map - Joppa East.mxd Author: stolzsd Date/Time: 9/28/2017 5:23:20 PM



Service Layer Credits: Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

DRAWN BY/DATE:  
SDS 9/27/17  
REVIEWED BY/DATE:  
JJW 9/27/17  
APPROVED BY/DATE:  
SJC 9/28/17

SITE AND WELL LOCATION MAP  
JOPPA EAST ASH POND  
UNIT ID: 401  
HYDROGEOLOGIC MONITORING PLAN  
DYNEGY CCR RULE GROUNDWATER MONITORING  
JOPPA POWER STATION  
JOPPA, ILLINOIS

PROJECT NO: 2285.5/1.1

FIGURE NO: 1





**ATTACHMENT 3 – WELL CONSTRUCTION DIAGRAMS AND DRILLING LOGS**

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/14/2015  
**Finish:** 8/14/2015  
**WEATHER:** Partly cloudy, calm, warm, mid-70s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** S. Keim

**BOREHOLE ID:** G01D  
**Well ID:** G01D  
**Surface Elev:** 361.50 ft. MSL  
**Completion:** 64.38 ft. BGS  
**Station:** 202,039.30N  
 831,716.11E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:		
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) Q <sub>p</sub> (tsf) Failure Type	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
	0/60 0%	BD					2			360	
	0/60 0%	BD					4			358	
	0/60 0%	BD					6			356	
	0/60 0%	BD					8			354	
	0/60 0%	BD					10	Blind drill - see G101 boring log		352	
	0/60 0%	BD					12			350	
	0/60 0%	BD					14			348	
	0/60 0%	BD					16			346	
	0/60 0%	BD					18			344	
	0/60 0%	BD					20			342	

**NOTE(S):** G01D installed in borehole.

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/14/2015  
**Finish:** 8/14/2015  
**WEATHER:** Partly cloudy, calm, warm, mid-70s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** S. Keim

**BOREHOLE ID:** G01D  
**Well ID:** G01D  
**Surface Elev:** 361.50 ft. MSL  
**Completion:** 64.38 ft. BGS  
**Station:** 202,039.30N  
 831,716.11E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:					
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) Q <sub>p</sub> (tsf)	Failure Type	Quadrangle: Joppa Township: 15S,3E Section 14, Tier 15S; Range 3E	▼ = 54.00 - During Drilling ▽ = 45.77 - 8/14/15 ▽ =	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
	0/60 0%	BD								22			340	
	0/60 0%	BD								24			338	
	0/60 0%	BD								26			336	
	0/60 0%	BD								28			334	
	0/60 0%	BD								30	Blind drill - see G101 boring log [Continued from previous page]		332	
	0/60 0%	BD								32			330	
	0/60 0%	BD								34			328	
	0/60 0%	BD								36			326	
	0/60 0%	BD								38			324	
										40			322	

**NOTE(S):** G01D installed in borehole.

# FIELD BORING LOG



CLIENT: Natural Resource Technology, Inc.  
 Site: Joppa Power Station  
 Location: Joppa, Illinois  
 Project: 15E0030  
 DATES: Start: 8/14/2015  
 Finish: 8/14/2015  
 WEATHER: Partly cloudy, calm, warm, mid-70s

CONTRACTOR: Bulldog Drilling, Inc.  
 Rig mfg/model: CME-750 ATV Drill  
 Drilling Method: 4/4" HSA, split spoon sampler  
 FIELD STAFF: Driller: J. Dittmaier  
 Helper: M. Hill  
 Eng/Geo: S. Keim

BOREHOLE ID: G01D  
 Well ID: G01D  
 Surface Elev: 361.50 ft. MSL  
 Completion: 64.38 ft. BGS  
 Station: 202,039.30N  
 831,716.11E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:		
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Qu (tsf) Qp (tsf) Failure Type	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
	0/48 0%	BD					42	Blind drill - see G101 boring log [Continued from previous page]		320	
9A	24/24 100%	SS	5-13 6-5 N=19	13		1.00	44	Strong brown (7.5YR5/6), moist, medium dense, silty, very fine- to coarse-grained SAND with trace small gravel.		318	
9B				20			46			316	
10A	22/24 92%	SS	2-3 3-4 N=6	20		1.50	48	Gray (10YR6/1) with 40% yellowish brown (10YR5/6) mottles, moist, stiff, SILT, few to little clay, trace fine- to medium-grained sand.		314	
11A	24/24 100%	SS	1-2 3-3 N=5	21		0.80	50	Gray (10YR6/1) with 30% yellowish brown (10YR5/6) mottles, moist, medium, silty CLAY, few fine- to medium-grained sand.		312	
12A	19/24 79%	SS	1-1 2-4 N=3	20		0.50	52			310	
13A	24/24 100%	SS	woh-1 2-3 N=3	19		0.50	54	Gray (10YR6/1) with 25% yellowish brown (10YR5/6) mottles, moist, medium, CLAY with few very fine- to fine-grained sand and trace silt.		308	
14A	19/24 79%	SS	14-18 20-24 N=38	14			56	Light yellowish brown (10YR6/4), moist, dense, silty, very fine- to fine-grained SAND.		306	
15A	16/24 67%	SS	woh-woh 5-13	23			58	Light yellowish brown (10YR6/4), wet, dense, silty, very fine- to fine-grained SAND.		304	
16A	20/24 83%	SS	4-21 25-21 N=46	18			60	Gray (10YR6/1), wet, dense, silty, very fine- to coarse-grained SAND.		302	

NOTE(S): G01D installed in borehole.

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/14/2015  
**Finish:** 8/14/2015  
**WEATHER:** Partly cloudy, calm, warm, mid-70s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** S. Keim

**BOREHOLE ID:** G01D  
**Well ID:** G01D  
**Surface Elev:** 361.50 ft. MSL  
**Completion:** 64.38 ft. BGS  
**Station:** 202,039.30N  
 831,716.11E

SAMPLE			TESTING				TOPOGRAPHIC MAP INFORMATION:			WATER LEVEL INFORMATION:		
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) Q <sub>p</sub> (tsf) Failure Type	Quadrangle: Joppa	Township: 15S;3E	Section 14, Tier 15S; Range 3E	▽ = 54.00 - During Drilling	▽ = 45.77 - 8/14/15	▽ =
Depth ft. BGS	Lithologic Description						Borehole Detail	Elevation ft. MSL	Remarks			
17A	23/24 96%	SS	7-15 32-37 N=47	19			Gray (10YR6/1), wet, dense, silty, very fine- to coarse-grained SAND. [Continued from previous page]					
18A	15/18 83%	SS	8-25 50/6"	17			Light brownish gray (10YR6/2), wet, dense, silty, very fine- to coarse-grained SAND with trace small gravel.					
	0/11 0%	BD										

End of boring = 64.38 feet

NOTE(S): G01D installed in borehole.

Surface Elevation: 361.12

Completion Date: \_\_\_\_\_

Datum msl

**WELL DIAGRAM**

Flushmount

Depth (ft)  
Elev. (ft)

DEPTH  
IN FEET

**DESCRIPTION OF MATERIAL**

GRAPHIC LOG

DRY UNIT WEIGHT (pcf)  
SPT BLOW COUNTS  
CORE RECOVERY/RQD

SAMPLES

Medium stiff to stiff, brown and gray, silty CLAY - (CL)

$k = 2.8 \times 10^{-8} \text{cm/s}$

5

10

15

20

25

trace sand

30

trace gravel and weathered limestone

Weathered LIMESTONE with silty clay

35

Stiff, brown and gray, silty CLAY with sand - CL

Medium stiff, brown and gray, silty CLAY, trace sand - CL

40

soft


45

very stiff, with weathered limestone

50

Boring terminated at 52 feet.

2-4-4-5	SS1
2-2-3-4	SS2
2-3-4-5	SS3
5-4-5-6	SS4
3-5-6-7	SS5
3-5-7-9	SS6
3-4-4-5	SS7
2-2-4-5	SS8
2-4-5-5	SS9
2-4-6-7	SS10
2-4-7-5	SS11
2-3-4-4	SS12
3-4-6-6	SS13
2-4-5-8	SS14
2-3-4-6	SS15
2-4-8-18	SS16
15-18-22 -22	SS17
7-7-6-6	SS18
2-3-4-4	SS19
3-3-4-4	SS20
1-2-2-1	SS21
1-4-6-7	SS22
4-10-12-6	SS23
3-4-4-4	SS24
1-2-3-3	SS25
2-3-4-6	SS26



NOTE: STRATIFICATION LINES REPRESENT THE APPROXIMATE BOUNDARIES BETWEEN SOIL TYPES  
LOG OF BORING 2002 WL J017150.02ENV - EEI JOPPA.GPJ GTINC 0638301.GPJ 9/22/10 AND THE TRANSITION MAY BE GRADUAL. GRAPHIC LOG FOR ILLUSTRATION PURPOSES ONLY.

**GROUNDWATER DATA**

**DRILLING DATA**

ENCOUNTERED AT 48 FEET  $\nabla$

AUGER  HOLLOW STEM  
WASHBORING FROM      FEET  
PH DRILLER BGF LOGGER  
     DRILL RIG  
HAMMER TYPE Auto

REMARKS:

Drawn by: KA      Checked by: RBP      App'vd. by: RBP  
Date: 7/14/10      Date: 9/24/10      Date: 9/24/10



Ash Pond Evaluation  
EEI Facility  
Joppa, Illinois

LOG OF BORING: G-101

Project No. J017150.02

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/12/2015  
**Finish:** 8/13/2015  
**WEATHER:** Sunny, warm, calm, lo-80s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** S. Keim

**BOREHOLE ID:** G02D  
**Well ID:** G02D  
**Surface Elev:** 360.82 ft. MSL  
**Completion:** 72.36 ft. BGS  
**Station:** 202,137.08N  
 832,842.99E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:		
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Qu (tsf) Qp (tsf) Failure Type	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
1A	20/24 83%	ss	1-1 2-3 N=3	24	2.00		1	Grayish brown (10YR5/2), moist, soft, SILT with few clay, trace very fine- to medium-grained sand, wood fragments, and roots.		360	
2A	24/24 100%	ss	1-3 5-5 N=8	23	2.50		2	Brown (10YR5/3) with 40% yellowish brown (10YR5/6) mottles, moist, stiff, SILT with few clay, trace very fine-grained sand and roots.		358	
3A	24/24 100%	ss	1-3 5-5 N=8	20	2.00		4			356	
4A	19/24 79%	ss	1-4 4-6 N=8	21	2.30		6	Brown (10YR5/3) with 40% yellowish brown (10YR5/6) and 10% gray (10YR6/1) mottles, moist, stiff, SILT with few clay, trace very fine-grained sand.		354	
5A	24/24 100%	ss	1-4 5-6 N=9	20	3.00		8			352	
6A	20/24 83%	ss	1-2 5-6 N=7	20	2.50		10	Gray (10YR6/1) with 30% yellowish brown (10YR5/6) mottles, moist, very stiff, SILT with few clay and trace very fine- to fine-grained sand.		350	
7A	22/24 92%	ss	1-5 7-11 N=12	18	3.00		12			348	
8A	19/24 79%	ss	2-9 13-18 N=22	15	4.50		14	Yellowish brown (10YR5/8) with 35% grayish brown (10YR5/2) mottles, moist, hard, SILT with few clay and trace very fine- to medium-grained sand.		346	
9A	24/24 100%	ss	4-8 11-15 N=19	17	3.00		16			344	
10A	18/24 75%	ss	1-7 10-14 N=17	16	3.50		18	Gray (10YR6/1) with 30% yellowish brown (10YR5/6) mottles, moist, very stiff, SILT with few clay and trace very fine- to fine-grained sand.		342	

NOTE(S): G02D installed in borehole.

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/12/2015  
**Finish:** 8/13/2015  
**WEATHER:** Sunny, warm, calm, lo-80s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4¼" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** S. Keim

**BOREHOLE ID:** G02D  
**Well ID:** G02D  
**Surface Elev:** 360.82 ft. MSL  
**Completion:** 72.36 ft. BGS  
**Station:** 202,137.08N  
 832,842.99E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:		
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) Q <sub>p</sub> (tsf) Failure Type	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
11A	21/24 88%	ss	2-8 12-17 N=20	15	4.00		22			340	
12A	22/24 92%	ss	4-9 12-13 N=21	16	4.00		24	Gray (10YR6/1) with 30% yellowish brown (10YR5/6) mottles, moist, very stiff, SILT with few clay and trace very fine- to fine-grained sand. [Continued from previous page]		338	
13A	24/24 100%	ss	3-8 11-11 N=19	17	3.00		26			336	
14A	20/24 83%	ss	2-6 8-9 N=14	16	2.50		28			334	
15A	22/24 92%	ss	1-5 7-8 N=12	19	3.30		30	Gray (10YR6/1) with 30% yellowish brown (10YR5/6) mottles, moist, very stiff, SILT with little clay and trace very fine- to fine-grained sand.		332	
16A	24/24 100%	ss	1-6 8-9 N=14	17	2.30		32	Yellowish brown (10YR5/4) with 10% gray (10YR6/1) mottles, moist, very stiff, SILT with few clay and very fine- to fine-grained sand, trace small gravel.		330	
17A	23/23 100%	ss	2-7 40-50/5" N=47	16	2.80		34	Strong brown (7.5YR4/6), moist, very stiff, SILT with little very fine- to coarse-grained sand and small to large gravel.		328	
18A	18/24 75%	ss	8-25 43-19 N=68	11			36	Strong brown (7.5YR4/6), moist, very dense, silty, very fine- to coarse-grained SAND with little small to large gravel.		326	
19A	24/24 100%	ss	1-3 4-30 N=7	22	0.80		38	Yellowish brown (10YR5/4) with 10% gray (10YR6/1) mottles, moist, medium, silty CLAY with few fine- to medium-grained sand, trace gravel.		324	
20A	12/16 75%	ss	6-35 50/4"	13			40	Strong brown (7.5YR4/6) moist, hard, SILT with little very fine- to coarse-grained sand and little small to large gravel.		322	

NOTE(S): G02D installed in borehole.



# FIELD BORING LOG



CLIENT: Natural Resource Technology, Inc.  
 Site: Joppa Power Station  
 Location: Joppa, Illinois  
 Project: 15E0030  
 DATES: Start: 8/12/2015  
 Finish: 8/13/2015  
 WEATHER: Sunny, warm, calm, lo-80s

CONTRACTOR: Bulldog Drilling, Inc.  
 Rig mfg/model: CME-750 ATV Drill  
 Drilling Method: 4/4" HSA, split spoon sampler  
 FIELD STAFF: Driller: J. Dittmaier  
 Helper: M. Hill  
 Eng/Geo: S. Keim

BOREHOLE ID: G02D  
 Well ID: G02D  
 Surface Elev: 360.82 ft. MSL  
 Completion: 72.36 ft. BGS  
 Station: 202,137.08N  
 832,842.99E

SAMPLE		TESTING				TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:					
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Qu (tsf) Qp (tsf) Failure Type	Quadrangle: Joppa Township: 15S;3E Section 14, Tier 15S; Range 3E	▼ = 43.00 - During Drilling ▽ = ▽ =	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
21A	9/9 100%	ss	39-50/37		11					Strong brown (7.5YR4/6) moist, hard, SILT with little very fine- to coarse-grained sand and little small to large gravel. <i>[Continued from previous page]</i>		320	
22A	8/24 33%	ss	5-14 17-8 N=31		15			▼	42	Brownish yellow (10YR6/6), moist, dense, silty, fine-grained SAND with trace medium- to coarse-grained sand.		318	
23A	24/24 100%	ss	1-2 3-4 N=5		22	0.50			44	Brownish yellow (10YR6/6), moist, medium, silty CLAY with few very fine- to medium-grained sand.		316	
24A	18/24 75%	ss	woh-woh 4-7		18	0.50			46	Brownish yellow (10YR6/6), moist, soft, CLAY with some very fine- to medium-grained sand and trace coarse-grained sand and trace small gravel.		314	
25A	20/24 83%	ss	1-2 6-5 N=8		18	0.80			48	Brownish yellow (10YR6/6), moist, medium, CLAY with some very fine- to medium-grained sand and trace coarse-grained sand and trace small gravel.		312	
26A	17/24 71%	ss	2-5 5-8 N=10		23	2.50			50			310	
27A	22/24 92%	ss	1-3 3-5 N=6		18	1.50			52	Gray (10YR6/1) with 40% yellowish brown (10YR5/6) mottles, moist, stiff, silty CLAY with few fine-grained sand.		308	
28A	24/24 100%	ss	woh-3 3-4 N=6		17	1.00			54			306	
29A	24/24 100%	ss	woh-4 5-5 N=9		22	3.00			56	Gray (10YR6/1), moist, medium, CLAY with some fine-grained sand and few silt.		304	
30A	20/24 83%	ss	2-4 6-6 N=10		19	2.00			58	Gray (10YR6/1) with 10% dark yellowish brown (10YR4/6) mottles, moist, stiff, SILT with few clay, trace fine-grained sand.		302	

NOTE(S): G02D installed in borehole.

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/12/2015  
**Finish:** 8/13/2015  
**WEATHER:** Sunny, warm, calm, lo-80s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4 1/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** S. Keim

**BOREHOLE ID:** G02D  
**Well ID:** G02D  
**Surface Elev:** 360.82 ft. MSL  
**Completion:** 72.36 ft. BGS  
**Station:** 202,137.08N  
 832,842.99E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:		
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Qu (tsf) Qp (tsf) Failure Type	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
31A	19/24 79%	SS	woh-1 4-14 N=5	20			62	Gray (10YR6/1) with 30% dark yellowish brown (10YR4/6) mottles, moist, medium, SILT with little clay and little very fine- to medium-grained sand.		300	
32A	16/24 67%	SS	3-14 18-25 N=32	20			64	Gray (10YR6/1), wet, dense, very fine- to coarse-grained SAND with some silt.		298	
33A	14/24 58%	SS	5-18 37-33 N=55	18			66	Gray (10YR6/1), wet, dense, very fine- to coarse-grained SAND with some silt and trace small to large gravel.		296	
34A	16/24 67%	SS	18-29 35-21 N=64	13			68	Brownish yellow (10YR6/6), wet, very dense, silty, very fine- to coarse-grained SAND and small to large GRAVEL.		294	
35A	14/24 58%	SS	20-24 30-30 N=54	16			70	Gray (10YR6/1), wet, very dense, silty, very fine- to coarse-grained SAND with trace small to large gravel.		292	
36A	16/24 67%	SS	12-19 37-28 N=56	14			72			290	
	0/4 0%	BD					72				

End of boring = 72.36 feet

NOTE(S): G02D installed in borehole.

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/17/2015  
**Finish:** 8/18/2015  
**WEATHER:** Partly cloudy, warm, mid-80s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** R. Hasenyager

**BOREHOLE ID:** G51D  
**Well ID:** G51D  
**Surface Elev:** 361.10 ft. MSL  
**Completion:** 59.90 ft. BGS  
**Station:** 200,430.10N  
 832,151.51E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:		
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) Q <sub>p</sub> (tsf) Failure Type	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
	0/60 0%	BD					2	Blind drill - see G151 boring log		360	
						4	358				
						6	356				
	0/60 0%	BD				8	354				
						10	352				
						12	350				
	0/60 0%	BD				14	348				
						16	346				
						18	344				
	0/60 0%	BD				20	342				

**NOTE(S):** G51D installed in borehole.

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/17/2015  
**Finish:** 8/18/2015  
**WEATHER:** Partly cloudy, warm, mid-80s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4 1/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** R. Hasenyager

**BOREHOLE ID:** G51D  
**Well ID:** G51D  
**Surface Elev:** 361.10 ft. MSL  
**Completion:** 59.90 ft. BGS  
**Station:** 200,430.10N  
 832,151.51E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:		
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) / Q <sub>p</sub> (tsf) Failure Type	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
	0/60 0%	BD					22			338	
	0/60 0%	BD					24			336	
	0/60 0%	BD					26			334	
	0/60 0%	BD					28			332	
	0/60 0%	BD					30	Blind drill - see G151 boring log [Continued from previous page]		330	
	0/60 0%	BD				32			328		
	0/60 0%	BD				34			326		
	0/60 0%	BD				36			324		
	0/60 0%	BD					38			322	
9A	24/24 100%	SS	6-7 4-4 N=11	22	1.50		40	Yellowish brown (10YR5/8) with 20% gray (10YR5/1) mottles, moist, medium, CLAY with few silt and little very fine- to fine-grained sand.		320	
							42				

**NOTE(S):** G51D installed in borehole.

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/17/2015  
**Finish:** 8/18/2015  
**WEATHER:** Partly cloudy, warm, mid-80s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** R. Hasenyager

**BOREHOLE ID:** G51D  
**Well ID:** G51D  
**Surface Elev:** 361.10 ft. MSL  
**Completion:** 59.90 ft. BGS  
**Station:** 200,430.10N  
 832,151.51E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:				
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) Q <sub>p</sub> (tsf) Failure Type	Quadrangle: Joppa Township: 15S,3E Section 14, Tier 15S; Range 3E	▼ = 39.50 - During Drilling ▼ = 34.91 - 8/18/15 ▼ =	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
10A	24/24 100%	ss	1-2 4-5 N=6	20	1.50		Yellowish brown (10YR5/8) with 20% gray (10YR5/1) mottles, moist, medium, CLAY with few silt and little very fine- to fine-grained sand. <i>[Continued from previous page]</i>		44		318		
11A	24/24 100%	ss	3-4 4-4 N=8	16	0.25			46	Yellowish brown (10YR5/8) with 50% gray (10YR6/1) mottles, moist, soft, very fine- to medium-grained SAND with some silt and little clay.		316		
12A	24/24 100%	ss	5-7 10-11 N=17	13	1.50			48	Yellowish brown (10YR5/8) with 50% gray (10YR6/1) mottles, moist, stiff, very fine- to medium-grained SAND with some silt, little clay, and trace small gravel.		314		
13A	20/24 83%	ss	5-12 14-15 N=26	15	0.25			50	Yellowish brown (10YR5/8) with 20% gray (10YR6/1) mottles, wet, loose, very fine- to medium-grained SAND with trace silt, trace clay and trace small gravel.		312		
14A	23/24 96%	ss	5-15 19-21 N=34	15	1.25			52			310		
15A	22/24 92%	ss	3-12 14-7 N=26	15	1.50			54			308		
16A	24/24 100%	ss	1-5 6-11 N=11	17	0.00			56	Strong brown (7.5YR5/8), wet, loose, very fine- to medium-grained SAND with trace silt, trace clay, and trace small gravel.		306		
17A	24/24 100%	ss	2-7 8-11 N=15	19	0.00			58			304		
	0/23 0%	BD								302	Drilled past end of sample interval		

End of boring = 59.9 feet

NOTE(S): G51D installed in borehole.

Surface Elevation: 360.9

Completion Date: 6/19/10

Datum msl

**WELL DIAGRAM**

Flushmount

Depth (ft)  
Elev. (ft)

DEPTH  
IN FEET

**DESCRIPTION OF MATERIAL**

GRAPHIC LOG

DRY UNIT WEIGHT (pcf)  
SPT BLOW COUNTS  
CORE RECOVERY/RQD

SAMPLES

GRAVEL

Medium stiff to stiff, brown and gray, silty CLAY - (CL)

5

10

15

20

25

30

35

40

45

50

$k = 1.6 \times 10^{-6} \text{ cm/s}$

Medium stiff to stiff, brown and gray, silty CLAY, trace sand - CL

Medium stiff to very stiff, brown and gray, sandy CLAY with silt - CL

Boring terminated at 42 feet.



SS1

3-4-4-5 SS2

2-3-3-5 SS3

3-3-4-4 SS4

1-2-3-5 SS5

3-5-5-6 SS6

2-4-5-6 SS7

2-3-4-5 SS8

3-4-6-7 SS9

3-4-6-6 SS10

3-5-7-8 SS11

3-5-7-9 SS12

2-3-5-6 SS13

3-5-7-6 SS14

3-5-8-8 SS15

4-7-9-4 SS16


4-4-6-7 SS17

2-4-3-5 SS18

5-5-7-14 SS19

13-13-10-8 SS20

2-4-6-7 SS21



NOTE: STRATIFICATION LINES REPRESENT THE APPROXIMATE BOUNDARIES BETWEEN SOIL TYPES AND THE TRANSITION MAY BE GRADUAL. GRAPHIC LOG FOR ILLUSTRATION PURPOSES ONLY.

**GROUNDWATER DATA**

FREE WATER NOT ENCOUNTERED DURING DRILLING

**DRILLING DATA**

AUGER  HOLLOW STEM WASHBORING FROM      FEET

PH DRILLER  BGF LOGGER

DRILL RIG

HAMMER TYPE Auto

Drawn by: KA      Checked by: RDP      App'vd. by: RDP  
Date: 7/14/10      Date: 9/20/10      Date: 9/20/10



Ash Pond Evaluation  
EEI Facility  
Joppa, Illinois

REMARKS:

LOG OF BORING: G-151

Project No. J017150.02

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/18/2015  
**Finish:** 8/19/2015  
**WEATHER:** Overcast, humid, mid-70s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** R. Hasenyager

**BOREHOLE ID:** G52D  
**Well ID:** G52D  
**Surface Elev:** 345.88 ft. MSL  
**Completion:** 80.01 ft. BGS  
**Station:** 198,098.93N  
 832,927.89E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:			
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) Q <sub>p</sub> (tsf) Failure Type	TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:			
							Depth ft. BGS	Lithologic Description	▼ = 28.45 - During Drilling ▼ = ▼ =	Borehole Detail	Elevation ft. MSL	Remarks
	0/60 0%	BD					2				344	
	0/60 0%	BD					4				342	
	0/60 0%	BD					6				340	
	0/60 0%	BD					8				338	
	0/60 0%	BD					10	Blind drill - see G152 boring log			336	
	0/60 0%	BD					12				334	
	0/60 0%	BD					14				332	
	0/60 0%	BD					16				330	
	0/60 0%	BD					18				328	
	0/60 0%	BD					20				326	

**NOTE(S):** G52D installed in borehole.

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/18/2015  
**Finish:** 8/19/2015  
**WEATHER:** Overcast, humid, mid-70s


**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** R. Hasenyager

**BOREHOLE ID:** G52D  
**Well ID:** G52D  
**Surface Elev:** 345.88 ft. MSL  
**Completion:** 80.01 ft. BGS  
**Station:** 198,098.93N  
 832,927.89E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:		
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) Q <sub>p</sub> (tsf) Failure Type	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
	0/60 0%	BD					22			324	
	0/60 0%	BD					24			322	
	0/60 0%	BD					26			320	
	0/60 0%	BD					28			318	
	0/60 0%	BD					30			316	
	0/60 0%	BD					32			314	
	0/60 0%	BD					34			312	
	0/60 0%	BD					36			310	
	0/60 0%	BD					38			308	
	0/24 0%	BD					40			306	
							42			304	

**TOPOGRAPHIC MAP INFORMATION:**  
**Quadrangle:** Joppa  
**Township:** 15S,3E  
**Section 14, Tier 15S; Range 3E**

**WATER LEVEL INFORMATION:**  
 ▽ = 28.45 - During Drilling  
 ▽ =  
 ▽ =



**NOTE(S):** G52D installed in borehole.



# FIELD BORING LOG



CLIENT: Natural Resource Technology, Inc.  
 Site: Joppa Power Station  
 Location: Joppa, Illinois  
 Project: 15E0030  
 DATES: Start: 8/18/2015  
 Finish: 8/19/2015  
 WEATHER: Overcast, humid, mid-70s

CONTRACTOR: Bulldog Drilling, Inc.  
 Rig mfg/model: CME-750 ATV Drill  
 Drilling Method: 4 1/4" HSA, split spoon sampler  
 FIELD STAFF: Driller: J. Dittmaier  
 Helper: M. Hill  
 Eng/Geo: R. Hasenyager

BOREHOLE ID: G52D  
 Well ID: G52D  
 Surface Elev: 345.88 ft. MSL  
 Completion: 80.01 ft. BGS  
 Station: 198,098.93N  
 832,927.89E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:				
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) Q <sub>p</sub> (tsf) Failure Type	Quadrangle: Joppa Township: 15S,3E Section 14, Tier 15S; Range 3E	▼ = 28.45 - During Drilling ▽ = ▽ =	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
10A	24/24 100%	ss	3-3 5-6 N=8	22	3.75				44	Gray (10YR5/1) with 40% yellowish brown (10YR5/8) mottles, moist, medium, CLAY with some silt and trace very fine-grained sand.		302	
11A	24/24 100%	ss	3-3 4-6 N=7	21	3.75				46			300	
12A				20	3.50				48	Gray (10YR6/1), moist, medium, SILT with some very fine-grained sand and trace clay.		298	
12B	24/24 100%	ss	3-4 4-7 N=8	23					50			296	
13A	24/24 100%	ss	2-4 5-6 N=9	23					52	Gray (10YR5/1) with 30% yellowish brown (10YR5/8) mottles, moist, medium, CLAY with some silt and trace very fine-grained sand.		294	
14A	24/24 100%	ss	5-7 8-10 N=15	20	4.00				54	Gray (10YR6/1) with 15% yellowish brown (10YR5/8) mottles, moist, stiff, CLAY with some silt and trace very fine-grained sand.		292	
15A	24/24 100%	ss	1-4 4-5 N=8	24	2.50				56	Gray (10YR6/1) with 10% yellowish brown (10YR5/8) mottles, moist, medium, SILT with few very fine-grained sand and little clay.		290	
16A	24/24 100%	ss	2-3 7-7 N=10	24	2.50				58	Gray (10YR6/1), moist, soft, CLAY with some silt and trace very fine-grained sand.		288	
16B				20					60	Gray (10YR6/1) with 10% yellowish brown (10YR5/8) mottles, moist, soft, SILT with little clay and very fine-grained sand.		286	
17A	24/24 100%	ss	4-4 7-9 N=11	21	3.75				62	Gray (10YR6/1), moist, soft, CLAY with some silt and trace very fine-grained sand.		284	
18A	24/24 100%	ss	2-6 7-7 N=13	24	3.25					Gray (10YR6/1), moist, medium, interbedded (0.1-0.2') SILT and very fine-grained SAND with few clay and CLAY with some silt and trace very fine-grained sand.			
19A	22/24 92%	ss	3-3 4-4 N=7	20	2.25								
	24/24		2-3							Gray (10YR6/1), moist, medium, SILT with very fine-grained sand and few clay.			

NOTE(S): G52D installed in borehole.

# FIELD BORING LOG



CLIENT: Natural Resource Technology, Inc.  
 Site: Joppa Power Station  
 Location: Joppa, Illinois  
 Project: 15E0030  
 DATES: Start: 8/18/2015  
 Finish: 8/19/2015  
 WEATHER: Overcast, humid, mid-70s

CONTRACTOR: Bulldog Drilling, Inc.  
 Rig mfg/model: CME-750 ATV Drill  
 Drilling Method: 4 1/4" HSA, split spoon sampler  
 FIELD STAFF: Driller: J. Dittmaier  
 Helper: M. Hill  
 Eng/Geo: R. Hasenyager

BOREHOLE ID: G52D  
 Well ID: G52D  
 Surface Elev: 345.88 ft. MSL  
 Completion: 80.01 ft. BGS  
 Station: 198,098.93N  
 832,927.89E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:					
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) / Q <sub>p</sub> (tsf)	Failure Type	Quadrangle: Joppa Township: 15S,3E Section 14, Tier 15S; Range 3E	▼ = 28.45 - During Drilling ▽ = ▽ =	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
20A	100%	ss	5-6 N=8	23		2.25				64			282	
21A	24/24 100%	ss	4-4 6-7 N=10	23		4.25				66	Gray (10YR6/1), moist, medium, SILT with very fine-grained sand and few clay. [Continued from previous page]		280	
22A	24/24 100%	ss	3-4 8-9 N=12	19		2.00				68			278	
23A	24/24 100%	ss	2-7 6-6 N=13	22		2.50				70			276	
24A	24/24 100%	ss	wor-6 9-9 N=15	22		2.50				72	Gray (10YR6/1) with 20% yellowish brown (10YR5/8) mottles, moist, stiff, SILT and very fine-grained SAND with few clay.		274	
25A	24/24 100%	ss	wor-3 5-7 N=8	22		2.25				74	Gray (10YR6/1), wet, dense, SILT and very fine-grained SAND with trace clay.		272	
26A				17						74	Gray (10YR6/1), wet, loose, very fine- to medium-grained SAND with trace silt.		272	
26B	24/24 100%	ss	6-7 8-9 N=15	22		3.25				76			270	Rods dropped, no blows
27A	24/24 100%	ss		22		2.75				78	Yellowish brown (10YR5/8) with 10% gray (10YR5/1) mottles, moist, stiff, CLAY with some silt and trace very fine-grained sand.		268	
28A	22/24 92%	ss	woh-3 6-7 N=9	27		3.25				80			266	

End of boring = 80.01 feet

NOTE(S): G52D installed in borehole.

Surface Elevation: 348.56

Completion Date: \_\_\_\_\_

Datum msl

**WELL DIAGRAM**

Flushmount

Depth (ft)  
Elev. (ft)

DEPTH  
IN FEET

**DESCRIPTION OF MATERIAL**

GRAPHIC LOG

DRY UNIT WEIGHT (pcf)  
SPT BLOW COUNTS  
CORE RECOVERY/ROD

SAMPLES

Medium stiff, brown CLAY with organics - CH

Medium stiff, brown and gray, silty CLAY - (CL)

becoming stiff


trace sand to 25 feet

$k = 1.1 \times 10^{-8}$  cm/s

Boring terminated at 25 feet.



2-3-3-4 SS1  
1-1-2-3 SS2  
1-2-3-5 SS3  
2-3-4-5 SS4  
1-3-4-4 SS5  
2-3-5-5 SS6  
2-5-8-9 SS7  
2-5-3-6 SS8  
3-5-5-7 SS9  
3-4-7-6 SS10  
~~3-6-10-9~~ SS11  
2-4-5-5 SS12



NOTE: STRATIFICATION LINES REPRESENT THE APPROXIMATE BOUNDARIES BETWEEN SOIL TYPES  
LOG OF BORING 2002 WL J017150.02 ENV - EEI JOPPA.GPJ GTINC 0638301.GPJ 9/22/10 AND THE TRANSITION MAY BE GRADUAL. GRAPHIC LOG FOR ILLUSTRATION PURPOSES ONLY.

**GROUNDWATER DATA**

**DRILLING DATA**

ENCOUNTERED AT 20 FEET  $\nabla$

AUGER  HOLLOW STEM  
WASHBORING FROM      FEET  
PH DRILLER BGF LOGGER  
ATV DRILL RIG  
HAMMER TYPE Auto

REMARKS:

Drawn by: KA      Checked by: KSR      App'vd. by: KSR  
Date: 7/14/10      Date: 9/20/10      Date: 9/20/10



Ash Pond Evaluation  
EEI Facility  
Joppa, Illinois

LOG OF BORING: G-152

Project No. J017150.02













SOIL BORING LOG INFORMATION



Facility/Project Name <b>Joppa Power Station (EEI)</b>		License/Permit/Monitoring Number		Boring Number <b>G152B</b>	
Boring Drilled By: Name of crew chief (first, last) and Firm <b>Matt Cooper Bulldog Drilling, Inc.</b>		Date Drilling Started <b>1/28/2013</b>		Date Drilling Completed <b>1/30/2013</b>	
Common Well Name <b>G152B</b>		Final Static Water Level <b>312.3 Feet (NAVD88)</b>		Surface Elevation <b>345.2 Feet (NAVD88)</b>	
				Borehole Diameter <b>7.8 inches</b>	
Local Grid Origin <input checked="" type="checkbox"/> (estimated: <input type="checkbox"/> ) or Boring Location <input type="checkbox"/>		State Plane <b>Illinois East Zone N, E S/C/N</b>		Local Grid Location <input checked="" type="checkbox"/> N <input checked="" type="checkbox"/> E <input type="checkbox"/> S <input type="checkbox"/> W	
1/4 of Section , T N, R		Lat _____ ' _____ "		198094.58 Feet <input type="checkbox"/> S 832931.61 Feet <input type="checkbox"/> W	
Facility ID		County <b>Massac</b>		State <b>Illinois</b>	
				Civil Town/City/ or Village <b>Joppa</b>	

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	PID 10.6 eV Lamp	Soil Properties					RQD/ Comments	
									Compressive Strength (tsf)	Moisture Content	Liquid Limit	Plasticity Index	P 200		
1	42 19		0 - 0.75'	<b>SILTY CLAY</b> CL, disturbed with gravel, tree limbs, wood from clearing activities; dark brown, wet.	CL										PP 2 - 2.25
			0.75 - 4.5'	<b>SILTY CLAY</b> CL, light yellowish brown (10YR 6/4), high plasticity, very soft to soft, silty clay with organics (roots), soft, high plasticity, light yellowish brown (10YR 6/4), moist.	CL										
2	60 56		4'	Silty Clay grading to a Clayey Silt, low plasticity, stiff, light gray (10YR 7/1), with 50% reddish brown mottling, moist.											
			4.5 - 12.5'	<b>SILT</b> : ML, non plastic, stiff, very pale brown (10YR 8/2), dry.											
			7.3'	soil horizon with small rootlets, 50% reddish brown mottling.											
			7.5'	very pale brown (10YR 8/2), non plastic, stiff, dry.											
3	60 58		9'	silt with clay, very stiff, non plastic, very pale brown (10YR 7/3) with 10-25% reddish brown mottling.	ML										

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature	Firm <b>Natural Resource Technology</b>	Tel: (262) 523-9000
	23713 W. Paul Road Suite D, Pewaukee, WI 53072	Fax: (262) 523-9001

Sample		Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	PID 10.6 eV Lamp	Soil Properties					RQD/ Comments
Number and Type	Length Att. & Recovered (in)								Compressive Strength (tsf)	Moisture Content	Liquid Limit	Plasticity Index	P 200	
4	60 60		12.5 - 28.5' <b>SILTY CLAY</b> CL, medium to stiff, low to medium plasticity, light gray (10YR 7/1), with 50% mottling, moist.	CL				2					PP 2.5 - 3.5	
		13	13.5' 10-50% reddish brown mottling.					2						
		14	15' light gray (10YR 7/1).					2.5						
		15						2.25						
5	60 60		18' yellowish brown (10YR 6/8) mottling, moist.	CL				18					PP 2.5 - 3.5	
		19	18.5' medium to stiff, medium to high plasticity, light gray (10YR 7/1), with 10-25% reddish brown mottling, moist.					2.25						
		20						2.5						
		21						1.75						
6	60 60		23.5' medium to stiff, high plasticity, light gray (10YR 7/1), with 25-50% reddish brown mottling, moist.	CL				23					PP 2.5 - 3.5	
		24						1.75						
		25						2						
		26						1.5						
NR	12 0		28.5 - 29.5' CL.	CL				27					stopped sampling for the day (1/28/13), cleaned hole with augers to 29.5' resumed sampling on 1/30/2013	
		28						2						
		29						2.75						
		30						3.25						
7	60 44		29.5 - 44.5' <b>SILTY CLAY</b> CL, stiff, medium to high plasticity, gray with >75% light yellowish brown (10YR 6/4) mottling, moist.	CL				31					stopped sampling for the day (1/28/13), cleaned hole with augers to 29.5' resumed sampling on 1/30/2013	
		32	31.5' 25-75% mottling.											

Sample		Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	PID 10.6 eV Lamp	Soil Properties					RQD/ Comments
Number and Type	Length Att. & Recovered (in)								Compressive Strength (tsf)	Moisture Content	Liquid Limit	Plasticity Index	P 200	
8	60 57		29.5 - 44.5'	<b>SILTY CLAY</b> CL, stiff, medium to high plasticity, gray with >75% light yellowish brown (10YR 6/4) mottling, moist. <i>(continued)</i>	CL				3.5					
			33'	33' very stiff to hard, gray (10YR 6/1), with < 25% yellowish brown (10YR 6/8) mottling.					4.5					
			34'	34.5' stiff to very stiff, high plasticity.					2.5					
			35'						3.5					
			36'						2.5					
			37'						4.25					
			38'	38' hard, < 10% mottling.					2.5					
		9	60 55						39.5'	39.5' very stiff to hard, high plasticity, gray (10YR 6/1) with < 10% yellowish brown (10YR 5/6) mottling, moist.				
	40'				3									
	41'				3									
	42'				3									
	43'				4.5									
	44'				3.75									
				44.5'	End of Boring.									

PP is >4.5

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/20/2015  
**Finish:** 8/21/2015  
**WEATHER:** Sunny, mild mid-60s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** R. Hasenyager

**BOREHOLE ID:** G53D  
**Well ID:** G53D  
**Surface Elev:** 352.16 ft. MSL  
**Completion:** 58.00 ft. BGS  
**Station:** 200,075.16N  
 833,980.21E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:		
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) Q <sub>p</sub> (tsf) Failure Type	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
	0/60 0%	BD					2			352	
	0/60 0%	BD					4			350	
	0/60 0%	BD					6			348	
	0/60 0%	BD					8			346	
	0/60 0%	BD					10	Blind drill - see G153 boring log		344	
	0/60 0%	BD					12			342	
	0/60 0%	BD					14			340	
	0/60 0%	BD					16			338	
	0/60 0%	BD					18			336	
	0/60 0%	BD					20			334	
										332	

**NOTE(S):** G55D installed in borehole.

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/20/2015  
**Finish:** 8/21/2015  
**WEATHER:** Sunny, mild mid-60s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4 1/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** R. Hasenyager

**BOREHOLE ID:** G53D  
**Well ID:** G53D  
**Surface Elev:** 352.16 ft. MSL  
**Completion:** 58.00 ft. BGS  
**Station:** 200,075.16N  
 833,980.21E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:		
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Qu (tsf) Qp (tsf) Failure Type	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
	0/60 0%	BD					22			330	
	0/60 0%	BD					24			328	
	0/60 0%	BD					26			326	
	0/60 0%	BD					28			324	
	0/60 0%	BD					30	Blind drill - see G153 boring log [Continued from previous page]		322	
	0/60 0%	BD					32			320	
	0/36 0%	BD					34			318	
	0/36 0%	BD					36			316	
9A	24/24 100%	SS	3-3 5-5 N=8	19	1.25		38	Gray (10YR5/1) with 30% yellowish brown (10YR5/8) mottles, moist, dense, very fine- to medium-grained SAND with some silt and little clay.		314	
10A	21/24 88%	SS	3-6 7-8 N=13	17	1.50		40	Dark yellowish orange (10YR6/6) with 20% gray (10YR5/1) mottles, wet, dense, very fine- to medium-grained SAND with some silt, little clay, and trace small gravel.		312	
							42				

**NOTE(S):** G55D installed in borehole.



# FIELD BORING LOG



CLIENT: Natural Resource Technology, Inc.  
 Site: Joppa Power Station  
 Location: Joppa, Illinois  
 Project: 15E0030  
 DATES: Start: 8/20/2015  
 Finish: 8/21/2015  
 WEATHER: Sunny, mild mid-60s

CONTRACTOR: Bulldog Drilling, Inc.  
 Rig mfg/model: CME-750 ATV Drill  
 Drilling Method: 4/4" HSA, split spoon sampler  
 FIELD STAFF: Driller: J. Dittmaier  
 Helper: M. Hill  
 Eng/Geo: R. Hasenyager

BOREHOLE ID: G53D  
 Well ID: G53D  
 Surface Elev: 352.16 ft. MSL  
 Completion: 58.00 ft. BGS  
 Station: 200,075.16N  
 833,980.21E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:				
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Qu (tsf) Qp (tsf) Failure Type	Quadrangle: Joppa Township: 15S,3E Section 14, Tier 15S; Range 3E	▼ = 43.45 - During Drilling ▽ = ▽ =	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
11A	24/24 100%	ss	1-3 4-5 N=7	20					44	Dark yellowish orange (10YR6/6) with 20% gray (10YR5/1) mottles, wet, dense, very fine- to medium-grained SAND with some silt, little clay, and trace small gravel. <i>[Continued from previous page]</i>		310	
12A	21/24 88%	ss	2-5 12-14 N=17	16					46	Yellowish brown (10YR5/8) with 10% gray (10YR6/10) mottles, wet, dense, very fine- to fine-grained SAND with some silt and trace clay.		308	
13A	23/24 96%	ss	1-1 6-10 N=7	20					48			306	
14A	15/24 63%	ss	wor-wor woh-3	25					50	Gray (10YR6/1) wet, loose, very fine- to medium-grained SAND (micaceous) with little silt and trace clay.		304	
15A	19/24 79%	ss	1-3 8-14 N=11	23					52			302	
16A	20/24 83%	ss	1-4 5-14 N=9	23					54	Gray (10YR6/1) wet, loose, very fine- to medium-grained SAND (micaceous) with little silt and trace clay and small gravel.		300	
17A	19/24 79%	ss	4-10 14-20 N=24	16					56	Gray (10YR6/1), wet, loose, very fine- to very coarse-grained SAND with few small to large gravel and little silt.		298	
17B	19/24 79%	ss	4-10 14-20 N=24	16					56			296	
18A	18/24 75%	ss	1-9 10-11 N=19	21					58	Gray (10YR6/1) wet, loose, very fine- to fine-grained SAND with little silt and trace small gravel.			
18B	18/24 75%	ss	1-9 10-11 N=19	21									

End of boring = 58.0 feet

NOTE(S): G55D installed in borehole.

Surface Elevation: 351.73

Completion Date: 6/18/10

Datum msl

**WELL DIAGRAM**

Flushmount

DEPTH  
IN FEET

**DESCRIPTION OF MATERIAL**

GRAPHIC LOG

DRY UNIT WEIGHT (pcf)  
SPT BLOW COUNTS  
CORE RECOVERY/RQD

SAMPLES

Depth (ft)  
Elev. (ft)

NOTE: STRATIFICATION LINES REPRESENT THE APPROXIMATE BOUNDARIES BETWEEN SOIL TYPES AND THE TRANSITION MAY BE GRADUAL. GRAPHIC LOG FOR ILLUSTRATION PURPOSES ONLY.

Medium stiff, brown and gray CLAY - CH

Soft, brown and gray CLAY - CH

Medium stiff to stiff, brown, silty CLAY, trace sand - (CL)


$k = 1.2 \times 10^{-6} \text{ cm/s}$

Very stiff to stiff, brown, silty CLAY - CL

Stiff, brown, sandy CLAY with silt - CL

Stiff, brown clayey SILT - ML  
Boring terminated at 40 feet.

2-2-3-4	SS1
1-1-2-1	SS2
1-2-4-4	SS3
2-4-4-5	SS4
2-3-6-6	SS5
3-5-5-6	SS6
1-4-4-8	SS7
2-4-5-8	SS8
2-6-6-7	SS9
3-5-7-7	SS10
2-5-7-8	SS11
3-5-6-7	SS12
4-4-6-6	SS13
4-8-8-11	SS14
3-4-7-9	SS15
4-6-8-10	SS16
5-6-6-8	SS17
3-4-6-8	SS18
5-5-7-7	SS19
2-3-6-7	SS20



**GROUNDWATER DATA**

FREE WATER NOT ENCOUNTERED DURING DRILLING

**DRILLING DATA**

AUGER  HOLLOW STEM  
WASHBORING FROM \_\_\_ FEET  
 PH DRILLER  BGF LOGGER  
 ATV DRILL RIG  
HAMMER TYPE Auto

REMARKS:

Drawn by: KA      Checked by: KSP      App'vd. by: KSP  
Date: 7/14/10      Date: 9/20/10      Date: 9/20/10



Ash Pond Evaluation  
EEI Facility  
Joppa, Illinois

LOG OF BORING: G-153

Project No. J017150.02

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/11/2015  
**Finish:** 8/11/2015  
**WEATHER:** Sunny, warm, lo-80s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** S. Keim

**BOREHOLE ID:** G54D  
**Well ID:** G54D  
**Surface Elev:** 353.71 ft. MSL  
**Completion:** 80.14 ft. BGS  
**Station:** 199,066.83N  
 831,610.42E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:		
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) Q <sub>p</sub> (tsf) Failure Type	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
1A	13/24 54%	ss	3-2 3-4 N=5	21			0	FILL - Black (10YR2/1), moist, medium, SILT with few clay, trace very fine- to medium-grained sand, and trace roots.		352	
2A	16/24 67%	ss	2-4 16-8 N=20	13			2	FILL - Yellowish brown (10YR5/4), moist, medium, SILT with few clay, trace very fine- to coarse-grained sand, and trace roots.		350	
3A	18/24 75%	ss	4-4 5-8 N=9	23	2.00		4	FILL - Yellowish brown (10YR5/4) with 25% gray (10YR5/1), moist, medium, SILT with few clay, trace very fine- to coarse-grained sand, trace small to large gravel, and trace roots.		348	
4A	21/24 88%	ss	2-2 4-4 N=6	25	2.00		6	Light gray (10YR7/1) with 20% dark yellowish brown (10YR4/6) mottles, moist, stiff, SILT with few clay, trace very fine- to fine-grained sand.		346	
5A	24/24 100%	ss	1-3 4-6 N=7	23	1.80		8			344	
6A	22/24 92%	ss	1-3 4-5 N=7	22	3.00		10	Brown (10YR5/3) with 20% dark yellowish brown (10YR4/6) mottles, moist, stiff, SILT with few clay, trace very fine-grained sand.		342	
7A	17/24 71%	ss	1-1 2-4 N=3	22	2.00		12			340	
8A	22/24 92%	ss	1-2 4-5 N=6	22	2.00		14	Gray (10YR6/1) with 35% dark yellowish brown (10YR4/6) mottles, moist, stiff, SILT with few clay, trace very fine-grained sand.		338	
9A	17/24 71%	ss	2-3 6-8 N=9	22	1.80		16			336	
10A	24/24 100%	ss	2-3 6-5 N=9	20	2.50		18	Yellowish brown (10YR5/6) with 30% gray (10YR6/1) mottles, moist, stiff, silty CLAY with trace very fine-grained sand.		334	
11A	24/24		1-3	20	1.90		20				

NOTE(S): G54D installed in borehole.

# FIELD BORING LOG



**CLIENT:** Natural Resource Technology, Inc.  
**Site:** Joppa Power Station  
**Location:** Joppa, Illinois  
**Project:** 15E0030  
**DATES: Start:** 8/11/2015  
**Finish:** 8/11/2015  
**WEATHER:** Sunny, warm, lo-80s

**CONTRACTOR:** Bulldog Drilling, Inc.  
**Rig mfg/model:** CME-750 ATV Drill  
**Drilling Method:** 4/4" HSA, split spoon sampler  
**FIELD STAFF: Driller:** J. Dittmaier  
**Helper:** M. Hill  
**Eng/Geo:** S. Keim

**BOREHOLE ID:** G54D  
**Well ID:** G54D  
**Surface Elev:** 353.71 ft. MSL  
**Completion:** 80.14 ft. BGS  
**Station:** 199,066.83N  
 831,610.42E

SAMPLE		TESTING				TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:					
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Qu (tsf) / Qp (tsf) Failure Type	Quadrangle: Joppa Township: 15S,3E Section 14, Tier 15S; Range 3E	▼ = 18.00 - During Drilling ▽ = ▽ =	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
	100%	ss	5-6 6-8 N=8						22	Yellowish brown (10YR5/6) with 30% gray (10YR6/1) mottles, moist, stiff, silty CLAY with trace very fine-grained sand. <i>[Continued from previous page]</i>		332	
12A	24/24 100%	ss	1-4 6-8 N=10	19		3.00			24			330	
13A	24/24 100%	ss	1-3 4-6 N=7	19		1.80			26			328	
14A	24/24 100%	ss	2-4 7-7 N=11	21		2.00			28	Light brownish gray (10YR6/2) with 35% dark yellowish brown (10YR4/6) mottles, moist, very stiff, SILT with few clay, trace very fine- to medium-grained sand.		326	
15A	22/24 92%	ss	1-3 6-8 N=9	20		2.30			30			324	
16A	20/24 83%	ss	1-3 6-6 N=9	18		2.40			32			322	
17A	24/24 100%	ss	1-4 8-8 N=12	20		3.50			34			320	
18A	22/24 92%	ss	1-3 4-5 N=7	22		2.80			36	Grayish brown (10YR5/2) with 10% dark yellowish brown (10YR4/6) mottles, moist, very stiff, SILT with little clay, trace very fine-grained sand.		318	
19A	24/24 100%	ss	3-4 8-8 N=12	19		3.00			38			316	
20A	24/24 100%	ss	1-4 7-10 N=11	19		2.50			40	Light gray (10YR7/1) with 5% yellowish brown (10YR5/6) mottles, moist, very stiff, SILT with few clay, trace very fine-grained sand.		314	
21A	24/24 100%	ss	1-3 10-10 N=13	17		3.80			42			312	

NOTE(S): G54D installed in borehole.

# FIELD BORING LOG



CLIENT: Natural Resource Technology, Inc.  
 Site: Joppa Power Station  
 Location: Joppa, Illinois  
 Project: 15E0030  
 DATES: Start: 8/11/2015  
 Finish: 8/11/2015  
 WEATHER: Sunny, warm, lo-80s

CONTRACTOR: Bulldog Drilling, Inc.  
 Rig mfg/model: CME-750 ATV Drill  
 Drilling Method: 4 1/4" HSA, split spoon sampler  
 FIELD STAFF: Driller: J. Dittmaier  
 Helper: M. Hill  
 Eng/Geo: S. Keim

BOREHOLE ID: G54D  
 Well ID: G54D  
 Surface Elev: 353.71 ft. MSL  
 Completion: 80.14 ft. BGS  
 Station: 199,066.83N  
 831,610.42E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:				
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) / Q <sub>p</sub> (tsf) Failure Type	Quadrangle: Joppa Township: 15S,3E Section 14, Tier 15S; Range 3E	▼ = 18.00 - During Drilling ▽ = ▽ =	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
22A	24/24 100%	ss	5-8 9-10 N=17	16	3.00				44	Light gray (10YR7/1) with 5% yellowish brown (10YR5/6) mottles, moist, very stiff, SILT with few clay, trace very fine-grained sand. <i>[Continued from previous page]</i>		310	
23A	24/24 100%	ss	3-6 8-8 N=14	19	3.00				46			308	
24A	24/24 100%	ss	2-4 5-5 N=9	19	3.20				48	Light brownish gray (10YR6/2) with 10% dark yellowish brown (10YR4/4) mottles, moist, very stiff, silty CLAY, trace very fine- to coarse-grained sand.		306	
25A	24/24 100%	ss	4-7 7-6 N=14	18	2.40				50			304	
26A	17/24 71%	ss	1-4 6-8 N=10	18	2.00				52	Gray (10YR6/1) with 15% dark yellowish brown (10YR4/6) mottles, moist, very stiff, silty CLAY with little very fine- to coarse-grained sand and trace small gravel.		302	
27A	22/24 92%	ss	3-3 7-18 N=10	21	3.30				54	Gray (10YR6/1) with 10% dark yellowish brown (10YR4/6) mottles, moist, very stiff, SILT with few clay, trace very fine-grained sand.		300	
28A	21/24 88%	ss	5-11 18-20 N=29	21	4.00				56			298	
29A	11/11 100%	ss	25-50/5	15	3.80				58	Gray (10YR6/1) with 10% dark yellowish brown (10YR4/6) mottles, moist, hard, SILT with few very fine- to fine-grained sand, trace clay.		296	
30A	20/24 83%	ss	21-19 35-29 N=54	14					60	Gray (10YR6/1) with 10% dark yellowish brown (10YR4/6) mottles, moist, very dense, silty, very fine- to fine-grained sand, trace clay.		294	
31A	17/24 71%	ss	4-6 10-9 N=16	17	1.80				62	Gray (10YR6/1) with 15% dark yellowish brown (10YR4/6) mottles, moist, stiff, SILT with little clay, trace very fine- to fine-grained sand.		292	
32A	22/24		6-8	22	3.30								

NOTE(S): G54D installed in borehole.

# FIELD BORING LOG



CLIENT: Natural Resource Technology, Inc.  
 Site: Joppa Power Station  
 Location: Joppa, Illinois  
 Project: 15E0030  
 DATES: Start: 8/11/2015  
 Finish: 8/11/2015  
 WEATHER: Sunny, warm, lo-80s

CONTRACTOR: Bulldog Drilling, Inc.  
 Rig mfg/model: CME-750 ATV Drill  
 Drilling Method: 4 1/4" HSA, split spoon sampler  
 FIELD STAFF: Driller: J. Dittmaier  
 Helper: M. Hill  
 Eng/Geo: S. Keim

BOREHOLE ID: G54D  
 Well ID: G54D  
 Surface Elev: 353.71 ft. MSL  
 Completion: 80.14 ft. BGS  
 Station: 199,066.83N  
 831,610.42E

SAMPLE		TESTING					TOPOGRAPHIC MAP INFORMATION:		WATER LEVEL INFORMATION:		
Number	Recov / Total (in) % Recovery	Type	Blows / 6 in N - Value RQD	Moisture (%)	Dry Den. (lb/ft <sup>3</sup> )	Q <sub>u</sub> (tsf) Q <sub>p</sub> (tsf) Failure Type	Depth ft. BGS	Lithologic Description	Borehole Detail	Elevation ft. MSL	Remarks
	92%	SS	5-7 N=13				64	Gray (10YR6/1) with 15% dark yellowish brown (10YR4/6) mottles, moist, stiff, SILT with little clay, trace very fine- to fine-grained sand. [Continued from previous page]		290	
33A	24/24 100%	SS	2-4 7-9 N=11	18		2.50	66			288	
34A	24/24 100%	SS	3-5 10-15 N=15	19		2.50	68	Gray (10YR6/1) with 15% dark yellowish brown (10YR4/6) mottles, moist, stiff, SILT with little clay, few very fine- to coarse-grained sand, trace small gravel.		286	
35A	22/24 92%	SS	1-3 3-5 N=6	23		1.50	70	Yellowish brown (10YR5/6) with 10% gray (10YR6/1) mottles, moist, stiff, SILT with little clay, trace very fine-grained sand.		284	
36A	24/24 100%	SS	woh-1 5-6 N=6	23		1.50	72	Gray (10YR6/1) with 10% dark yellowish brown (10YR4/6) mottles, moist, stiff, SILT with little clay, trace very fine- to fine-grained sand.		282	
37A	24/24 100%	SS	woh-1 2-4 N=3	23		1.50	74			280	
38A	16/24 67%	SS	30-40 27-34 N=67	11			76			278	
39A	12/15 80%	SS	10-47 50/3"	14			78	Yellowish brown (10YR5/6), moist, very dense, silty, fine- to coarse-grained SAND and small to large GRAVEL.		276	
40A	5/5 100%	SS	50/5"	12			80			274	
	0/21 0%	BD									

End of boring = 80.14 feet


NOTE(S): G54D installed in borehole.



Site #: \_\_\_\_\_ County: Massac County Well #: G01D  
Site Name: Joppa Power Station Borehole #: G01D  
State \_\_\_\_\_  
Plane Coordinate: X 831,716.1 Y 202,039.3 (or) Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_  
Surveyed By: Gary C. Rogers IL Registration #: 035-002957  
Drilling Contractor: Bulldog Drilling, Inc. Driller: J. Dittmaier  
Consulting Firm: Hanson Professional Services Inc. Geologist: Rhonald W. Hasenyager, LPG #196-000246  
Drilling Method: Hollow Stem Auger Drilling Fluid (Type): Water  
Logged By: Suzanna L. Keim Date Started: 8/14/2015 Date Finished: 8/14/2015  
Report Form Completed By: Suzanna L. Keim Date: 8/18/2015

ANNULAR SPACE DETAILS

Table with 3 columns: Description, Elevations (MSL)\*, Depths (BGS) (0.01 ft.). Includes data for Top of Protective Casing, Top of Riser Pipe, Ground Surface, Top of Annular Sealant, Static Water Level, Top of Seal, Top of Sand Pack, Top of Screen, Bottom of Screen, Bottom of Well, and Bottom of Borehole.



\* Referenced to a National Geodetic Datum

WELL CONSTRUCTION MATERIALS  
(Choose one type of material for each area)

Table with 2 columns: Material Type and Material Options (SS304, SS316, PTFE, PVC, OTHER: Steel, PVC).

CASING MEASUREMENTS

Table with 3 columns: Measurement, Unit, Value. Includes Diameter of Borehole (8.0 inches), ID of Riser Pipe (2.0 inches), Protective Casing Length (5.0 feet), Riser Pipe Length (56.88 feet), Bottom of Screen to End Cap (0.53 feet), Screen Length (9.66 feet), Total Length of Casing (67.07 feet), and Screen Slot Size (0.010 inches).



Site #: \_\_\_\_\_ County: Massac County Well #: G02D  
Site Name: Joppa Power Station Borehole #: G02D  
State \_\_\_\_\_  
Plane Coordinate: X 832,843.0 Y 202,137.1 (or) Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_  
Surveyed By: Gary C. Rogers IL Registration #: 035-002957  
Drilling Contractor: Bulldog Drilling, Inc. Driller: J. Dittmaier  
Consulting Firm: Hanson Professional Services Inc. Geologist: Rhonald W. Hasenyager, LPG #196-000246  
Drilling Method: Hollow Stem Auger Drilling Fluid (Type): Water  
Logged By: Suzanna L. Keim Date Started: 8/12/2015 Date Finished: 8/13/2015  
Report Form Completed By: Suzanna L. Keim Date: 8/18/2015

ANNULAR SPACE DETAILS

Table with 4 columns: Description, Elevations (MSL)\*, Depths (BGS), and (0.01 ft.). Includes a central diagram of a well casing and screen assembly. Key data points include: Top of Protective Casing (364.09 MSL, -3.27 BGS), Top of Riser Pipe (363.65 MSL, -2.83 BGS), Ground Surface (360.82 MSL, 0.00 BGS), Top of Annular Sealant (358.82 MSL, 2.00 BGS), Static Water Level (312.82 MSL, 48.00 BGS), Top of Seal (301.82 MSL, 59.00 BGS), Top of Sand Pack (300.42 MSL, 60.40 BGS), Top of Screen (298.61 MSL, 62.21 BGS), Bottom of Screen (288.98 MSL, 71.84 BGS), Bottom of Well (288.46 MSL, 72.36 BGS), Bottom of Borehole (288.46 MSL, 72.36 BGS).

\* Referenced to a National Geodetic Datum

WELL CONSTRUCTION MATERIALS  
(Choose one type of material for each area)

Table for well construction materials with columns for material type (SS304, SS316, PTFE, PVC, OTHER) and selection status. Rows include Protective Casing, Riser Pipe Above W.T., Riser Pipe Below W.T., and Screen.

CASING MEASUREMENTS

Table for casing measurements with columns for measurement type and value. Measurements include Diameter of Borehole (8.0 inches), ID of Riser Pipe (2.0 inches), Protective Casing Length (5.0 feet), Riser Pipe Length (65.04 feet), Bottom of Screen to End Cap (0.52 feet), Screen Length (9.63 feet), Total Length of Casing (75.19 feet), and Screen Slot Size (0.010 inches).





Site #: \_\_\_\_\_ County: Massac County Well #: G51D

Site Name: Joppa Power Station Borehole #: G51D

State \_\_\_\_\_  
Plane Coordinate: X 832,151.5 Y 200,430.1 (or) Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

Surveyed By: Gary C. Rogers IL Registration #: 035-002957

Drilling Contractor: Bulldog Drilling, Inc. Driller: J. Dittmaier

Consulting Firm: Hanson Professional Services Inc. Geologist: Rhonald W. Hasenyager, LPG #196-000246


Drilling Method: Hollow Stem Auger Drilling Fluid (Type): Water

Logged By: Rhonald W. Hasenyager Date Started: 8/17/2015 Date Finished: 8/18/2015

Report Form Completed By: Suzanna L. Keim Date: 8/28/2015

ANNULAR SPACE DETAILS

	Elevations (MSL)*	Depths (BGS)	(0.01 ft.)
	<u>364.22</u>	<u>-3.12</u>	Top of Protective Casing
	<u>363.85</u>	<u>-2.75</u>	Top of Riser Pipe
Type of Surface Seal: <u>Concrete</u>	<u>361.10</u>	<u>0.00</u>	Ground Surface
Type of Annular Sealant: <u>High-solids bentonite</u>	<u>359.10</u>	<u>2.00</u>	Top of Annular Sealant
Installation Method: <u>Tremie</u>			
Setting Time: <u>&gt;48 hours</u>			
Type of Bentonite Seal -- Granular <input type="radio"/> Pellet <input checked="" type="radio"/> Slurry (choose one)	<u>311.65</u>	<u>49.45</u>	Static Water Level (After Completion) 10/5/2015
Installation Method: <u>Gravity</u>	<u>315.42</u>	<u>45.68</u>	Top of Seal
Setting Time: <u>70 minutes</u>	<u>313.59</u>	<u>47.51</u>	Top of Sand Pack
Type of Sand Pack: <u>Quartz Sand</u>			
Grain Size: <u>10-20</u> (sieve size)	<u>311.49</u>	<u>49.61</u>	Top of Screen
Installation Method: <u>Gravity</u>	<u>301.83</u>	<u>59.27</u>	Bottom of Screen
Type of Backfill Material: <u>n/a</u> (if applicable)	<u>301.20</u>	<u>59.90</u>	Bottom of Well
Installation Method: _____	<u>301.20</u>	<u>59.90</u>	Bottom of Borehole



\* Referenced to a National Geodetic Datum

WELL CONSTRUCTION MATERIALS  
(Choose one type of material for each area)

Protective Casing	SS304	SS316	PTFE	PVC	OTHER: <input checked="" type="radio"/> Steel
Riser Pipe Above W.T.	SS304	SS316	PTFE	<input checked="" type="radio"/> PVC	OTHER:
Riser Pipe Below W.T.	SS304	SS316	PTFE	<input checked="" type="radio"/> PVC	OTHER:
Screen	SS304	SS316	PTFE	<input checked="" type="radio"/> PVC	OTHER:

CASING MEASUREMENTS


Diameter of Borehole	(inches)	8.0
ID of Riser Pipe	(inches)	2.0
Protective Casing Length	(feet)	5.0
Riser Pipe Length	(feet)	52.36
Bottom of Screen to End Cap	(feet)	0.63
Screen Length (1st slot to last slot)	(feet)	9.66
Total Length of Casing	(feet)	62.65
Screen Slot Size **	(inches)	0.010



Site #: \_\_\_\_\_ County: Massac County Well #: G52D  
Site Name: Joppa Power Station Borehole #: G52D  
State \_\_\_\_\_  
Plane Coordinate: X 832,927.9 Y 198,098.9 (or) Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_  
Surveyed By: Gary C. Rogers IL Registration #: 035-002957  
Drilling Contractor: Bulldog Drilling, Inc. Driller: J. Dittmaier  
Consulting Firm: Hanson Professional Services Inc. Geologist: Rhonald W. Hasenyager, LPG #196-000246  
Drilling Method: Hollow Stem Auger Drilling Fluid (Type): Water  
Logged By: Rhonald W. Hasenyager Date Started: 8/18/2015 Date Finished: 8/19/2015  
Report Form Completed By: Suzanna L. Keim Date: 8/28/2015

ANNULAR SPACE DETAILS

	Elevations (MSL)*	Depths (BGS)	(0.01 ft.)
	<u>348.67</u>	<u>-2.79</u>	Top of Protective Casing
	<u>348.41</u>	<u>-2.53</u>	Top of Riser Pipe
Type of Surface Seal: <u>Concrete</u>	<u>345.88</u>	<u>0.00</u>	Ground Surface
Type of Annular Sealant: <u>High-solids bentonite</u>	<u>343.88</u>	<u>2.00</u>	Top of Annular Sealant
Installation Method: <u>Tremie</u>			
Setting Time: <u>&gt;48 hours</u>			
Type of Bentonite Seal -- Granular <input type="radio"/> Pellet <input checked="" type="radio"/> Slurry (choose one)	<u>313.46</u>	<u>32.42</u>	Static Water Level (After Completion) 10/5/2015
Installation Method: <u>Gravity</u>	<u>278.91</u>	<u>66.97</u>	Top of Seal
Setting Time: <u>32 minutes</u>	<u>277.22</u>	<u>68.66</u>	Top of Sand Pack
Type of Sand Pack: <u>Quartz Sand</u>	<u>276.03</u>	<u>69.85</u>	Top of Screen
Grain Size: <u>10-20</u> (sieve size)	<u>266.33</u>	<u>79.55</u>	Bottom of Screen
Installation Method: <u>Gravity</u>	<u>265.87</u>	<u>80.01</u>	Bottom of Well
Type of Backfill Material: <u>n/a</u> (if applicable)			
Installation Method: _____	<u>265.87</u>	<u>80.01</u>	Bottom of Borehole



\* Referenced to a National Geodetic Datum

WELL CONSTRUCTION MATERIALS  
(Choose one type of material for each area)

Protective Casing	SS304	SS316	PTFE	PVC	OTHER: <input checked="" type="radio"/> Steel
Riser Pipe Above W.T.	SS304	SS316	PTFE	<input checked="" type="radio"/> PVC	OTHER:
Riser Pipe Below W.T.	SS304	SS316	PTFE	<input checked="" type="radio"/> PVC	OTHER:
Screen	SS304	SS316	PTFE	<input checked="" type="radio"/> PVC	OTHER:

CASING MEASUREMENTS

Diameter of Borehole	(inches)	8.0
ID of Riser Pipe	(inches)	2.0
Protective Casing Length	(feet)	5.0
Riser Pipe Length	(feet)	72.38
Bottom of Screen to End Cap	(feet)	0.46
Screen Length (1st slot to last slot)	(feet)	9.70
Total Length of Casing	(feet)	82.54
Screen Slot Size **	(inches)	0.010



Site #: \_\_\_\_\_ County: Massac County Well #: G53D  
Site Name: Joppa Power Station Borehole #: G53D  
State \_\_\_\_\_  
Plane Coordinate: X 833,980.2 Y 200,075.2 (or) Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_  
Surveyed By: Gary C. Rogers IL Registration #: 035-002957  
Drilling Contractor: Bulldog Drilling, Inc. Driller: J. Dittmaier  
Consulting Firm: Hanson Professional Services Inc. Geologist: Rhonald W. Hasenyager, LPG #196-000246  
Drilling Method: Hollow Stem Auger Drilling Fluid (Type): Water  
Logged By: Rhonald W. Hasenyager Date Started: 8/20/2015 Date Finished: 8/21/2015  
Report Form Completed By: Suzanna L. Keim Date: 8/28/2015

ANNULAR SPACE DETAILS

Table with 4 columns: Description, Elevations (MSL)\*, Depths (BGS), and (0.01 ft.). Rows include: Top of Protective Casing (355.82, -3.66), Top of Riser Pipe (355.47, -3.31), Ground Surface (352.16, 0.00), Top of Annular Sealant (350.16, 2.00), Static Water Level (309.91, 42.25), Top of Seal (309.77, 42.39), Top of Sand Pack (307.85, 44.31), Top of Screen (304.87, 47.29), Bottom of Screen (295.27, 56.89), Bottom of Well (294.83, 57.33), Bottom of Borehole (294.16, 58.00). Includes a well diagram and material selection options like Concrete, High-solids bentonite, Tremie, Pellet, Gravity, Quartz Sand, Formation, and Drilling.

\* Referenced to a National Geodetic Datum

CASING MEASUREMENTS

Table with 3 columns: Measurement, Unit, and Value. Rows include: Diameter of Borehole (8.0 inches), ID of Riser Pipe (2.0 inches), Protective Casing Length (5.0 feet), Riser Pipe Length (50.60 feet), Bottom of Screen to End Cap (0.44 feet), Screen Length (9.60 feet), Total Length of Casing (60.64 feet), Screen Slot Size (0.010 inches).

WELL CONSTRUCTION MATERIALS (Choose one type of material for each area)

Table for material selection with columns for material type (SS304, SS316, PTFE, PVC, OTHER) and selection options for Protective Casing, Riser Pipe Above W.T., Riser Pipe Below W.T., and Screen.



Site #: \_\_\_\_\_ County: Massac County Well #: G54D
Site Name: Joppa Power Station Borehole #: G54D
State \_\_\_\_\_
Plane Coordinate: X 831,610.4 Y 199,066.8 (or) Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_
Surveyed By: Gary C. Rogers IL Registration #: 035-002957
Drilling Contractor: Bulldog Drilling, Inc. Driller: J. Dittmaier
Consulting Firm: Hanson Professional Services Inc. Geologist: Rhonald W. Hasenyager, LPG #196-000246
Drilling Method: Hollow Stem Auger Drilling Fluid (Type): Water
Logged By: Suzanna L. Keim Date Started: 8/11/2015 Date Finished: 8/11/2015
Report Form Completed By: Suzanna L. Keim Date: 8/18/2015

ANNULAR SPACE DETAILS

Table with 4 columns: Description, Elevations (MSL)\*, Depths (BGS), and (0.01 ft.). Includes a central diagram of a well casing and screen assembly. Rows include: Top of Protective Casing (357.39, -3.68), Top of Riser Pipe (357.03, -3.32), Ground Surface (353.71, 0.00), Top of Annular Sealant (351.71, 2.00), Static Water Level (304.50, 49.21), Top of Seal (286.76, 66.95), Top of Sand Pack (285.71, 68.00), Top of Screen (283.75, 69.96), Bottom of Screen (274.05, 79.66), Bottom of Well (273.57, 80.14), Bottom of Borehole (273.57, 80.14).

\* Referenced to a National Geodetic Datum

WELL CONSTRUCTION MATERIALS
(Choose one type of material for each area)


Table with 2 columns: Material Type and Material Options. Rows include: Protective Casing (SS304, SS316, PTFE, PVC, OTHER: Steel), Riser Pipe Above W.T. (SS304, SS316, PTFE, PVC, OTHER:), Riser Pipe Below W.T. (SS304, SS316, PTFE, PVC, OTHER:), Screen (SS304, SS316, PTFE, PVC, OTHER:).

CASING MEASUREMENTS

Table with 3 columns: Measurement, Unit, and Value. Rows include: Diameter of Borehole (8.0 inches), ID of Riser Pipe (2.0 inches), Protective Casing Length (5.0 feet), Riser Pipe Length (73.28 feet), Bottom of Screen to End Cap (0.48 feet), Screen Length (9.70 feet), Total Length of Casing (83.46 feet), Screen Slot Size (0.010 inches).

**ATTACHMENT 4 – MAPS OF THE DIRECTION OF GROUNDWATER FLOW**

Y:\Mapping\Projects\22285\MXD\GW\_Contours\Round\_01\RT1\_JoppaAP\_GW\_Contours.mxd Author: sstolz Date/Time: 2/15/2017, 4:16:52 PM



- CCR RULE MONITORING WELL LOCATION
- GROUNDWATER ELEVATION CONTOUR (1-FT CONTOUR INTERVAL, NAVD88)
- - - INFERRED GROUNDWATER ELEVATION CONTOUR
- ➔ GROUNDWATER FLOW DIRECTION
- ▭ CCR MONITORED UNIT

Service Layer Credits: Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

NOTE: G52D GROUNDWATER ELEVATION IS NOT INCLUDED IN POTENTIOMETRIC SURFACE CONTOURS

**JOPPA EAST ASH POND (UNIT ID: 401)  
UPPERMOST AQUIFER UNIT  
GROUNDWATER ELEVATION CONTOUR MAP  
ROUND 1: DECEMBER 2, 2015**

DYNEGY CCR RULE GROUNDWATER MONITORING  
JOPPA POWER STATION  
JOPPA, ILLINOIS


DRAWN BY/DATE:  
SDS 1/23/17  
REVIEWED BY/DATE:  
ANS 1/25/17  
APPROVED BY/DATE:  
JJW 2/7/17

PROJECT NO: 2285/1.6

FIGURE NO: 1



Y:\Mapping\Projects\222285\MIX DIGW\_Contours\Round\_02\R2\_JoppaEAP\_GW\_Contours.mxd Author: sstolz Date/Time: 3/2/2017, 4:17:21 PM



**JOPPA EAST ASH POND (UNIT ID: 401)  
UPPERMOST AQUIFER UNIT  
GROUNDWATER ELEVATION CONTOUR MAP  
ROUND 2: MARCH 15, 2016**


DRAWN BY/DATE:  
SDS 1/23/17  
REVIEWED BY/DATE:  
ANS 1/25/17  
APPROVED BY/DATE:  
JJW 2/8/17

DYNEGY CCR RULE GROUNDWATER MONITORING  
JOPPA POWER STATION  
JOPPA, ILLINOIS

PROJECT NO: 2285  
FIGURE NO: 1



Y:\Mapping\Projects\22\2285\MXD\GW\_Contours\Round\_03\R3\_JoppaAP\_GW\_Contours.mxd Author: stolzsd, Date/Time: 5/2/2017, 6:25:27 PM



- CCR RULE MONITORING WELL LOCATION
- GROUNDWATER ELEVATION CONTOUR (1-FT CONTOUR INTERVAL, NAVD88)
- - - INFERRED GROUNDWATER ELEVATION CONTOUR
- ➔ GROUNDWATER FLOW DIRECTION
- ▭ CCR MONITORED UNIT

Service Layer Credits: Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

NOTE: G52D GROUNDWATER ELEVATION IS NOT INCLUDED IN POTENTIOMETRIC SURFACE CONTOURS

**JOPPA EAST ASH POND (UNIT ID: 401)  
UPPERMOST AQUIFER UNIT  
GROUNDWATER ELEVATION CONTOUR MAP  
ROUND 3: JUNE 14, 2016**

DRAWN BY/DATE:  
SDS 1/23/17  
REVIEWED BY/DATE:  
ANS 1/25/17  
APPROVED BY/DATE:  
JJW 2/8/17


DYNEGY CCR RULE GROUNDWATER MONITORING  
JOPPA POWER STATION  
JOPPA, ILLINOIS

PROJECT NO: 2285  
FIGURE NO: 1





Y:\Mapping\Projects\22\2285\MIX\DIGW\_Contours\Round\_04\R4\_JoppaAP\_GW\_Contours.mxd Author: sstolz Date/Time: 3/3/2017, 2:28:06 PM



DRAWN BY/DATE:  
 SDS 1/23/17  
 REVIEWED BY/DATE:  
 ANS 1/25/17  
 APPROVED BY/DATE:  
 JJW 2/8/17


**JOPPA EAST ASH POND (UNIT ID: 401)  
 UPPERMOST AQUIFER UNIT  
 GROUNDWATER ELEVATION CONTOUR MAP  
 ROUND 4: SEPTEMBER 13, 2016**

DYNEGY CCR RULE GROUNDWATER MONITORING  
 JOPPA POWER STATION  
 JOPPA, ILLINOIS

PROJECT NO: 2285  
 FIGURE NO: 1



Y:\Mapping\Projects\22285\MXD\GW\_Contours\Round\_05\R5\_JoppaEAP\_GW\_Contours.mxd Author: stolzsd; Date/Time: 9/1/2017, 5:09:29 PM



- CCR RULE MONITORING WELL LOCATION
- GROUNDWATER ELEVATION CONTOUR (1-FOOT INTERVAL, NAVD88)
- INFERRED GROUNDWATER ELEVATION CONTOUR
- GROUNDWATER FLOW DIRECTION
- CCR MONITORED UNIT

Service Layer Credits: Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

NOTE: G52D GROUNDWATER ELEVATION IS NOT INCLUDED IN POTENTIOMETRIC SURFACE CONTOURS

**JOPPA EAST ASH POND (UNIT ID: 401)  
UPPERMOST AQUIFER UNIT  
GROUNDWATER ELEVATION CONTOUR MAP  
ROUND 5: DECEMBER 14, 2016**


DYNEGY CCR RULE GROUNDWATER MONITORING  
JOPPA POWER STATION  
JOPPA, ILLINOIS

DRAWN BY/DATE:  
SDS 3/6/17  
REVIEWED BY/DATE:  
ANS 3/6/17  
APPROVED BY/DATE:  
JJW 8/30/17

PROJECT NO: 2285  
FIGURE NO: 1



Y:\Mapping\Projects\22285M\XDGW\_Contours\Round\_06\R6\_JoppaEAP\_GW\_Contours.mxd Author: stolzsd; Date/Time: 9/1/2017, 5:11:01 PM



- CCR RULE MONITORING WELL LOCATION
- GROUNDWATER ELEVATION CONTOUR ( 1-FOOT INTERVAL)
- INFERRED GROUNDWATER ELEVATION CONTOUR
- GROUNDWATER FLOW DIRECTION
- CCR MONITORED UNIT

Service Layer Credits: Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

NOTE: G52D GROUNDWATER ELEVATION IS NOT INCLUDED IN POTENTIOMETRIC SURFACE CONTOURS

**JOPPA EAST ASH POND (UNIT ID: 401)  
UPPERMOST AQUIFER UNIT  
GROUNDWATER ELEVATION CONTOUR MAP  
ROUND 6: MARCH 7, 2017**

DRAWN BY/DATE:  
SDS 7/12/17  
REVIEWED BY/DATE:  
ANS 7/12/17  
APPROVED BY/DATE:  
JJW 8/30/17


DYNEGY CCR RULE GROUNDWATER MONITORING  
JOPPA POWER STATION  
JOPPA, ILLINOIS

PROJECT NO: 2285

FIGURE NO: 1



Y:\Mapping\Projects\22285\MXD\GW\_Contours\Round\_07\R7\_JoppaEAP\_GW\_Contours.mxd Author: stolbszd Date/Time: 9/1/2017, 5:11:57 PM



- CCR RULE MONITORING WELL LOCATION
- GROUNDWATER ELEVATION CONTOUR ( 1-FOOT INTERVAL)
- INFERRED GROUNDWATER ELEVATION CONTOUR
- GROUNDWATER FLOW DIRECTION
- CCR MONITORED UNIT

Service Layer Credits: Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

NOTE: G52D GROUNDWATER ELEVATION IS NOT INCLUDED IN POTENTIOMETRIC SURFACE CONTOURS

**JOPPA EAST ASH POND (UNIT ID: 401)  
UPPERMOST AQUIFER UNIT  
GROUNDWATER ELEVATION CONTOUR MAP  
ROUND 7: JUNE 14, 2017**

DRAWN BY/DATE:  
SDS 7/10/17  
REVIEWED BY/DATE:  
ANS 7/10/17  
APPROVED BY/DATE:  
JJW 8/30/17


DYNEGY CCR RULE GROUNDWATER MONITORING  
JOPPA POWER STATION  
JOPPA, ILLINOIS

PROJECT NO: 2285

FIGURE NO: 1



Y:\Mapping\Projects\22285\MXD\GW\_Contours\Round\_08\JoppaEAP\_GW\_Contours.mxd Author: stolzsd; Date/Time: 9/1/2017, 5:14:13 PM



- CCR RULE MONITORING WELL LOCATION
- GROUNDWATER ELEVATION CONTOUR ( 1-FOOT INTERVAL)
- - - INFERRED GROUNDWATER ELEVATION CONTOUR
- ➔ GROUNDWATER FLOW DIRECTION
- ▭ CCR MONITORED UNIT

Service Layer Credits: Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

NOTE: G52D GROUNDWATER ELEVATION IS NOT INCLUDED IN POTENTIOMETRIC SURFACE CONTOURS

**JOPPA EAST ASH POND (UNIT ID: 401)  
UPPERMOST AQUIFER UNIT  
GROUNDWATER ELEVATION CONTOUR MAP  
ROUND 8: JULY 19, 2017**

DYNEGY CCR RULE GROUNDWATER MONITORING  
JOPPA POWER STATION  
JOPPA, ILLINOIS


DRAWN BY/DATE:  
SDS 8/10/17  
REVIEWED BY/DATE:  
ANS 8/10/17  
APPROVED BY/DATE:  
JJW 8/30/17

PROJECT NO: 2285

FIGURE NO: 1




Service Layer Credits: Source: Esri, Maxar, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community



- CCR RULE MONITORING WELL LOCATION
- GROUNDWATER ELEVATION CONTOUR ( 1-FOOT CONTOUR INTERVAL, NAVD88)
- INFERRED GROUNDWATER ELEVATION CONTOUR
- GROUNDWATER FLOW DIRECTION
- CCR MONITORED UNIT


**JOPPA EAST ASH POND (UNIT ID: 401)**  
GROUNDWATER ELEVATION CONTOUR MAP  
NOVEMBER 30, 2017

CCR RULE GROUNDWATER MONITORING  
JOPPA POWER STATION  
JOPPA, ILLINOIS






Service Layer Credits: Source: Esri, Maxar, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community



- CCR RULE MONITORING WELL LOCATION
- GROUNDWATER ELEVATION CONTOUR (1-FOOT CONTOUR INTERVAL, NAVD 88)
- INFERRED GROUNDWATER ELEVATION CONTOUR
- GROUNDWATER FLOW DIRECTION
- CCR MONITORED UNIT

JOPPA EAST ASH POND (UNIT ID: 401)  
GROUNDWATER ELEVATION CONTOUR MAP  
SEPTEMBER 5, 2018

CCR RULE GROUNDWATER MONITORING  
JOPPA POWER STATION  
JOPPA, ILLINOIS









NOTE:  
\* = G52D GROUNDWATER ELEVATION  
NOT USED FOR CONTOURING






Service Layer Credits: Source: Esri, Maxar, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community




-  CCR RULE MONITORING WELL LOCATION
-  GROUNDWATER ELEVATION CONTOUR (1-FOOT CONTOUR INTERVAL, NAVD 88)
-  INFERRED GROUNDWATER ELEVATION CONTOUR
-  GROUNDWATER FLOW DIRECTION
-  CCR MONITORED UNIT






**JOPPA EAST ASH POND (UNIT ID: 401)  
GROUNDWATER ELEVATION CONTOUR MAP  
MARCH 27, 2019**

CCR RULE GROUNDWATER MONITORING  
JOPPA POWER STATION  
JOPPA, ILLINOIS



Service Layer Credits: Source: Esri, Maxar, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community



-  CCR RULE MONITORING WELL LOCATION
-  GROUNDWATER ELEVATION CONTOUR (1-FOOT CONTOUR INTERVAL, NAVD 88)
-  INFERRED GROUNDWATER ELEVATION CONTOUR
-  GROUNDWATER FLOW DIRECTION
-  CCR MONITORED UNIT

JOPPA EAST ASH POND (UNIT ID: 401)  
GROUNDWATER ELEVATION CONTOUR MAP  
SEPTEMBER 9, 2019

CCR RULE GROUNDWATER MONITORING  
JOPPA POWER STATION  
JOPPA, ILLINOIS



NOTE:  
\* = G52D GROUNDWATER ELEVATION  
NOT USED FOR CONTOURING





NOTE:  
 \* = G52D GROUNDWATER ELEVATION NOT USED FOR CONTOURING

- CCR MONITORING WELL
- GROUNDWATER ELEVATION CONTOUR (1-FOOT CONTOUR INTERVAL, NAVD 88)
- - INFERRED GROUNDWATER ELEVATION CONTOUR
- ➔ GROUNDWATER FLOW DIRECTION
- CCR UNIT BOUNDARY, SUBJECT SITE

**GROUNDWATER ELEVATION CONTOUR MAP**  
**MARCH 30, 2020**



**JOPPA EAST ASH POND (UNIT ID: 401)**  
 VISTRA ENERGY  
 JOPPA POWER STATION  
 JOPPA, ILLINOIS

RAMBOLL US CORPORATION  
 A RAMBOLL COMPANY



**ATTACHMENT 5 – TABLES SUMMARIZING CONSTITUENT CONCENTRATIONS  
AT EACH MONITORING WELL**

**Analytical Results - Appendix III  
Joppa East Ash Pond**

Sample Location	Date Sampled	Boron, total (mg/L)	Calcium, total (mg/L)	Chloride, total (mg/L)	Fluoride, total (mg/L)	pH (s.u.)	Sulfate, total (mg/L)	Total Dissolved Solids (mg/L)
<b>Background Wells</b>								
G01D	12/3/2015	<0.025	37.9	13	0.26	6.7	20	216
G01D	3/15/2016	0.0360	45.5	20	0.29	6.7	126	496
G01D	6/15/2016	0.0296	43.9	21	0.25	6.9	157	518
G01D	9/14/2016	0.0416	40.8	21	0.26	6.8	129	498
G01D	12/14/2016	<0.025	35.9	14	0.24	6.8	53	294
G01D	3/7/2017	<0.025	34.9	16	0.22	6.2	72	384
G01D	6/15/2017	<0.025	32.1	15	0.23	6.7	56	372
G01D	7/20/2017	<0.025	29.5	12	0.24	6.8	31	368
G01D	11/30/2017	<0.025	37.2	18	0.22	6.8	117	450
G01D	6/19/2018	<0.025	29.5	13	0.24	6.8	70	394
G01D	9/5/2018	<0.025	30.5	14	0.20	7.0	94	414
G01D	3/27/2019	<0.025	25.1	8	0.23	6.7	30	310
G01D	9/9/2019	<0.025	25.6	8	0.23	6.4	37	336
G01D	3/30/2020	<0.025	22.7	8	0.21	6.8	35	296
G02D	12/3/2015	0.0536	39.9	24	0.24	6.7	16	244
G02D	3/15/2016	0.0494	39.8	24	0.22	6.6	17	256
G02D	6/15/2016	0.0508	38.6	21	0.21	6.8	15	248
G02D	9/14/2016	0.0534	34.7	24	0.20	6.6	22	276
G02D	12/14/2016	0.0552	40.4	24	0.19	6.3	22	266
G02D	3/8/2017	0.0546	40.0	24	0.19	6.9	18	270
G02D	6/14/2017	0.0467	33.2	25	0.19	6.3	20	198
G02D	7/20/2017	0.0440	37.5	22	0.22	6.7	12	264
G02D	11/30/2017	0.0496	40.1	23	0.21	6.9	17	246
G02D	6/19/2018	0.0404	33.9	23	0.21	6.7	17	232
G02D	9/5/2018	0.0468	36.3	23	0.18	6.6	19	252
G02D	3/27/2019	0.0473	38.7	20	0.20	6.6	20	262
G02D	9/9/2019	0.0429	40.3	18	0.21	6.5	20	264
G02D	3/30/2020	0.0449	33.5	20	0.18	6.6	22	222
<b>Downgradient Wells</b>								
G51D	12/3/2015	0.117	39.2	9	0.13	6.2	117	304
G51D	3/15/2016	0.184	39.7	9	0.10	5.9	145	342
G51D	6/15/2016	0.213	42.3	7	<0.1	5.8	139	330
G51D	9/14/2016	0.263	29.6	9	<0.1	5.6	136	360
G51D	12/14/2016	0.171	30.0	11	<0.1	5.9	101	270
G51D	3/8/2017	0.309	32.6	8	<0.1	6.2	146	340
G51D	6/15/2017	0.580	34.0	9	<0.1	5.6	149	340
G51D	7/20/2017	0.332	31.8	8	<0.1	5.9	140	344
G51D	11/30/2017	0.302	34.4	8	<0.1	5.6	138	356
G51D	6/19/2018	0.337	31.1	7	<0.1	5.7	124	324
G51D	9/5/2018	0.263	29.1	7	<0.1	6.0	134	342
G51D	3/27/2019	0.778	34.7	6	<0.1	5.7	125	350
G51D	9/9/2019	0.501	31.3	6	<0.1	5.3	109	320
G51D	3/30/2020	0.697	31.2	6	<0.1	5.6	130	304
G52D	12/3/2015	<0.025	46.6	22	0.25	6.5	65	332
G52D	3/15/2016	<0.025	49.1	22	0.26	6.3	99	310
G52D	6/15/2016	<0.025	69.2	21	0.25	6.6	88	360
G52D	9/14/2016	<0.025	47.6	20	0.26	6.4	84	376
G52D	12/14/2016	<0.025	53.4	20	0.25	6.7	82	356
G52D	3/7/2017	<0.025	55.0	18	0.24	5.9	115	410
G52D	6/14/2017	<0.025	51.0	17	0.24	6.2	112	372
G52D	7/19/2017	<0.025	50.7	15	0.27	6.4	108	412
G52D	11/30/2017	<0.025	54.7	15	0.26	6.0	97	392

**Analytical Results - Appendix III  
Joppa East Ash Pond**

<b>Sample Location</b>	<b>Date Sampled</b>	<b>Boron, total (mg/L)</b>	<b>Calcium, total (mg/L)</b>	<b>Chloride, total (mg/L)</b>	<b>Fluoride, total (mg/L)</b>	<b>pH (s.u.)</b>	<b>Sulfate, total (mg/L)</b>	<b>Total Dissolved Solids (mg/L)</b>
G52D	6/19/2018	<0.025	50.1	15	0.26	6.4	97	388
G52D	9/5/2018	<0.025	49.8	14	0.24	6.3	101	384
G52D	3/27/2019	<0.025	59.8	13	0.28	6.4	81	376
G52D	9/9/2019	<0.025	52.2	14	0.27	6.0	78	370
G52D	3/30/2020	<0.025	48.8	14	0.27	6.4	84	362
G53D	12/3/2015	0.332	62.6	22	0.79	6.8	103	368
G53D	3/15/2016	0.334	50.5	20	0.72	6.7	107	406
G53D	6/15/2016	0.342	47.2	17	0.68	6.6	107	392
G53D	9/14/2016	0.368	44.4	20	0.70	6.5	104	424
G53D	12/14/2016	0.364	44.5	20	0.69	6.8	106	418
G53D	3/8/2017	0.138	23.6	6	0.49	7.2	35	216
G53D	6/15/2017	0.309	38.9	18	0.59	6.6	79	348
G53D	7/20/2017	0.366	40.8	18	0.69	6.8	94	396
G53D	11/30/2017	0.427	44.6	20	0.74	6.6	98	348
G53D	6/19/2018	0.361	37.8	18	0.66	6.6	84	360
G53D	9/5/2018	0.392	40.3	20	0.61	6.8	81	390
G53D	3/27/2019	0.269	30.5	12	0.59	6.6	54	272
G53D	9/9/2019	0.385	42.2	18	0.67	6.2	80	364
G53D	3/30/2020	0.334	34.8	17	0.63	6.7	66	296
G54D	12/3/2015	0.663	103	33	0.38	7.0	191	556
G54D	3/15/2016	0.513	75.2	32	0.38	6.8	176	554
G54D	6/15/2016	0.508	72.8	28	0.34	6.6	160	476
G54D	9/14/2016	0.557	70.4	28	0.34	6.6	149	502
G54D	12/14/2016	0.564	74.3	26	0.32	6.7	144	456
G54D	3/8/2017	0.499	74.1	26	0.30	7.1	131	482
G54D	6/15/2017	0.685	80.5	24	0.32	6.8	170	506
G54D	7/20/2017	0.580	75.7	24	0.32	6.8	151	512
G54D	11/30/2017	0.646	76.2	26	0.33	6.7	136	472
G54D	6/19/2018	0.631	72.7	26	0.34	6.7	146	486
G54D	9/5/2018	0.660	73.6	25	0.30	6.5	152	480
G54D	3/27/2019	1.03	115	22	0.35	6.8	142	510
G54D	9/9/2019	0.614	79.9	<25	0.32	6.4	136	482
G54D	3/30/2020	0.766	84.9	22	0.33	6.8	184	508

Notes:

1. Abbreviations: mg/L - milligrams per liter; s.u. - standard units.

**Analytical Results - Appendix IV  
Joppa East Ash Pond**

Sample Location	Date Sampled	Antimony, total (mg/L)	Arsenic, total (mg/L)	Barium, total (mg/L)	Beryllium, total (mg/L)	Cadmium, total (mg/L)	Chromium, total (mg/L)	Cobalt, total (mg/L)	Fluoride, total (mg/L)	Lead, total (mg/L)	Lithium, total (mg/L)	Mercury, total (mg/L)	Molybdenum, total (mg/L)	Radium-226 + Radium-228, tot (pCi/L)	Selenium, total (mg/L)	Thallium, total (mg/L)
<b>Background Wells</b>																
G01D	12/3/2015	<0.001	0.0015	0.254	<0.001	<0.001	0.0047	0.0060	0.26	0.0018	0.0018	<0.0002	0.0010	0.07	<0.001	<0.001
G01D	3/15/2016	<0.001	0.0026	0.283	<0.001	<0.001	0.0032	0.0136	0.29	0.0012	0.0017	<0.0002	0.0013	0.96	<0.001	<0.001
G01D	6/15/2016	<0.001	0.0018	0.204	<0.001	<0.001	0.0016	0.0128	0.25	<0.001	0.0015	<0.0002	0.0010	0.44	<0.001	<0.001
G01D	9/14/2016	<0.001	0.0021	0.190	<0.001	<0.001	0.0031	0.0113	0.26	0.0013	0.0024	<0.0002	0.0010	0.58	<0.001	<0.001
G01D	12/14/2016	<0.001	0.0012	0.163	<0.001	<0.001	0.0036	0.0077	0.24	0.0012	0.0024	<0.0002	<0.001	0.40	<0.001	<0.001
G01D	3/7/2017	<0.001	<0.001	0.155	<0.001	<0.001	0.0014	0.0061	0.22	<0.001	0.0013	<0.0002	<0.001	0.24	<0.001	<0.001
G01D	6/15/2017	<0.001	<0.001	0.140	<0.001	<0.001	0.0032	0.0047	0.23	0.0013	0.0018	<0.0002	<0.001	0.93	<0.001	<0.001
G01D	7/20/2017	<0.001	0.001	0.140	<0.001	<0.001	0.0042	0.0035	0.24	0.0014	0.0017	<0.0002	0.0018	0.41	<0.001	<0.001
G01D	11/30/2017	NA	NA	NA	NA	NA	NA	NA	0.22	NA	NA	NA	NA	NA	NA	NA
G01D	6/19/2018	<0.001	0.0019	0.202	<0.001	<0.001	0.0093	0.0057	0.24	0.0034	0.0038	<0.0002	<0.0015	1.41	<0.001	<0.002
G01D	9/5/2018	NA	<0.001	0.147	NA	NA	0.0026	0.0022	0.20	<0.001	0.0017	NA	NA	0.37	0.0010	NA
G01D	3/27/2019	<0.001	<0.001	0.129	<0.001	<0.001	0.003	0.0014	0.23	<0.001	0.0015	<0.0002	<0.0015	0.78	0.0015	<0.002
G01D	9/9/2019	NA	<0.001	0.123	NA	NA	0.0044	0.0014	0.23	0.0012	<0.003	NA	NA	0.79	0.0011	NA
G01D	3/30/2020	<0.001	0.0011	0.130	<0.001	<0.001	0.0065	0.0018	0.21	0.0019	0.0034	<0.0002	<0.0015	1.44	0.0013	<0.002
G02D	12/3/2015	<0.001	<0.001	0.232	<0.001	<0.001	<0.001	0.0024	0.24	<0.001	0.0011	<0.0002	<0.001	1.10	0.0019	<0.001
G02D	3/15/2016	<0.001	<0.001	0.218	<0.001	<0.001	<0.001	<0.001	0.22	<0.001	<0.001	<0.0002	<0.001	0.47	0.0022	<0.001
G02D	6/15/2016	<0.001	<0.001	0.203	<0.001	<0.001	<0.001	<0.001	0.21	<0.001	0.0012	<0.0002	<0.001	0.63	0.0022	<0.001
G02D	9/14/2016	<0.001	<0.001	0.206	<0.001	<0.001	<0.001	<0.001	0.20	<0.001	0.0013	<0.0002	<0.001	0.33	0.0033	<0.001
G02D	12/14/2016	<0.001	<0.001	0.224	<0.001	<0.001	0.0057	0.0019	0.19	<0.001	0.0019	<0.0002	<0.001	0.40	0.0039	<0.001
G02D	3/8/2017	<0.001	<0.001	0.211	<0.001	<0.001	<0.001	<0.001	0.19	<0.001	<0.001	<0.0002	<0.001	1.06	0.0024	<0.001
G02D	6/14/2017	<0.001	<0.001	0.192	<0.001	<0.001	<0.001	<0.001	0.19	<0.001	0.0013	<0.0002	<0.001	0.63	0.0023	<0.001
G02D	7/20/2017	<0.001	<0.001	0.211	<0.001	<0.001	0.0016	<0.001	0.22	<0.001	<0.001	<0.0002	<0.001	1.33	0.0016	<0.001
G02D	11/30/2017	NA	NA	NA	NA	NA	NA	NA	0.21	NA	NA	NA	NA	NA	NA	NA
G02D	6/19/2018	<0.001	<0.001	0.245	<0.001	<0.001	<0.0015	<0.001	0.21	<0.001	<0.0015	<0.0002	<0.0015	0.92	0.0023	<0.002
G02D	9/5/2018	NA	<0.001	0.209	NA	NA	<0.0015	<0.001	0.18	<0.001	<0.0015	NA	NA	0.46	0.002	NA
G02D	3/27/2019	<0.001	<0.001	0.235	<0.001	<0.001	0.0026	<0.001	0.20	<0.001	<0.0015	<0.0002	<0.0015	0.12	0.003	<0.002
G02D	9/9/2019	NA	<0.001	0.208	NA	NA	<0.0015	<0.001	0.21	<0.001	<0.003	NA	NA	0.49	0.0021	NA
G02D	3/30/2020	<0.001	<0.001	0.202	<0.001	<0.001	<0.0015	<0.001	0.18	<0.001	<0.003	<0.0002	<0.0015	0.79	0.0035	<0.002
<b>Downgradient Wells</b>																
G51D	12/3/2015	<0.001	<0.001	0.129	<0.001	<0.001	<0.001	0.0141	0.13	<0.001	0.0035	<0.0002	<0.001	0.02	0.0024	<0.001
G51D	3/15/2016	<0.001	<0.001	0.0702	<0.001	<0.001	0.0014	0.0249	0.10	<0.001	0.0048	<0.0002	<0.001	0.69	0.0019	<0.001
G51D	6/15/2016	<0.001	<0.001	0.0628	<0.001	<0.001	<0.001	0.0198	<0.1	<0.001	0.0059	<0.0002	<0.001	0.43	0.0028	<0.001
G51D	9/14/2016	<0.001	<0.001	0.0536	<0.001	<0.001	<0.001	0.0110	<0.1	<0.001	0.0052	<0.0002	<0.001	0.80	0.0031	<0.001
G51D	12/14/2016	<0.001	<0.001	0.0459	<0.001	<0.001	<0.001	0.0119	<0.1	<0.001	0.0050	<0.0002	<0.001	0.29	0.0031	<0.001
G51D	3/8/2017	<0.001	<0.001	0.0493	<0.001	<0.001	<0.001	0.0082	<0.1	<0.001	0.0045	<0.0002	<0.001	0.52	0.0033	<0.001
G51D	6/15/2017	<0.001	<0.001	0.0442	<0.001	<0.001	<0.001	0.0052	<0.1	<0.001	0.0058	<0.0002	<0.001	0.56	0.0039	<0.001
G51D	7/20/2017	<0.001	<0.001	0.0462	<0.001	<0.001	<0.001	0.0055	<0.1	<0.001	0.0047	<0.0002	<0.001	1.68	0.0035	<0.001
G51D	11/30/2017	NA	NA	NA	NA	NA	NA	NA	<0.1	NA	NA	NA	NA	NA	NA	NA
G51D	6/19/2018	<0.001	<0.001	0.0756	<0.001	<0.001	<0.0015	0.0038	<0.1	<0.001	0.0070	<0.0002	<0.0015	1.22	0.0035	<0.002
G51D	9/5/2018	NA	<0.001	0.0395	#N/A	#N/A	<0.0015	0.0043	<0.1	<0.001	0.0054	NA	NA	0.42	0.0036	NA
G51D	3/27/2019	<0.001	<0.001	0.0495	<0.001	<0.001	0.0016	0.0026	<0.1	<0.001	0.0059	<0.0002	<0.0015	0.23	0.005	<0.002
G51D	9/9/2019	NA	<0.001	0.0377	#N/A	#N/A	<0.0015	0.0017	<0.1	<0.001	0.0057	NA	NA	0.36	0.0042	NA
G51D	3/30/2020	<0.001	<0.001	0.0445	<0.001	<0.001	0.0019	0.0024	<0.1	<0.001	0.0065	<0.0002	<0.0015	0.90	0.0048	<0.002

**Analytical Results - Appendix IV  
Joppa East Ash Pond**

Sample Location	Date Sampled	Antimony, total (mg/L)	Arsenic, total (mg/L)	Barium, total (mg/L)	Beryllium, total (mg/L)	Cadmium, total (mg/L)	Chromium, total (mg/L)	Cobalt, total (mg/L)	Fluoride, total (mg/L)	Lead, total (mg/L)	Lithium, total (mg/L)	Mercury, total (mg/L)	Molybdenum, total (mg/L)	Radium-226 + Radium-228, tot (pCi/L)	Selenium, total (mg/L)	Thallium, total (mg/L)
G52D	12/3/2015	<0.001	0.0032	0.318	<0.001	<0.001	<0.001	0.0056	0.25	<0.001	0.0026	<0.0002	0.0017	0.31	<0.001	<0.001
G52D	3/15/2016	<0.001	0.0051	0.345	<0.001	<0.001	<0.001	0.0064	0.26	<0.001	0.0023	<0.0002	<0.001	1.16	<0.001	<0.001
G52D	6/15/2016	<0.001	0.0072	0.506	<0.001	<0.001	<0.001	0.0093	0.25	<0.001	0.0040	<0.0002	<0.001	2.18	<0.001	<0.001
G52D	9/14/2016	<0.001	0.0043	0.362	<0.001	<0.001	<0.001	0.0063	0.26	<0.001	0.0027	<0.0002	0.0017	1.81	<0.001	<0.001
G52D	12/14/2016	<0.001	0.0030	0.356	<0.001	<0.001	<0.001	0.0030	0.25	<0.001	0.0036	<0.0002	0.0024	1.24	<0.001	<0.001
G52D	3/7/2017	<0.001	0.0066	0.358	<0.001	<0.001	<0.001	0.0072	0.24	<0.001	0.0024	<0.0002	<0.001	0.80	<0.001	<0.001
G52D	6/14/2017	<0.001	0.0054	0.289	<0.001	<0.001	<0.001	0.0062	0.24	<0.001	0.0030	<0.0002	<0.001	1.28	<0.001	<0.001
G52D	7/19/2017	<0.001	0.0016	0.293	<0.001	<0.001	<0.001	0.0013	0.27	<0.001	0.0028	<0.0002	0.0011	0.80	<0.001	<0.001
G52D	11/30/2017	NA	NA	NA	NA	NA	NA	NA	0.26	NA	NA	NA	NA	NA	NA	NA
G52D	6/19/2018	<0.001	0.0025	0.340	<0.001	<0.001	<0.0015	0.0045	0.26	<0.001	0.0035	<0.0002	<0.0015	1.64	<0.001	<0.002
G52D	9/5/2018	NA	0.0014	0.275	NA	NA	<0.0015	0.0019	0.24	<0.001	0.0032	NA	NA	0.68	<0.001	NA
G52D	3/27/2019	<0.001	0.0064	0.271	<0.001	<0.001	<0.0015	0.0069	0.28	<0.001	0.0028	<0.0002	<0.0015	0.58	<0.001	<0.002
G52D	9/9/2019	NA	0.0021	0.254	NA	NA	<0.0015	0.0022	0.27	<0.001	<0.003	NA	NA	1.54	<0.001	NA
G52D	3/30/2020	<0.001	0.0017	0.254	<0.001	<0.001	<0.0015	0.0033	0.27	<0.001	<0.003	<0.0002	<0.0015	1.30	<0.001	<0.002
G53D	12/3/2015	<0.001	<0.001	0.353	<0.001	<0.001	0.0017	0.0087	0.79	<0.001	0.0020	<0.0002	0.0013	0.28	<0.001	<0.001
G53D	3/15/2016	<0.001	<0.001	0.279	<0.001	<0.001	<0.001	0.0087	0.72	<0.001	0.0015	<0.0002	0.0012	1.24	<0.001	<0.001
G53D	6/15/2016	<0.001	<0.001	0.207	<0.001	<0.001	<0.001	0.0059	0.68	<0.001	0.0017	<0.0002	<0.001	1.11	<0.001	<0.001
G53D	9/14/2016	<0.001	<0.001	0.191	<0.001	<0.001	<0.001	0.002	0.70	<0.001	0.0016	<0.0002	<0.001	0.10	<0.001	<0.001
G53D	12/14/2016	<0.001	<0.001	0.169	<0.001	<0.001	<0.001	0.0029	0.69	<0.001	0.0018	<0.0002	<0.001	0.39	<0.001	<0.001
G53D	3/8/2017	<0.001	<0.001	0.109	<0.001	<0.001	0.0018	0.0027	0.49	<0.001	0.0021	<0.0002	<0.001	0.08	<0.001	<0.001
G53D	6/15/2017	<0.001	<0.001	0.172	<0.001	<0.001	<0.001	<0.001	0.59	<0.001	0.0022	<0.0002	<0.001	0.16	<0.001	<0.001
G53D	7/20/2017	<0.001	<0.001	0.165	<0.001	<0.001	<0.001	0.0011	0.69	<0.001	0.0015	<0.0002	<0.001	1.25	<0.001	<0.001
G53D	11/30/2017	NA	NA	NA	NA	NA	NA	NA	0.74	NA	NA	NA	NA	NA	NA	NA
G53D	6/19/2018	<0.001	<0.001	0.176	<0.001	<0.001	<0.0015	<0.001	0.66	<0.001	0.0019	<0.0002	<0.0015	0.77	<0.001	<0.002
G53D	9/5/2018	NA	<0.001	0.133	NA	NA	<0.0015	0.0016	0.61	<0.001	0.0018	NA	NA	0.55	<0.001	NA
G53D	3/27/2019	<0.001	<0.001	0.101	<0.001	<0.001	<0.0015	<0.001	0.59	<0.001	<0.0015	<0.0002	<0.0015	0.17	<0.001	<0.002
G53D	9/9/2019	NA	<0.001	0.128	NA	NA	<0.0015	0.002	0.67	<0.001	<0.003	NA	NA	0.03	<0.001	NA
G53D	3/30/2020	<0.001	<0.001	0.109	<0.001	<0.001	<0.0015	<0.001	0.63	<0.001	<0.003	<0.0002	<0.0015	1.32	<0.001	<0.002
G54D	12/3/2015	<0.001	0.0020	0.115	<0.001	<0.001	0.0016	0.0268	0.38	<0.001	0.0069	<0.0002	<0.001	0.20	<0.001	<0.001
G54D	3/15/2016	<0.001	0.0025	0.106	<0.001	<0.001	0.0030	0.0183	0.38	<0.001	0.0078	<0.0002	0.0010	0.354	<0.001	<0.001
G54D	6/15/2016	<0.001	0.0020	0.114	<0.001	<0.001	<0.001	0.0158	0.34	<0.001	0.0068	<0.0002	<0.001	1.02	<0.001	<0.001
G54D	9/14/2016	<0.001	0.0026	0.134	<0.001	<0.001	<0.001	0.0167	0.34	<0.001	0.0062	<0.0002	<0.001	0.39	<0.001	<0.001
G54D	12/14/2016	<0.001	0.0033	0.138	<0.001	<0.001	<0.001	0.0178	0.32	<0.001	0.0061	<0.0002	<0.001	1.05	<0.001	<0.001
G54D	3/8/2017	<0.001	0.0025	0.132	<0.001	<0.001	<0.001	0.017	0.30	<0.001	0.0048	<0.0002	<0.001	0.68	<0.001	<0.001
G54D	6/15/2017	<0.001	<0.001	0.105	<0.001	<0.001	0.0018	0.016	0.32	<0.001	0.0047	<0.0002	<0.001	1.67	<0.001	<0.001
G54D	7/20/2017	<0.001	0.0012	0.127	<0.001	<0.001	0.0017	0.0139	0.32	<0.001	0.0044	<0.0002	<0.001	0.32	<0.001	<0.001
G54D	11/30/2017	NA	NA	NA	NA	NA	NA	NA	0.33	NA	NA	NA	NA	NA	NA	NA
G54D	6/19/2018	<0.001	0.0019	0.196	<0.001	<0.001	0.0019	0.0134	0.34	<0.001	0.0060	<0.0002	<0.0015	1.00	<0.001	<0.002
G54D	9/5/2018	NA	0.0010	0.131	NA	NA	0.0020	0.0109	0.30	<0.001	0.0046	NA	NA	1.32	<0.001	NA
G54D	3/27/2019	<0.001	0.0011	0.120	<0.001	<0.001	<0.0015	0.0138	0.35	<0.001	0.0037	<0.0002	<0.0015	0.42	<0.001	<0.002
G54D	9/9/2019	NA	<0.001	0.128	NA	NA	<0.0015	0.0117	0.32	<0.001	0.0037	NA	NA	0.84	<0.001	NA
G54D	3/30/2020	<0.001	<0.001	0.105	<0.001	<0.001	<0.0015	0.013	0.33	<0.001	0.0036	<0.0002	<0.0015	0.89	<0.001	<0.002

Notes:

1. Abbreviations: mg/L - milligrams per liter; NA - not analyzed; pCi/L - picocurie per liter;



**ATTACHMENT 6 – SITE HYDROGEOLOGY AND STRATIGRAPHIC CROSS-  
SECTIONS OF THE SITE**

## CONCEPTUAL SITE MODEL AND DESCRIPTION OF SITE HYDROGEOLOGY (EAST ASH POND)

The Joppa Power Station (Power Station) conceptual site model (CSM) and Description of Site Hydrogeology for the Joppa East Ash Pond (EAP), located in Joppa, Illinois are described in the following sections.

### REGIONAL SETTING

The Power Station is located west of the Village of Joppa in Massac County, Illinois, northeast of the Ohio River in Section 14, Township 15 South, Range 3 East of the 3rd Principal Meridian. The EAP is located in the west half of Section 14 directly north of the Power Station. The Power Station property is bordered by LaFarge North America cement plant to the west, Trunkline Gas Company-Joppa Compressor Station to the north, the Village of Joppa to the east and the Ohio River to the south.

The EAP lies adjacent to and north to northeast of the Ohio River at the southern boundary of the Illinois Basin and the northern edge of the Mississippi Embayment, a relatively low lying area that is part of the Coastal Plain Physiographic Province (Leighton, 1948). Based on stack-unit maps prepared by the Illinois State Geological Survey (Berg and Kempton, 1987) the area is characterized by less than 20 feet of silty and clayey diamictons overlying Cretaceous-age sediments, silts, sands, etc., between depths of 20 to 50 feet. However, in some areas along the Ohio River, the predominant unlithified materials are Quaternary-age sand and gravel outwash deposits belonging to the Henry Formation. The unlithified materials rest on Mississippian-age bedrock. The bedrock dips gently northward toward the center of the Illinois Basin.

### SITE GEOLOGY

Previous investigations and reports at Joppa East Ash Pond indicate the surface impoundment is underlain by more than 50-feet of clay-rich deposits (predominantly clay and silty clay deposits with some minor intervals of sandy clay deposits) of the Equality and Metropolis Formations (NRT, 2013).

### SITE HYDROGEOLOGY

The CCR groundwater monitoring system consists of six monitoring wells installed in the uppermost aquifer and adjacent to the EAP (G01D, G02D, G51D, G52D, G53D, G54D) (see Monitoring Well Location Map, and Well Construction Diagrams and Drilling Logs attached to this demonstration). The unit utilizes two background monitoring wells (G01D and G02D) as part of the CCR groundwater monitoring system.

The uppermost aquifer consists of intermittent unlithified silty sand deposits within the McNairy Formation. The McNairy Formation was described as a hydrostratigraphic unit with greater permeability than the overlying clay-rich deposits of the Equality and Metropolis Formations in the Phase I Hydrogeologic Site Assessment Report (NRT, 2013). The report indicated the overlying hydrostratigraphic unit (inclusive of both the Equality and Metropolis Formations) is a confining unit, where the geometric mean hydraulic conductivity of the unit was  $5.9 \times 10^{-6}$  centimeters per second (cm/s). No known wells in the area utilize the Equality and Metropolis Formations for groundwater and most wells obtain groundwater from sands and gravels of the McNairy Formation or underlying Mississippian-age limestone bedrock. The McNairy Formation was also identified as the uppermost aquifer in the vicinity of Joppa Landfill, located northwest of the EAP (Hanson, 2009). The uppermost aquifer is laterally continuous across the Power Station and is approximately 85 feet thick in the vicinity of the EAP.

The lower limit of the uppermost aquifer (McNairy Formation) is the Mississippian-age Salem Limestone bedrock. The Mississippian-age bedrock in the vicinity of the EAP is a useable groundwater

resource (NRT,2013). The fractured limestone bedrock has widely variable transmissivities and is estimated to have a thickness of approximately 200 to 500 feet. Bedrock was intercepted at an elevation of approximately 210 feet MSL at plant well 4 located south of the EAP. Bedrock was not encountered in borings performed at the EAP.

### Hydraulic Conductivity

Falling/rising head tests were completed in wells screened in the unlithified material of the McNairy Formation (uppermost aquifer) as part of the supplemental site characterization activities completed by NRT in 2017. The single-well falling/rising head tests indicate the McNairy Formation has a moderate hydraulic conductivity ranging from  $2.4 \times 10^{-5}$  to  $9.9 \times 10^{-4}$  cm/s, with the exception of monitoring well location G52D, which exhibited a hydraulic conductivity of  $7.1 \times 10^{-8}$  cm/s. The geometric mean of hydraulic conductivities in the McNairy Formation was  $2.4 \times 10^{-4}$  cm/s. The effective porosity of this aquifer likely ranges significantly in magnitude due to its variable composition. The effective porosity of the aquifer was estimated (20%) from literature values (Smith and Wheatcraft, 1993) to calculate the groundwater velocity.

### Groundwater Elevations, Flow Direction and Velocity

Average measured groundwater elevations range from approximately 319 ft MSL in the northern portion of the EAP (upgradient, G01D and G02D), to approximately 312 ft MSL in southern portion of the EAP (downgradient, G54D). Groundwater elevations at downgradient well G52D, located southeast of the EAP, are typically more than 5 feet higher than nearby downgradient well G54D, located southwest of the EAP. A significant portion of the well screen at monitoring well G52D is across primarily clay and silt materials which may influence the hydraulic heads measured at the monitoring well location. Screened materials at G52D were also shown to have a decreased hydraulic conductivity when compared to other monitoring well locations which may influence the measured hydraulic heads.

Groundwater elevations vary seasonally and may fluctuate by about 10 feet. Slight seasonal variation in groundwater flow directions ranging from southeast to southwest are also observed, however, the major component of groundwater flow direction is consistently south toward the Ohio River, which is the primary discharge area in the vicinity of the EAP (NRT, 2013).

Horizontal hydraulic gradients are moderate across the EAP well network and ranged from 0.002 feet per foot (ft/ft) in December 2016 to 0.003 ft/ft in June 2017. Horizontal hydraulic gradients upgradient of the EAP (measured from monitoring wells G01D and G02D) appeared to be slightly lower.

Groundwater flow velocity at the EAP ranged from 0.003 to 0.01 feet per day (ft/day) in December 2016 and June 2017. In December 2016, groundwater flow velocity was 0.008 ft/day as groundwater flowed from northwest to southeast across the central portion of the EAP, while in June 2017 groundwater flow velocity was 0.01 ft/day. Near upgradient monitoring wells G01D and G02D, groundwater flow velocity was 0.003 ft/day in December 2016 and 0.009 ft/day in June 2017.

### REFERENCES





Berg, R.C., and J.P. Kempton, 1987, Stack-Unit Mapping of Geologic Materials in Illinois to a Depth of 15 Meters: Illinois State Geological Survey, Circular 542, 23 p.

Hanson Professional Services Inc. (Hanson), 2009. "Section 3 – Hydrogeologic Report" of Initial Facility Report, Landfill, CCB Management Facility, Joppa Generating Station, Massac County, Illinois, August 2009.

Leighton, M.M., G.E. Ekblaw, and L. Horberg, 1948, Physiographic Divisions of Illinois: Illinois State Geological Survey, Report of Investigations 129, 19 p.

Natural Resource Technology, Inc., 2013. Phase I Hydrogeological Assessment Report, Coal Combustion Product Impoundments, Joppa Generating Station, Joppa, IL, July 23, 2013.

Smith, L., and Wheatcraft, S.W., 1993, Groundwater Flow, in Handbook of Hydrology, D.R. Maidment (ed.), McGraw-Hill Inc., pp. 6.1-6.58, New York, NY.



DRAWN BY:	JMO	DATE:	09/27/2017
CHECKED BY:	JJW	DATE:	10/2/2017
APPROVED BY:	SJC	DATE:	10/2/2017
DRAWING NO:	East Ash Pond - Geologic Cross Sections Updated		
REFERENCE:			

**GEOLOGIC CROSS-SECTION A-A'**





JOPPA EAST ASH POND (UNIT ID: 401)  
 HYDROLOGIC MONITORING PLAN  
 DYNEGY CCR RULE GROUNDWATER MONITORING

JOPPA POWER STATION  
 JOPPA, ILLINOIS



PROJECT NO.  
2285.5/1.1

FIGURE NO.  
2



DRAWN BY:	JMO	DATE:	09/29/2017
CHECKED BY:	JJW	DATE:	10/2/2017
APPROVED BY:	SJC	DATE:	10/2/2017
DRAWING NO:	East Ash Pond - Geologic Cross Sections Updated		
REFERENCE:			

**GEOLOGIC CROSS-SECTION B-B'**  
 JOPPA EAST ASH POND (UNIT ID: 401)  
 HYDROLOGIC MONITORING PLAN  
 DYNEGY CCR RULE GROUNDWATER MONITORING  
 JOPPA POWER STATION  
 JOPPA, ILLINOIS



PROJECT NO.  
2285.5/1.1

FIGURE NO.  
**3**

**ATTACHMENT 7 – STRUCTURAL STABILITY ASSESSMENT**



Submitted to  
Electric Energy, Inc.  
2200 Portland Road  
Metropolis, IL 62960

Submitted by  
AECOM  
1001 Highlands Plaza Drive West  
Suite 300  
St. Louis, MO 63110

October 2016

# CCR Rule Report: Initial Structural Stability Assessment

For

East Ash Pond

At Joppa Power Station



# 1 Introduction

This Coal Combustion Residual (CCR) Rule Report documents that the East Ash Pond at the Electric Energy, Inc. (EEI) Joppa Power Station meets the structural stability assessment requirements specified in 40 Code of Federal Regulations (CFR) §257.73(d), except as noted herein. The East Ash Pond is located near Joppa, Illinois in Massac County, approximately 0.1 miles northeast of the Joppa Power Station. The East Ash Pond serves as the wet impoundment basin for CCRs produced by the Joppa Power Station.

The East Ash Pond is an existing CCR surface impoundment as defined by 40 CFR §257.53. The CCR Rule requires that an initial structural stability assessment for an existing CCR surface impoundment be completed by October 17, 2016. In general, the initial structural stability assessment must document that the design, construction, operation, and maintenance of the CCR unit is consistent with recognized and generally accepted good engineering practices.

The owner or operator of the CCR unit must obtain a certification from a qualified professional engineer stating that the initial structural stability assessment was conducted in accordance with the requirements of 40 CFR §257.73(d). The owner or operator must prepare a periodic structural stability assessment every five years.

## 2 Initial Structural Stability Assessment

### *40 CFR §257.73(d)(1)*

*The owner or operator of the CCR unit must conduct initial and periodic structural stability assessments and document whether the design, construction, operation, and maintenance of the CCR unit is consistent with recognized and generally accepted good engineering practices for the maximum volume of CCR and CCR wastewater which can be impounded therein. The assessment must, at a minimum, document whether the CCR unit has been designed, constructed, operated, and maintained with [the standards in (d)(1)(i)-(vii)].*

An initial structural stability assessment has been performed to document that the design, construction, operation and maintenance of the East Ash Pond is consistent with recognized and generally accepted good engineering practices. The results of the structural stability assessment are discussed in the following sections. Based on the assessment and its results, the design, construction, operation, and maintenance of the Joppa East Ash Pond were found to be consistent with recognized and generally accepted good engineering practices, and meet the standards in §257.73(d)(1)(i)-(vii), except as noted herein.

### **2.1 Foundations and Abutments (§257.73(d)(1)(i))**

*CCR unit designed, constructed, operated, and maintained with stable foundations and abutments.*

The stability of the foundations was evaluated using soil data from field investigations and reviewing design drawings, operational and maintenance procedures, and conditions observed in the field by AECOM. Additionally, slope stability analyses were performed to evaluate slip surfaces passing through the foundations. The East Ash Pond is a ring dike structure and does not have abutments.

The foundation consists of medium stiff to stiff clay overlying medium dense to dense sand, which indicates stable foundations. Ash placed before 1973 was identified below the compacted embankment of the dike and above the naturally occurring foundation materials near the southeast corner of the East Ash Pond embankment; however this condition was modified by installing a Deep Soil Mixed (DMM), wet soil cement mixed method, zone in 2016. Slope stability analyses exceed the criteria listed in §257.73(e)(1) for slip surfaces passing through the foundation. The slope stability analyses are discussed in the *CCR Rule Report: Initial Safety Factor Assessment for East Ash Pond at Joppa Power Station* (October 2016). Additional slope stability analyses were performed to evaluate the effects of liquefaction in the foundation and were found to satisfy the criteria in §257.73(e)(1)(iv) applicable to dikes. A review of information about operations and maintenance as well as current and past performance of the dikes has determined appropriate processes are in place for continued operational performance.

Based on the conditions observed by AECOM, the East Ash Pond was designed and constructed with stable foundations. Any issues related to the stability of the foundation are addressed during operations and maintenance; therefore, the East Ash Pond meets the requirements in §257.73(d)(1)(i).

### **2.2 Slope Protection (§257.73(d)(1)(ii))**

*CCR unit designed, constructed, operated, and maintained with adequate slope protection to protect against surface erosion, wave action and adverse effects of sudden drawdown.*

The adequacy of slope protection was evaluated by reviewing design drawings, information about operations and maintenance, and conditions observed in the field by AECOM.

Based on this evaluation, adequate slope protection was designed and constructed at the East Ash Pond. No evidence of significant areas of erosion or wave action was observed. The exterior dike slopes are covered with crushed stone and vegetation for slope protection. EEL regularly maintains the slopes, including repairing observed surface erosion and addressing areas of poor vegetation growth, as required. As the exterior slopes are not adjacent to a downstream water body, they are not susceptible to wave action or sudden drawdown. AECOM observed the vegetation to be adequately protecting against surface erosion.

The interior dike slopes have a 1.5H:1V orientation and are covered with vegetation, stacked CCRs, and some limited areas of crushed stone. Sudden drawdown conditions are not expected to occur due to the characteristics of the outfall structure at the East Ash Pond. EEL regularly maintains the interior slopes, including repairing observed surface erosion and addressing areas of poor vegetation growth, as required. AECOM observed the vegetation to be adequately protecting against surface erosion and wave action. Therefore, the East Ash Pond meets the requirements in §257.73(d)(1)(ii).

### **2.3 Dike Compaction (§257.73(d)(1)(iii))**

*CCR unit designed, constructed, operated, and maintained with dikes mechanically compacted to a density sufficient to withstand the range of loading conditions in the CCR unit.*

The density of the dike materials was evaluated using soil strength data from field investigations and reviewing design drawings, information about operations and maintenance, and conditions observed in the field by AECOM. Additionally, slope stability analyses were performed to evaluate slip surfaces passing through the dike over the range of expected loading conditions as defined within §257.73(e)(1).

Based on this evaluation, the dike consists of medium stiff to stiff material, which is indicative of properly mechanically compacted dikes. Slope stability analyses exceed the criteria listed in §257.73(e)(1) for slip surfaces passing through the dike. The slope stability analyses are discussed in the *CCR Rule Report: Initial Safety Factor Assessment for East Ash Pond at Joppa Power Station* (October 2016); therefore, the original design and construction of the East Ash Pond included sufficient dike compaction. Operational and maintenance procedures are in place to identify and mitigate deficiencies in order to maintain sufficient compaction and density of the dikes to withstand the range of loading conditions. Therefore, the East Ash Pond meets the requirements in §257.73(d)(1)(iii).

### **2.4 Vegetated Slopes (§257.73(d)(1)(iv))<sup>1</sup>**

*CCR unit designed, constructed, operated, and maintained with vegetated slopes of dikes and surrounding areas, except for slopes which have an alternate form or forms of slope protection.*

The adequacy of slope vegetation was evaluated by reviewing design drawings, information about operations and maintenance, and conditions observed in the field by AECOM.

Based on this evaluation, the vegetation on the exterior slopes is adequate as no substantial bare or overgrown areas were observed. The exterior slopes were vegetated or covered with crushed stone and the interior slopes were covered with vegetation, crushed stone, or mechanically-stacked CCR which are alternate forms of slope protection. Therefore, the original design and construction of the East Ash Pond included adequate vegetation of the dikes and surrounding areas. Adequate operational and maintenance practices are in place to regularly manage vegetation growth, including mowing and seeding any bare areas, as evidenced by the conditions observed by AECOM. Therefore, the East Ash Pond meets the requirements in §257.73(d)(1)(iv).

---

<sup>1</sup> As modified by court order issued June 14, 2016, *Utility Solid Waste Activities Group v. EPA*, D.C. Cir. No. 15-1219 (order granting remand and vacatur of specific regulatory provisions).

## 2.5 Spillways (§257.73(d)(1)(v))

*CCR unit designed, constructed, operated, and maintained with a single spillway or a combination of spillways configured as specified in [paragraph (A) and (B)]:*

*(A) All spillways must be either:*

- (1) of non-erodible construction and designed to carry sustained flows; or*
- (2) earth- or grass-lined and designed to carry short-term, infrequent flows at non-erosive velocities where sustained flows are not expected.*

*(B) The combined capacity of all spillways must adequately manage flow during and following the peak discharge from a:*

- (1) Probable maximum flood (PMF) for a high hazard potential CCR surface impoundment; or*
- (2) 1000-year flood for a significant hazard potential CCR surface impoundment; or*
- (3) 100-year flood for a low hazard potential CCR surface impoundment.*

The spillways were evaluated using design drawings, information about operations and maintenance, and conditions observed in the field by AECOM. Additionally, hydrologic and hydraulic analyses were completed to evaluate the capacity of the spillway relative to inflow estimated for the probable maximum flood event for the high hazard potential East Ash Pond.

Two spillway structures are present at the East Ash Pond, including a ductile iron pipe and high-density polyethylene (HDPE) spillway pipe and a reinforced concrete pipe (RCP) spillway. The ductile iron, HDPE, and reinforced concrete are non-erodible materials designed to carry sustained flows. The capacity of the spillways was evaluated using hydrologic and hydraulic analysis performed per §257.82(a). The analysis found that the spillways can adequately manage flow during peak discharge resulting from the probable maximum flood event without overtopping of the embankments. The hydrologic and hydraulic analyses are discussed in the *CCR Rule Report: Initial Inflow Design Flood Control System Plan for East Ash Pond at Joppa Power Station* (October 2016). Therefore, the East Ash Pond meets the requirements in §257.73(d)(1)(v).

## 2.6 Stability and Structural Integrity of Hydraulic Structures (§257.73(d)(1)(vi))

*CCR unit designed, constructed, operated, and maintained with hydraulic structures underlying the base of the CCR unit or passing through the dike of the CCR unit that maintain structural integrity and are free of significant deterioration, deformation, distortion, bedding deficiencies, sedimentation, and debris which may negatively affect the operation of the hydraulic structure.*

Two hydraulic structures pass through the dike of the East Ash Pond: the south-sub-basin 26-inch diameter HDPE spillway pipe and the north sub-basin 48-inch RCP spillway pipe. The stability and structural integrity of both pipes were evaluated using design drawings, information about operations and maintenance, inspections, and conditions observed in the field by AECOM. No other hydraulic structures are known to pass through the dike or underlie the base of the East Ash Pond.

Closed circuit television (CCTV) inspections of both pipes were attempted in 2016. The 48-inch RCP was successfully visually inspected and noted to contain 12-inches of cemented CCR materials. However, the pipe was free of significant deterioration, deformation, distortion, and bedding deficiencies that may negatively affect the operation of the hydraulic structure. The presence of the cemented CCR materials was accounted for in the hydrologic and hydraulic analyses discussed in the *CCR Rule Report: Initial Inflow Design Flood Control System Plan for East Ash Pond at Joppa Power Station* (October 2016), and were not found sufficient enough to negatively affect the operation of the hydraulic structure. The inspection of the HDPE spillway pipe could not be fully completed due to access issues that prevented an inspection of the entire pipe. However, the evaluation of design drawings, operational and maintenance procedures, and conditions observed in the field did not identify any issues with the HDPE spillway pipe.

Based on this evaluation, all East Ash Pond hydraulic structures cannot be certified to meet the requirements of §257.73(d)(1)(vi) because a complete CCTV inspection of the 26-inch HDPE pipe has not yet been performed, thus, precluding completion of the evaluation of the stability and structural integrity of that pipe. In accordance

with §257.73(d)(2), AECOM recommends that a CCTV pipe inspection of the 26-inch HDPE pipe be completed as soon as feasible and that this assessment be updated once the inspection is completed.

## **2.7 Downstream Slope Inundation/Stability (§257.73(d)(1)(vii))**

*CCR unit designed, constructed, operated, and maintained with, for CCR units with downstream slopes which can be inundated by the pool of an adjacent water body, such as a river, stream or lake, downstream slopes that maintain structural stability during low pool of the adjacent water body or sudden drawdown of the adjacent water body.*

The structural stability of the downstream slope of the East Ash Pond was evaluated by comparing the location of the East Pond relative to published flood maps for the area. The East Ash Pond is located outside of the 100-year flood zone shown on the FEMA Federal Insurance Rate Map (FIRM) map for Massac County, Illinois and the village of Joppa, Illinois. Therefore, adjacent water bodies that could potentially inundate the downstream slopes of the East Ash Pond are not present. Based on this evaluation, the requirements in §257.73(d)(1)(vii) are not applicable to the East Ash Pond, as inundation of the downstream slopes is not expected to occur during 100-year or lesser flood conditions.


### 3 Certification Statement

**CCR Unit:** Electric Energy, Inc.; Joppa Power Station; East Ash Pond

I, Victor A. Modeer, being a Registered Professional Engineer in good standing in the State of Illinois, do hereby certify, to the best of my knowledge, information, and belief that the information contained in this CCR Rule Report, and the underlying data in the operating record, has been prepared in accordance with the accepted practice of engineering. I certify, for the above-referenced CCR Unit, that the initial structural stability assessment dated October 14, 2016 was conducted in accordance with the requirements of 40 CFR §257.73.

Victor A. Modeer  
Printed Name

10/14/16  
Date



## About AECOM

AECOM (NYSE: ACM) is a global provider of professional technical and management support services to a broad range of markets, including transportation, facilities, environmental, energy, water and government. With nearly 100,000 employees around the world, AECOM is a leader in all of the key markets that it serves. AECOM provides a blend of global reach, local knowledge, innovation, and collaborative technical excellence in delivering solutions that enhance and sustain the world's built, natural, and social environments. A Fortune 500 company, AECOM serves clients in more than 100 countries and has annual revenue in excess of \$19 billion.

More information on AECOM and its services can be found at [www.aecom.com](http://www.aecom.com).

1001 Highlands Plaza Drive West  
Suite 300  
St. Louis, MO 63110  
1-314-429-0100

**ATTACHMENT 8 – SAFETY FACTOR ASSESSMENT**





Submitted to  
Electric Energy, Inc.  
2200 Portland Road  
Metropolis, IL 62960

Submitted by  
AECOM  
1001 Highlands Plaza Drive West  
Suite 300  
St. Louis, MO 63110

October 2016

# CCR Rule Report: Initial Safety Factor Assessment

For

East Ash Pond

At Joppa Power Station

# 1 Introduction

This Coal Combustion Residual (CCR) Rule Report documents that the East Ash Pond at the Electric Energy, Inc. (EEI) Joppa Power Station meets the safety factor assessment requirements specified in 40 Code of Federal Regulations (CFR) §257.73(e). The East Ash Pond is located near Joppa, Illinois in Massac County, approximately 0.1 miles northeast of the Joppa Power Station. The East Ash Pond serves as the ash impoundment basin for CCRs produced at the Joppa Power Station.

The East Ash Pond is an existing CCR surface impoundment as defined by 40 CFR §257.53. The CCR Rule requires that the initial safety factor assessment for an existing CCR surface impoundment be completed by October 17, 2016.

The owner or operator of the CCR unit must obtain a certification from a qualified professional engineer stating that the initial safety factor assessment meets the requirements of 40 CFR § 257.73(e). The owner or operator must prepare a safety factor assessment every five years.

## 2 Initial Safety Factor Assessment

### 40 CFR §257.73(e)(1)

The owner or operator must conduct initial and periodic safety factor assessments for each CCR unit and document whether the calculated factors of safety for each CCR unit achieve the minimum safety factors specified in (e)(1)(i) through (iv) of this section for the critical cross section of the embankment. The critical cross section is the cross section anticipated to be the most susceptible of all cross sections to structural failure based on appropriate engineering considerations, including loading conditions. The safety factor assessments must be supported by appropriate engineering calculations.

(i) The calculated static factor of safety under the long-term, maximum storage pool loading condition must equal or exceed 1.50.

(ii) The calculated static factor of safety under the maximum surcharge pool loading condition must equal or exceed 1.40.

(iii) The calculated seismic factor of safety must equal or exceed 1.00.

(iv) For dikes constructed of soils that have susceptibility to liquefaction, the calculated liquefaction factor of safety must equal or exceed 1.20.

A geotechnical investigation program and stability analyses were performed to evaluate the design, performance, and condition of the earthen dikes of the East Ash Pond. The exploration consisted of hollow-stem auger borings, cone penetration testing with seismic wave velocity measurements and pore pressure dissipation testing, piezometer installation and monitoring, and a laboratory program including strength and index testing. Data collected from the geotechnical investigation, available design drawings, construction records, inspection reports, previous engineering investigations, and other pertinent historic documents were utilized to perform the safety factor assessment and geotechnical analyses.

The East Ash Pond embankment is generally medium stiff to stiff and overlies predominantly alluvial foundation materials. The alluvial foundation consists of soft to stiff clay overlying medium dense to dense sand. A zone of sluiced flyash that existed before the embankment dike was constructed was encountered below the compacted embankment in the southeast corner. The zone of sluiced flyash was modified by the installation of Deep Mixing Method (DMM) ground improvement technology using the wet soil mixing method. Explorations were terminated in the soil overburden and were not extended to bedrock. The phreatic surface is typically at or slightly above the embankment/foundation interface.

Six (6) representative cross sections were analyzed using limit equilibrium slope stability analysis software to evaluate stability of the perimeter dike system and foundations. The cross sections were located to represent critical surface geometry, subsurface stratigraphy, and phreatic conditions across the CCR unit. Each cross section was evaluated for each of the loading conditions stipulated in §257.73(e)(1).

The Soils Susceptible to Liquefaction loading condition, §257.73(e)(1)(iv), was not evaluated because a liquefaction susceptibility evaluation did not find soils susceptible to liquefaction within the East Ash Pond dikes. As a result, this loading condition is not applicable to the East Ash Pond at the Joppa Power Station.

Results of the Initial Safety Factor Assessments, for the critical cross-section for each loading condition (i.e., the lowest calculated factor of safety out of the cross sections analyzed for each loading condition), are listed in Table 1.

**Table 1 – Summary of Initial Safety Factor Assessments**

Loading Conditions	§257.73(e)(1) Subsection	Minimum Factor of Safety	Calculated Factor of Safety
Maximum Storage Pool Loading	(i)	1.50	1.59
Maximum Surcharge Pool Loading	(ii)	1.40	1.57
Seismic	(iii)	1.00	1.01
Soils Susceptible to Liquefaction	(iv)	1.20	Not Applicable

Based on this evaluation, the East Ash Pond meets the requirements in §257.73(e)(1).


### 3 Certification Statement

**CCR Unit:** Electric Energy, Inc.; Joppa Power Station; East Ash Pond

I, Victor A. Modeer, being a Registered Professional Engineer in good standing in the State of Illinois, do hereby certify, to the best of my knowledge, information, and belief that the information contained in this CCR Rule Report, and the underlying data in the operating record, has been prepared in accordance with the accepted practice of engineering. I certify, for the above-referenced CCR Unit, that the initial safety factor assessment dated October 14, 2016 meets the requirements of 40 CFR §257.73.

Victor A. Modeer Jr  
Printed Name

10 / 14 / 16  
Date



## About AECOM

AECOM (NYSE: ACM) is a global provider of professional technical and management support services to a broad range of markets, including transportation, facilities, environmental, energy, water and government. With nearly 100,000 employees around the world, AECOM is a leader in all of the key markets that it serves. AECOM provides a blend of global reach, local knowledge, innovation, and collaborative technical excellence in delivering solutions that enhance and sustain the world's built, natural, and social environments. A Fortune 500 company, AECOM serves clients in more than 100 countries and has annual revenue in excess of \$19 billion.

More information on AECOM and its services can be found at [www.aecom.com](http://www.aecom.com).

1001 Highlands Plaza Drive West  
Suite 300  
St. Louis, MO 63110  
1-314-429-0100

**ATTACHMENT 9 – ADDENDUM TO THE CLOSURE PLAN (SEPTEMBER 2020)**

## ADDENDUM NO. 1 JOPPA EAST ASH POND CLOSURE PLAN


This Addendum No. 1 to the Closure Plan for Existing Coal Combustion Residuals (CCR) Impoundment for the Joppa East Ash Pond at the Joppa Power Station, Revision 0 - October 17, 2016 has been prepared to meet the requirements of Title 40 of the Code of Federal Regulations (40 C.F.R.) Section 257.103(f)(2)(v)(D) as a component of the demonstration that the Joppa East Ash Pond qualifies for a site-specific alternative deadline to initiate closure due to permanent cessation of a coal-fired boiler by a certain date.

The Joppa East Ash Pond will begin construction of closure by October 17, 2025 and cease receipt and placement of CCR and non-CCR wastestreams by no later than July 17, 2027 as indicated in the Joppa Power Station Alternative Closure Demonstration dated September 29, 2020. Closure will be completed by October 17, 2028 within the 5-year timeframe included in the Closure Schedule identified in the Joppa East Ash Pond Closure Plan in accordance with 40 C.F.R. § 257.102(f)(ii).

All other aspects of the Closure Plan remain unchanged.

## CERTIFICATION

I, Eric J. Tlachac, a Qualified Professional Engineer in good standing in the State of Illinois, certify that the information in this addendum is accurate as of the date of my signature below. The content of this report is not to be used for other than its intended purpose and meaning, or for extrapolations beyond the interpretations contained herein.



Eric J. Tlachac  
Qualified Professional Engineer  
062-063091  
Illinois

Ramboll Americas Engineering Solutions, Inc., f/k/a O'Brien & Gere Engineers, Inc.

Date: September 29, 2020





CREATE AMAZING.

Burns & McDonnell World Headquarters  
9400 Ward Parkway  
Kansas City, MO 64114  
O 816-333-9400  
F 816-333-3690  
[www.burnsmcd.com](http://www.burnsmcd.com)