

Annual CCR Fugitive Dust Control Report

for

Kincaid Power Plant

Prepared for:



Kincaid Generation, LLC

Kincaid Power Plant
4 Miles West of Kincaid on Route 104
Kincaid, IL 62540

November 2021

**Kincaid Power Plant
ANNUAL CCR FUGITIVE DUST CONTROL REPORT**

CCR Activity	Actions Taken to Control CCR Fugitive Dust
Handling of CCR at the facility	Perform housekeeping, as necessary, in the fly ash loading area.
	Operate fly ash handling system in accordance with good operating practices.
	Maintain and repair as necessary dust controls on the fly ash handling system.
Transportation of CCR at the facility for onsite and offsite disposal	Cover or enclose trucks or containers used to transport CCR fly ash.
	Limit the speed of vehicles to no more than 15 mph on facility roads.
	Cover or enclose trucks or containers used to transport CCR other than fly ash, as necessary.
	Watering roads used to transport CCR materials, as needed.
	Sweep or rinse off the outside of the trucks transporting CCR, as necessary.
	Remove CCR, as necessary, deposited on facility road surfaces during transport.

Based on a review of the Plan and inspections associated with CCR fugitive dust control performed in the reporting year, the control measures identified in the Plan as implemented at the facility effectively minimized CCR from becoming airborne at the facility. No corrective actions were needed during the reporting period. No revisions or additions to control measures identified in the Plan were needed. No material changes occurred in the reporting year in site conditions potentially resulting in CCR fugitive dust becoming airborne at the facility that warrant amendment of the Plan.

Section 2 Record of Citizen Complaints

No citizen complaints were received regarding CCR fugitive dust at Kincaid Power Plant in the reporting year.