

Annual CCR Fugitive Dust Control Report for Newton Power Station

Prepared for:




Illinois Power Generating Company

**Newton Power Station
6725 North 500th Street
Newton, IL 62448**

December 2020

**Newton Power Station
ANNUAL CCR FUGITIVE DUST CONTROL REPORT**

Reporting Year: 4th Quarter 2019 through 3rd Quarter 2020

Completed by:  
Name Title

This Annual CCR Fugitive Dust Control Report has been prepared for the Newton Power Station in accordance with 40 CFR 257.80(c). Section 1 provides a description of the actions taken to control CCR fugitive dust at the facility during the reporting year, including a summary of any corrective measures taken. Section 2 provides a record of citizen complaints received concerning CCR fugitive dust at the facility during the reporting year, including a summary of any corrective measures taken.

Section 1 Actions Taken to Control CCR Fugitive Dust

In accordance with the Newton Power Station CCR Fugitive Dust Control Plan (Plan), the following measures were used to control CCR fugitive dust from becoming airborne at the facility during the reporting year:

CCR Activity	Actions Taken to Control CCR Fugitive Dust
Management of CCR in the facility's CCR units	CCR to be emplaced in the landfill is conditioned before loading into vehicles for transport to the landfill.
	Apply cover to exposed material in the landfill.
	Wet management of CCR bottom ash and CCR fly ash in CCR surface impoundments.
	Water areas of exposed CCR in CCR units, as necessary.
	Naturally occurring grass vegetation in areas of exposed CCR in CCR surface impoundments.
Handling of CCR at the facility	Wet sluice CCR bottom ash and fly ash to CCR surface impoundments.
	Pneumatically convey dry CCR fly ash to storage silos in an enclosed system.
	CCR fly ash to be emplaced in the landfill is conditioned before loading into trucks for transport to the landfill.
	Load CCR transport trucks from the CCR fly ash silos in a partially enclosed area.
	Load CCR transport trucks from the CCR fly ash silos using a telescoping chute.

**Newton Power Station
ANNUAL CCR FUGITIVE DUST CONTROL REPORT**

CCR Activity	Actions Taken to Control CCR Fugitive Dust
Handling of CCR at the facility	Perform housekeeping, as necessary, in the fly ash loading area.
	Operate fly ash handling system in accordance with good operating practices.
	Maintain and repair as necessary dust controls on the fly ash handling system.
Transportation of CCR at the facility	CCR to be emplaced in the landfill is conditioned before loaded into vehicles for transport to the landfill.
	Cover or enclose trucks used to transport CCR material, as necessary.
	Limit the speed of vehicles to no more than 15 mph on facility roads.
	Sweep or rinse off the outside of the trucks transporting CCR, as necessary.
	Remove CCR, as necessary, deposited on facility road surfaces during transport.

Based on a review of the Plan and inspections associated with CCR fugitive dust control performed in the reporting year, the control measures identified in the Plan as implemented at the facility effectively minimized CCR from becoming airborne at the facility. No revisions or additions to control measures identified in the Plan were needed.

No material changes occurred in the reporting year in site conditions potentially resulting in CCR fugitive dust becoming airborne at the facility that warrant an amendment of the Plan.

Section 2 Record of Citizen Complaints

No citizen complaints were received regarding CCR fugitive dust at Newton Power Station in the reporting year.