

40 C.F.R. § 257.95(g) NOTIFICATION FOR STATISTICALLY SIGNIFICANT LEVELS OF 40 C.F.R. PART 257 APPENDIX IV CONSTITUENTS ABOVE GROUNDWATER PROTECTION STANDARDS MIAMI FORT POND SYSTEM

February 17, 2021

In accordance with Title 40 Code of Federal Regulations (C.F.R.) § 257.95(g), the owner or operator of a Coal Combustion Residuals (CCR) unit must prepare a notification that identifies constituents listed in Appendix IV of 40 C.F.R. Part 257 that have exceeded Groundwater Protection Standards established under 40 C.F.R. § 257.95(h). The notification must be placed in the facility's operating record within 30 days of detection (40 C.F.R. § 257.105(h)(8)).

The following Appendix IV constituents were detected at Statistically Significant Levels above the applicable Groundwater Protection Standards established pursuant to 40 C.F.R. § 257.95(h) during assessment monitoring completed at Miami Fort Pond System:

- Arsenic
- Cobalt
- Molybdenum

Miami Fort