Prepared for

**Dynegy Zimmer, LLC** 

Date

January 31, 2021

Project No.

1940074924

# 2020 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT

ZIMMER GYPSUM RECYCLE POND, ZIMMER POWER STATION

## 2020 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT ZIMMER GYPSUM RECYCLE POND, ZIMMER POWER STATION

Project name Zimmer Power Station

Project no. **1940074924** 

Recipient Dynegy Zimmer, LLC

Document type Annual Groundwater Monitoring and Corrective Action Report

Version FINAL

Date January 31, 2021
Prepared by Kristen L. Theesfeld
Checked by Nikki M. Pagano, PE
Approved by Lauren D. Cook

Description Annual Report in Support of the CCR Rule Groundwater Monitoring Program

Ramboll

234 W. Florida Street

Fifth Floor

Milwaukee, WI 53204

USA

T 414-837-3607 F 414-837-3608 https://ramboll.com

Kristen L. Theesfeld Hydrogeologist Nikki M. Pagano, PG Senior Managing Engineer

#### **CONTENTS**

<b>EXECU</b>	ITIVE SUMMARY	3
1.	Introduction	4
2.	Monitoring and Corrective Action Program Status	6
3.	Key Actions Completed in 2020	7
4.	<b>Problems Encountered and Actions to Resolve the Problems</b>	9
5.	Key Activities Planned for 2021	10
6.	References	11

#### **TABLES (IN TEXT)**

Table A 2019-2020 Assessment Monitoring Program Summary

#### **TABLES (ATTACHED)**

Table 1 Analytical Results – Groundwater Elevation and Appendix III Parameters

Table 2 Analytical Results – Appendix IV Parameters

Table 3 Statistical Background Values
Table 4 Groundwater Protection Standards

#### **FIGURES**

Figure 1 Monitoring Well Location Map

#### **ACRONYMS AND ABBREVIATIONS**

40 C.F.R. Title 40 of the Code of Federal Regulations

ASD Alternate Source Demonstration CCR Coal Combustion Residuals

CMA Corrective Measures Assessment

GRP Gypsum Recycle Pond

GWPS Groundwater Protection Standard
SSI Statistically Significant Increase
SSL Statistically Significant Level



#### **EXECUTIVE SUMMARY**

This report has been prepared to provide the information required by Title 40 of the Code of Federal Regulations (40 C.F.R.) § 257.90(e) for Zimmer Gypsum Recycle Pond (GRP) located at Zimmer Power Station near Moscow, Ohio.

Groundwater is being monitored at Zimmer GRP in accordance with the Assessment Monitoring Program requirements specified in 40 C.F.R. § 257.95. Assessment Monitoring was initiated at Zimmer GRP on April 9, 2018.

No changes were made to the monitoring system in 2020 (no wells were installed or decommissioned).

No Statistically Significant Levels (SSLs) of 40 C.F.R. Part 257 Appendix IV parameters were determined. Consequently, a Corrective Measures Assessment (CMA) is not required and Zimmer GRP remains in the Assessment Monitoring Program.

#### 1. INTRODUCTION

This report has been prepared by Ramboll Americas Engineering Solutions Inc. (Ramboll) on behalf of Dynegy Zimmer, LLC, to provide the information required by 40 C.F.R.§ 257.90(e) for Zimmer GRP located at Zimmer Power Station near Moscow, Ohio.

In accordance with 40 C.F.R. § 257.90(e), the owner or operator of a Coal Combustion Residuals (CCR) unit must prepare an Annual Groundwater Monitoring and Corrective Action Report for the preceding calendar year that documents the status of the Groundwater Monitoring and Corrective Action Program for the CCR unit, summarizes key actions completed, describes any problems encountered, discusses actions to resolve the problems, and projects key activities for the upcoming year. At a minimum, the annual report must contain the following information, to the extent available:

- 1. A map, aerial image, or diagram showing the CCR unit and all background (or upgradient) and downgradient monitoring wells, to include the well identification numbers, that are part of the groundwater monitoring program for the CCR unit.
- 2. Identification of any monitoring wells that were installed or decommissioned during the preceding year, along with a narrative description of why those actions were taken.
- 3. In addition to all the monitoring data obtained under §§ 257.90 through 257.98, a summary including the number of groundwater samples that were collected for analysis for each background and downgradient well, the dates the samples were collected, and whether the sample was required by the Detection Monitoring or Assessment Monitoring Programs.
- 4. A narrative discussion of any transition between monitoring programs (e.g., the date and circumstances for transitioning from Detection Monitoring to Assessment Monitoring in addition to identifying the constituent(s) detected at a Statistically Significant Increase [SSI] relative to background levels).
- 5. Other information required to be included in the annual report as specified in §§ 257.90 through 257.98.
- 6. A section at the beginning of the annual report that provides an overview of the current status of groundwater monitoring and corrective action programs for the CCR unit. At a minimum, the summary must specify all of the following:
  - i. At the start of the current annual reporting period, whether the CCR unit was operating under the detection monitoring program in §257.94 or the assessment monitoring program in §257.95.
  - ii. At the end of the current annual reporting period, whether the CCR unit was operating under the detection monitoring program in §257.94 or the assessment monitoring program in §257.95.
  - iii. If it was determined that there was a SSI over background for one or more constituents listed in Appendix III of §257 pursuant to §257.94(e):
    - A. Identify those constituents listed in Appendix III of §257 and the names of the monitoring wells associated with the SSI(s).

- B. Provide the date when the assessment monitoring program was initiated for the CCR unit.
- iv. If it was determined that there was a SSL above the Groundwater Protection Standard (GWPS) for one or more constituents listed in Appendix IV of §257 pursuant to §257.95(g) include all of the following:
  - A. Identify those constituents listed in Appendix IV of §257 and the names of the monitoring wells associated with the SSL(s).
  - B. Provide the date when the CMA was initiated for the CCR unit.
  - C. Provide the date when the public meeting was held for CMA for the CCR unit.
  - D. Provide the date when the CMA was completed for the CCR unit.
- v. Whether a remedy was selected pursuant to §257.97 during the current annual reporting period, and if so, the date of remedy selection.
- vi. Whether remedial activities were initiated or are ongoing pursuant to §257.98 during the current annual reporting period.

This report provides the required information for Zimmer GRP for calendar year 2020.

### 2. MONITORING AND CORRECTIVE ACTION PROGRAM STATUS

No changes have occurred to the Monitoring Program status in calendar year 2020, and Zimmer GRP remains in the Assessment Monitoring Program in accordance with 40 C.F.R. § 257.95.



#### 3. KEY ACTIONS COMPLETED IN 2020

The Assessment Monitoring Program is summarized in Table A. The groundwater monitoring system, including the CCR unit and all background and downgradient monitoring wells, is presented in Figure 1. No changes were made to the monitoring system in 2020. In general, one groundwater sample was collected from each background and downgradient well during each monitoring event. All samples were collected and analyzed in accordance with the Sampling and Analysis Plan (AECOM, 2017). All monitoring data obtained under 40 C.F.R. §§ 257.90 through 257.98 (as applicable) in 2020, and analytical results for the September 2019 sampling event, are presented in Tables 1 and 2. Analytical data were evaluated in accordance with the Statistical Analysis Plan (NRT/OBG, 2017) to determine any SSLs of Appendix IV parameters over GWPSs.

Statistical background values are provided in Table 3 and GWPSs in Table 4.



Table A - 2019-2020 Assessment Monitoring Program Summary

Sampling Dates	Analytical Data Receipt Date	Parameters Collected	SSL(s)	SSL(s) Determination Date
September 11 - 12, 2019	October 16, 2019	Appendix III		
		Appendix IV Detected <sup>1</sup>	none	January 14, 2020
April 9 - 10, 2020	April 27, 2020	Appendix III		
		Appendix IV	none	July 27, 2020
September 16-17, 2020	October 31, 2020	Appendix III		
		Appendix IV Detected <sup>1</sup>	TBD	TBD

#### Notes:

NA: Not Applicable TBD: To Be Determined

<sup>1.</sup> Groundwater sample analysis was limited to Appendix IV parameters detected in previous events in accordance with 40 C.F.R. § 257.95(d)(1).

## 4. PROBLEMS ENCOUNTERED AND ACTIONS TO RESOLVE THE PROBLEMS

No problems were encountered with the Groundwater Monitoring Program during 2020. Groundwater samples were collected and analyzed in accordance with the Sampling and Analysis Plan (AECOM, 2017), and all data were accepted.

#### 5. KEY ACTIVITIES PLANNED FOR 2021

The following key activities are planned for 2021:

- Continuation of the Assessment Monitoring Program with semi-annual sampling scheduled for the first and third quarters of 2021.
- Complete evaluation of analytical data from the downgradient wells, using GWPSs to determine whether an SSL of Appendix IV parameters has occurred.
- If an SSL is identified, potential alternate sources (*i.e.*, a source other than the CCR unit caused the SSL or that that SSL resulted from error in sampling, analysis, statistical evaluation, or natural variation in groundwater quality) will be evaluated. If an alternate source is demonstrated to be the cause of the SSL, a written demonstration will be completed within 90 days of SSL determination and included in the 2021 Annual Groundwater Monitoring and Corrective Action Report.
  - If an alternate source(s) is not identified to be the cause of the SSL, the applicable requirements of 40 C.F.R. §§ 257.94 through 257.98 (e.g., assessment of corrective measures) as may apply in 2021 will be met, including associated recordkeeping/notifications required by 40 C.F.R. §§ 257.105 through 257.108.

#### 6. REFERENCES

AECOM, 2017, Sampling and Analysis Plan, CCR Rule Groundwater Monitoring, Gypsum Recycle Pond, Unit 124, Zimmer Power Station, Moscow, Ohio, Job Number: 60442412, Revision 0, October 17, 2017.

Natural Resource Technology, an OBG Company (NRT/OBG), 2017, Statistical Analysis Plan, Zimmer Power Station, Dynegy Zimmer, LLC, October 17, 2017.



#### **TABLES**

TABLE 1.
ANALYTICAL RESULTS - GROUNDWATER ELEVATION AND APPENDIX III PARAMETERS 2020 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT

ZIMMER POWER STATION 124 - GYPSUM RECYCLE POND

MOSCOW, OH

Well ID	Latitude (Decimal	Longitude (Decimal	Date	Depth to Groundwater (ft)	Groundwater Elevation (ft NAVD88)	Boron, total (mg/L)	Calcium, total (mg/L)	Chloride, total (mg/L)	Fluoride, total (mg/L)	pH (field) (STD)	Sulfate, total (mg/L)	Total Dissolved Solids (mg/L)
	Degrees)	Degrees)		6020A	6020A	6020A	6020A	9251	9214	SM4500 H+B	9036	SM 2540C
			9/11/2019	53.72	458.07	3.38	159	62.8	<1	7.3	376	912
MW-7A  Downgradient	38.869036	-84.227563	4/10/2020			2.43	156	62.8	<0.15	7.2	366	876
20migradiene			9/17/2020	54.82	456.97	3.26	148	66.4	<0.15	6.9	397	974
	38.86994583		9/10/2019	52.51	459.09							
MW-8		-84.22557183	9/11/2019			<0.08	129	34	<1	6.8	59.5	508
Background		-64.2253/165	4/9/2020	41.15	470.45	<0.03	122	16	<0.15	6.8	65.2	421
			9/16/2020	53.62	457.98	0.0434	122	13.8	<0.15	7.0	67.2	473
	38.86885	-84.22711983	9/10/2019	52.97	459.21							
			9/12/2019			2.79	140	73.3	1.41	6.8	513	1100
MW-10			4/9/2020	42.44	469.74							
Downgradient			4/10/2020			4.38	108	60.5	1.92	7.3	372	845
			9/16/2020	54.85	457.33							
			9/17/2020			2.03	94.6	55	1.63	7.1	289	735
	38.868625		9/10/2019	50.06	458.81							
		-84.227203	9/12/2019			0.45	119	45.1	<1	6.9	145	590
MW-11			4/9/2020	39.66	469.21							
Downgradient	30.000023		4/10/2020			0.719	110	48.9	0.17	7.4	135	510
			9/16/2020	51.61	457.26							
			9/17/2020			0.395	85.4	31.7	0.184	7.2	107	427

Notes

40 C.F.R. = Title 40 of the Code of Federal Regulations

ft = foot/feet

mg/L = milligrams per liter

NAVD88 = North American Vertical Datum of 1988

S.U. = Standard Units

<sup>&</sup>lt; = concentration is less than the concentration shown, which corresponds to the reporting limit for the method; estimated concentrations below the reporting limit and associated qualifiers are not provided since not utilized in statistics to determine Statistically Significant Increases (SSIs) over background.</p>

<sup>4-</sup>digit numbers below parameter represent SW-846 analytical methods and alpha-numeric values that begin with SM represent Standard Methods for the Examination of Water and Wastewater.

## TABLE 2. ANALYTICAL RESULTS - APPENDIX IV PARAMETERS 2020 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT

ZIMMER POWER STATION 124 - GYPSUM RECYCLE POND MOSCOW, OH

Well ID	Date	Antimony, total 6020A	Arsenic, total 6020A	Barium, total 6020A	Beryllium, total 6020A	Cadmium, total 6020A	Chromium, total 6020A	<b>Cobalt,</b> <b>total</b> 6020A	Fluoride, total 6020A	<b>Lead,</b> <b>total</b> 6020A	<b>Lithium,</b> <b>total</b> 6020A	Mercury, total 7470A	Molybdenum, total 6020A	Radium-226 + Radium 228, 6020A	Selenium, total 6020A	Thallium, total 6020A
	9/11/2019		< 0.001	0.0458		<0.001	<0.002	0.00101	<1	<0.001	0.0124		<0.005	0.436	<0.005	
MW-7A Downgradient	4/10/2020	<0.004	<0.002	0.0371	<0.002	<0.001	<0.002	<0.002	<0.15	<0.005	<0.002	<0.0002	<0.005	0.785	0.00204	<0.002
Downgradiene	9/17/2020		<0.002	0.04		<0.001	<0.002	<0.002	<0.15	<0.005	0.0031		<0.005	0.43	0.0027	
	9/11/2019		< 0.001	0.0552	<0.001		0.00206	<0.0005	<1	<0.001	0.00754		<0.005	0.261	<0.005	
MW-8 Background	4/9/2020	<0.004	<0.002	0.046	<0.002	<0.001	<0.002	<0.002	<0.15	<0.005	0.00464	<0.0002	<0.005	0.292	<0.002	<0.002
Buckground	9/16/2020		<0.002	0.0452	<0.002	<0.001	<0.002	<0.002	<0.15	<0.005	0.00612		<0.005	0.0611	<0.002	
	9/12/2019		0.00501	0.0127		<0.001	<0.002	0.00464	1.41	<0.001	0.0144		0.0105	0.336	<0.005	
MW-10 Downgradient	4/10/2020	<0.004	0.00201	<0.02	<0.002	<0.001	<0.002	<0.002	1.92	<0.005	0.00934	<0.0002	0.00628	1.29	<0.002	<0.002
Downgradiene	9/17/2020		0.00241	<0.02		<0.001	<0.002	<0.002	1.63	<0.005	0.00856		<0.005	0.107	<0.002	
	9/12/2019		0.00109	0.0493		<0.001	<0.002	0.00136	<1	<0.001	0.00609		<0.005	0.105	<0.005	
MW-11 Downgradient	4/10/2020	<0.004	<0.002	0.0443	<0.002	<0.001	<0.002	<0.002	0.17	<0.005	<0.002	<0.0002	<0.005	0.955	<0.002	< 0.002
Downgradient	9/17/2020		<0.002	0.0329		<0.001	<0.002	<0.002	0.184	<0.005	<0.002		<0.005	1.26	<0.002	

#### Notes

40 C.F.R. = Title 40 of the Code of Federal Regulations

mg/L = milligrams per liter

NA = Not Analyzed

pCi/L = picoCuries per liter

< = concentration is less than concentration shown, which corresponds to the reporting limit for the method; estimated concentrations below the reporting limit and associated qualifiers are not provided since not utilized in statistics to determine Statistically Significant Levels (SSLs) over Groundwater Protection Standards.</p>

4-digit numbers below parameter represent SW-846 analytical methods and 3-digit numbers represent Clean Water Act analytical methods.

#### TABLE 3.

#### STATISTICAL BACKGROUND VALUES

#### 2020 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT

ZIMMER POWER STATION

124 - GYPSUM RECYCLE POND

MOSCOW, OHIO

ASSESSMENT MONITORING PROGRAM

Parameter	Statistical Background Value (UPL)				
40 C.F.R. Part 257 A	ppendix III				
Boron (mg/L)	0.09				
Calcium (mg/L)	169				
Chloride (mg/L)	42.17				
Fluoride (mg/L)	0.106				
pH (S.U.)	6.5 / 7.8				
Sulfate (mg/L)	72.7				
Total Dissolved Solids (mg/L)	578				

[O: RAB 12/26/19, C: KLT 12/26/19]

#### Notes:

40 C.F.R. = Title 40 of the Code of Federal Regulations

mg/L = milligrams per liter

S.U. = Standard Units

UPL = Upper Prediction Limit

#### TABLE 4.

#### GROUNDWATER PROTECTION STANDARDS 2020 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT

ZIMMER POWER STATION 124 - GYPSUM RECYCLE POND MOSCOW, OHIO

ASSESSMENT MONITORING PROGRAM

Parameter	Groundwater Protection Standard <sup>1</sup>								
40 C.F.R. Part 257 Appendix IV									
Antimony (mg/L)	0.006								
Arsenic (mg/L)	0.010								
Barium (mg/L)	2								
Beryllium (mg/L)	0.004								
Cadmium (mg/L)	0.005								
Chromium (mg/L)	0.10								
Cobalt (mg/L)	0.006								
Fluoride (mg/L)	4								
Lead (mg/L)	0.015								
Lithium (mg/L)	0.040								
Mercury (mg/L)	0.002								
Molybdenum (mg/L)	0.10								
Radium 226+228 (pCi/L)	5								
Selenium (mg/L)	0.05								
Thallium (mg/L)	0.002								

[O: RAB 12/26/19, C: KLT 12/26/19]

#### Notes:


40 C.F.R. = Title 40 of the Code of Federal Regulations

mg/L = milligrams per liter

pCi/L = picoCuries per liter

 $^1\mbox{Groundwater}$  Protection Standard is the higher of the Maximum Contaminant Level / Health-Based Level or background.

#### **FIGURES**



#### FIGURE 1

RAMBOLL AMERICAS ENGINEERING SOLUTIONS, INC.

RAMBOLL

MONITORING WELL LOCATION MAP ZIMMER GYPSUM RECYCLING POND **UNIT ID:124** 

2020 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT
VISTRA CCR RULE GROUNDWATER MONITORING
ZIMMER POWER STATION
MOSCOW, OHIO

CCR MONITORED UNIT

DOWNGRADIENT MONITORING WELL LOCATION