

Annual CCR Fugitive Dust Report

Big Brown SES
Solid Waste Registration (SWR) # 30080

Reporting Year: 2017

Date of Report: December 7, 2017

CCR Unit	CCR Material Managed	Dust Control Methods Used During the Reporting Year	Complaint	Date of Complaint	Summary of Corrective Measures Taken
North Bottom Ash Pond	Bottom Ash	<ul style="list-style-type: none"> • Water spray or fogging system. • Compaction • Vegetative cover • Reduced vehicle speed limits 	NONE	N/A	N/A
South Bottom Ash Pond	Bottom Ash				
Ash Disposal Area 2 Landfill	Fly Ash and Bottom Ash				

In accordance with §257.80(c), Luminant has reviewed the CCR fugitive dust control plan and prepared this annual report. Based upon this review, no changes or additional measures were determined to be necessary.

Reviewed by: Kim Mireles, Sr Director of Environmental Services
Printed Name, Title

Kim Mireles
Signature

12/7/2017
Date