

Luminant
1601 Bryan Street
Dallas, Texas 75201

**RE: HYDROLOGIC & HYDRAULIC CAPACITY REQUIREMENTS
CCR SURFACE IMPOUNDMENTS, OAK GROVE SES
ROBERTSON COUNTY, TX**

1.0 INTRODUCTION

The “Disposal of Coal Combustion Residuals (CCR) from Electric Utilities rule” (40 Code of Federal Regulations (40 CFR) Part 257), effective October 19, 2015, requires that the owner or operator of all existing non-incised CCR surface impoundments conduct a hydrologic and hydraulic (H&H) evaluation. This letter provides the H&H assessment pursuant to §257.82 for the Oak Grove Steam Electric Station’s (OGSES) CCR Surface Impoundments, identified as flue gas desulphurization (FGD) Ponds FGD-A, FGD-B, and FGD-C. As low hazard structures (pursuant to §257.73), it is required that the CCR impoundment’s inflow design control system be adequate to manage flow from a 24-hour, 100-year return period inflow design flood.

2.0 INFLOW DESIGN CONTROL SYSTEM

The CCR surface impoundments (FGD-A, FGD-B and FGD-C) are ring dikes with no additional watershed area except direct rainfall on the footprint of each facility. Additional stormwater is pumped to the CCR impoundments from a series of sump pumps throughout the plant site. The pumped stormwater can be operationally controlled and sent to any of the three impoundments as excess storage volume exists. While water can be pumped out of the ponds during a storm event, this analysis assumes that during a major storm event, the rate of non-stormwater inflow equals the rate of pump discharge and as such are neglected from this analysis.

The US Weather Bureau’s Technical Paper No. 40 (Hershfield, 1961) specifies a depth of 10.5 inches of rainfall for the 24-hour, 100-year return period. With a total surface impoundment footprint of about 38 acres, direct rainfall accumulation of 33 acre-feet occurs over all three CCR impoundments during the 100-year event. With a plant area of about 41 acres over mostly impervious surface, rainfall runoff of 35 acre-feet occurs from the plant to a series of sump pumps for subsequent pumping to the CCR impoundments. Between direct rainfall and pumping, a total of 68 acre-feet (33 + 35) of volume is sent to the three CCR surface impoundments.



Luminant operates all three surface impoundments with an operational freeboard of 2 feet. With a total footprint area of about 38 acres, the three CCR impoundments have a total surcharge volume of 75 acre-feet to be used in the event of a major storm. During the course of the 24-hour, 100-year rainfall event, the surcharge volume is used for storm storage with 7 acre-feet (75-68) of free storage remaining at its conclusion.

3.0 CONCLUSION

Based on the conditions described above, each of the three CCR surface impoundments meet the hydraulic criteria specified in §257.82. The details of this analysis per CCR impoundment are attached to this letter.

Golder appreciates the opportunity to assist Luminant with this project. If you have any questions, or require further assistance from Golder, please contact the undersigned at (281) 821-6868.

Sincerely,

GOLDER ASSOCIATES INC.



Michael Chilson, PE (GA)
Senior Civil Engineer



Jeffrey B. Fassett, PE
Senior Consultant and Associate

MTC/JBF/kc

Attachments:

Figure 1 – Site Layout
Attachment 1 - Hydrologic Evaluation

Reference

Hershfield, David M., (1961) Rainfall Frequency Atlas of the United States for Durations from 30 Minutes to 24 Hours and Return Period from 1 to 100 Years, Cooperative Studies Section, Hydrologic Services Division, US Weather Bureau Technical Paper No. 40 (TP-40).


4.0 CERTIFICATION

I hereby certify that this report has been prepared in general accordance with normally accepted civil engineering practices and in accordance with the requirements of 40 CFR 257.82.



Jeffrey B. Fassett, PE
Golder Associates Inc.
Firm Registration Number F-2578

**FIGURE 1
SITE LAYOUT**



TERTIARY DISCHARGE CANAL

SECONDARY DISCHARGE CANAL
NORMAL POOL ELEV: ~410 FT-MSL
AVERAGE AREA: ~270 AC
SURCHARGE DEPTH: ~6 FT
SURCHARGE STORAGE: ~1,600 AC-FT

MULTIPLE CULVERTS HYDRAULICALLY
CONNECT IMPOUNDMENTS

TOD: 423 FT-MSL

TOD: 416 FT-MSL

TWIN OAK RESERVOIR
NORMAL POOL: 401 FT 30,300 AC-FT
AUXILIARY SPILLWAY: 407 FT 46,300 AC-FT
SURCHARGE STORAGE: 6,000 AC-FT

UPPER SECONDARY DISCHARGE POND
NORMAL POOL ELEV: ~410 FT-MSL
AVERAGE AREA: ~80 AC
SURCHARGE DEPTH: ~13 FT
SURCHARGE STORAGE: ~1,000 AC-FT

TOD: 431.5 FT

BOT: 416 FT

FGD-B
HYDRAULIC HEAD: 15.5 FT
AVERAGE AREA: 8.1 AC
STORAGE: 125 AC-FT

TOD: 450 FT

FGD-A
HYDRAULIC HEAD: 28 FT
AVERAGE AREA: 6.8 AC
STORAGE: 190 AC-FT

BOT: 443 FT

TOD: 464 FT

BOT: 422 FT

FGD-C
HYDRAULIC HEAD: 21 FT
AVERAGE AREA: 11.8 AC
STORAGE: 248 AC-FT

WATERSHED AREA TO SUMPS


WATERSHED AREA TO
LIGNITE RUNOFF POND

Jeffrey B. Fassett
10/11/16



Professional Engineering Firm
Registration Number F-2578

IMAGE REFERENCE
Service Layer Credits: Source: Esri, DigitalGlobe, GeoEye, i-cubed, Earthstar
Geographics, CNES/Airbus DS, USDA, USGS, AEX, Getmapping, Aerogrid,
IGN, IGP, swisstopo, and the GIS User Community

CLIENT LUMINANT		
PROJECT OAK GROVE CCR SURFACE IMPOUNDMENTS HYDROLOGIC & HYDRAULIC CAPACITY		
TITLE SITE LAYOUT		
CONSULTANT	YYYY-MM-DD	2016-10-06
	DESIGNED	MTC
	PREPARED	MTC
	REVIEWED	WEG
	APPROVED	JBF
PROJECT NO. 1648164	REV. 2	FIGURE 1

PATH: G:\GIS\Luminant\1648164\Oak Grove CCR Assessment\unCG_SitePlan.mxd, PRINTED ON: 2016-10-06 AT: 11:41:50 AM

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM ANSI B

**ATTACHMENT 1
HYDROLOGIC EVALUATION**

Subject: HYDROLOGIC EVALUATION
Date: September 29 2016 **Made By:** MTC
Project No.: 1648164 **Checked By:** LDH
Project Short Title: Luminant/OG CCR Unit Assessments/TX **Reviewed By:** JBF

100-Year Rainfall Depth (P) = inches

PLANT HYDROLOGY

Plant Watershed Area (WSA) = acres
 Runoff Curve Number (CN) =
 Potential Watershed Retention (S) = inches
 Runoff Depth (Q) = inches
 Runoff Volume (RV) = acre-feet

$$S = \frac{1000}{CN} - 10$$

$$Q = \frac{(P - 0.2S)^2}{(P + 0.8S)}$$

$$RV = \frac{A \cdot Q}{12}$$

FGD CAPACITY

	FGD-A	FGD-B	FGD-C	TOTAL	
Area (ResA) =	<input type="text" value="9.4"/>	<input type="text" value="11.3"/>	<input type="text" value="17.0"/>	<input type="text" value="37.7"/>	acres
Freeboard (FB) =	<input type="text" value="2"/>	<input type="text" value="2"/>	<input type="text" value="2"/>	<input type="text" value="2"/>	feet
Surcharge Volume (SurchargeV) =	<input type="text" value="18.8"/>	<input type="text" value="22.6"/>	<input type="text" value="34.0"/>	<input type="text" value="75.4"/>	acre-feet
Direct Rainfall Volume (DirectV) =	<input type="text" value="8.2"/>	<input type="text" value="9.9"/>	<input type="text" value="14.9"/>	<input type="text" value="33.0"/>	acre-feet
Sump Inflow from Plant (SumpV) =	<input type="text" value="8.7"/>	<input type="text" value="10.5"/>	<input type="text" value="15.8"/>	<input type="text" value="35.1"/>	acre-feet
Total Storm Inflow (StormV) =	<input type="text" value="17.0"/>	<input type="text" value="20.4"/>	<input type="text" value="30.7"/>	<input type="text" value="68.0"/>	acre-feet
Excess Storage (ExV) =	<input type="text" value="1.8"/>	<input type="text" value="2.2"/>	<input type="text" value="3.3"/>	<input type="text" value="7.4"/>	acre-feet

DirectV = ResA · P / 12 Rainfall volume falling directly on the pond
 SumpV = fraction of RV Fraction of Plant Runoff Volume (RV) being pumped to a particular pond
 StormV = DirectV + SumpV Total rainfall volume entering a pond from both direct rainfall and pump inflow
 ExV = SurchargeV - StormV Remaining pond volume after all sumps are fully depleted

OTHER INFLOWS and ASSUMPTIONS

- This analysis assumes non-stormwater inflows do not exceed the capacity of the discharge pumps.
- It further assumes that the discharge pumps, during the storm event, are used to keep up with non-stormwater inflows and do not contribute to excess storage.

- After a storm passes, the stored storm surcharge would be evacuated through the discharge pump system for operational uses. No other discharge devise was assumed in this analysis.
- This analysis assumes stormwater runoff from the coal pile and landfill would be stored in the Lignite Runoff Pond and at the landfill until adequate space exists within the FGD ponds.



Professional Engineering Firm
Registration Number F-2578