

# Annual CCR Fugitive Dust Report

Sandow 5 Generating Plant  
Solid Waste Registration (SWR) # 88209

Reporting Year: 2017

Date of Report: December 7, 2017

CCR Unit	CCR Material Managed	Dust Control Methods Used During the Reporting Year	Complaint	Date of Complaint	Summary of Corrective Measures Taken
AX Landfill	Fly Ash & Bed Ash	<ul style="list-style-type: none"> <li>• Water spray or fogging system</li> <li>• Compaction</li> <li>• Vegetative cover</li> <li>• Reduced vehicle speed limits</li> <li>• Vacuum Trucks</li> </ul>	NONE	N/A	N/A

In accordance with §257.80(c), Luminant has reviewed the CCR fugitive dust control plan and prepared this annual report. Based upon this review, no changes or additional measures were determined to be necessary.

Reviewed by: Kim Mireles, Sr Director of Environmental Services  
Printed Name, Title

  
Signature

12/7/17  
Date