

Annual CCR Fugitive Dust Report  
 Sandow 5 Generating Plant  
 Solid Waste Registration (SWR) # 88209

Reporting Year: 2021

Date of Report: December 10, 2021

CCR Unit	CCR Material Managed	Dust Control Methods Used During the Reporting Year	Complaint	Date of Complaint	Summary of Corrective Measures Taken
AX Landfill	Fly Ash & Bed Ash	<ul style="list-style-type: none"> <li>• Water spray or fogging system</li> <li>• Compaction</li> <li>• Vegetative cover</li> <li>• Reduced vehicle speed limits</li> <li>• Vacuum Trucks</li> </ul>	NONE	N/A	N/A

In accordance with §257.80(c), Luminant has reviewed the CCR fugitive dust control plan and prepared this annual report. Based upon this review, no changes or additional measures were determined to be necessary.

Reviewed by: Renee Collins, Sr Director of Environmental Services  
 Printed Name, Title

  
 \_\_\_\_\_  
 Signature

12/10/2021  
 \_\_\_\_\_  
 Date