

CCR Impoundment Weekly Inspection

35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Baldwin Power Plant

Date: 6-16-21

Impoundment Name: Old East Fly Ash Pond

Time: 5:00 PM - 6:30 PM

IEPA Number: W1578510001-01

Inspector(s): MM/KE

Sky: Sunny Temp.: 87 F Precip. (last 48 hrs): 0 Pool Elev.: N/A

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
CREST	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		✓				
Settlement		✓				
Erosion Rills		✓				
Animal Burrows		✓				
Misalignment		✓				
Vegetation (greater than 12")	✓		<u>Mowing in Progress</u>			
UPSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Animal Burrows		✓				
Erosion Rills	✓		<u>NE corner ~ 100 yards 6"-18" wide, 3"-24" deep</u>			
Slope Protection / Rip Rap		✓				
Vegetation (greater than 12")	✓		<u>Mowing in Progress</u>			

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
DOWNSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs:	Date:		
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Sand Boils (indicate if flowing and color)		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Vegetation (greater than 12")	✓		<i>Mowing in Progress</i>			
SPILLWAY(S)	General Condition: <u>Good</u> / Fair / Poor		Repairs:	Date:		
Actively Flowing (provide depth)		✓				
Obstructions Present		✓				
Seepage		✓				
Sand Boils (indicate if flowing and color)		✓				
Erosion Rills		✓				

CCR Impoundment Weekly Inspection

35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Baldwin Power Plant
 Impoundment Name: East Fly Ash Pond
 IEPA Number: W1578510001-02

Date: 6-16-21
 Time: 5:00 PM - 6:30 PM
 Inspector(s): MM / KSE

Sky: Sunny Temp.: 87F Precip. (last 48 hrs): 0 Pool Elev.: N/A

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
CREST	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		✓				
Settlement		✓				
Erosion Rills		✓				
Animal Burrows		✓				
Misalignment		✓				
Vegetation (greater than 12")	✓		<u>Mowing in Progress</u>			
UPSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Slope Protection / Rip Rap		✓				
Vegetation (greater than 12")	✓		<u>Mowing in Progress</u>			

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
DOWNSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs:	Date:		
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Sand Boils (indicate if flowing and color)		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Vegetation (greater than 12")	✓		Mowing in Progress			
SPILLWAY(S)	General Condition: <u>Good</u> / Fair / Poor		Repairs:	Date:		
Actively Flowing (provide depth)		✓				
Obstructions Present		✓				
Seepage		✓				
Sand Boils (indicate if flowing and color)		✓				
Erosion Rills		✓				

CCR Impoundment Weekly Inspection

35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Baldwin Power Plant
 Impoundment Name: West Fly Ash Pond
 IEPA Number: W1578510001-03

Date: 6-16-21
 Time: 5:00 PM - 6:30 PM
 Inspector(s): MM / KSE

Sky: Sunny Temp.: 87F Precip. (last 48 hrs): 0 Pool Elev.: N/A

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
CREST	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		✓				
Settlement		✓				
Erosion Rills		✓				
Animal Burrows		✓				
Misalignment		✓				
Vegetation (greater than 12")	✓		<u>Mowing in Progress</u>			
UPSTREAM EMBANKMENT	General Condition: Good / <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Slope Protection / Rip Rap		✓				
Vegetation (greater than 12")	✓		<u>Mowing in Progress</u>			

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
DOWNSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs:	Date:		
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Sand Boils (indicate if flowing and color)		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Vegetation (greater than 12")	✓		<i>Mowing in Progress</i>			
SPILLWAY(S)	General Condition: <u>Good</u> / Fair / Poor		Repairs:	Date:		
Actively Flowing (provide depth)		✓				
Obstructions Present		✓				
Seepage		✓				
Sand Boils (indicate if flowing and color)		✓				
Erosion Rills		✓				

CCR Impoundment Weekly Inspection

35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Baldwin Power Plant
 Impoundment Name: Bottom Ash Pond
 IEPA Number: W1578510001-06

Date: 6-16-21
 Time: 5:00 PM - 6:30 PM
 Inspector(s): MM KSE

Sky: Sunny Temp.: 87F Precip. (last 48 hrs): 0 Pool Elev.: 3" Above Weir

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
CREST	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		✓				
Settlement		✓				
Erosion Rills		✓				
Animal Burrows		✓				
Misalignment		✓				
Vegetation (greater than 12")		✓				
UPSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Slope Protection / Rip Rap		✓				
Vegetation (greater than 12")		✓				

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
DOWNSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs:	Date:		
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Sand Boils (indicate if flowing and color)		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Vegetation (greater than 12")	✓		<i>Mowing in progress</i>			
SPELLWAY(S)	General Condition: Good / Fair / Poor		Repairs:	Date:		
Actively Flowing (provide depth)	✓		<i>3" above Weir</i>			
Obstructions Present		✓				
Seepage		✓				
Sand Boils (indicate if flowing and color)		✓				
Erosion Rills		✓				