

CCR Impoundment Weekly Inspection

35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Baldwin Power Plant
 Impoundment Name: Old East Fly Ash Pond
 IEPA Number: W1578510001-01

Date: 12-7-22
 Time: 1100a-230p
 Inspector(s): JJ

Sky: cloudy Temp.: 48°F Precip. (last 48 hrs): 0 Pool Elev.: _____

"YES" responses require description (size, depth, extants, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate data forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
CREST	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		<input checked="" type="checkbox"/>				
Settlement		<input checked="" type="checkbox"/>				
Erosion Rills		<input checked="" type="checkbox"/>				
Animal Burrows		<input checked="" type="checkbox"/>				
Misalignment		<input checked="" type="checkbox"/>				
Vegetation (greater than 12")		<input checked="" type="checkbox"/>				
UPSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		<input checked="" type="checkbox"/>				
Sloughing / Bulging		<input checked="" type="checkbox"/>				
Seepage		<input checked="" type="checkbox"/>				
Sink Holes		<input checked="" type="checkbox"/>				
Animal Burrows		<input checked="" type="checkbox"/>				
Erosion Rills		<input checked="" type="checkbox"/>				
Slope Protection / Rip Rap		<input checked="" type="checkbox"/>	repair on (1st) RR apron is in good condition			<input checked="" type="checkbox"/>
Vegetation (greater than 12')		<input checked="" type="checkbox"/>				

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
DOWNSTREAM EMBANKMENT	General Condition <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		<input checked="" type="checkbox"/>				
Sloughing / Bulging		<input checked="" type="checkbox"/>				
Seepage		<input checked="" type="checkbox"/>				
Sink Holes		<input checked="" type="checkbox"/>				
Sand Boils (indicate if flowing and color)		<input checked="" type="checkbox"/>				
Animal Burrows		<input checked="" type="checkbox"/>				
Erosion Rills		<input checked="" type="checkbox"/>				
Vegetation (greater than 12")		<input checked="" type="checkbox"/>				
SPILLWAY(S)	General Condition <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Actively Flowing (provide depth)		<input checked="" type="checkbox"/>				
Obstructions Present		<input checked="" type="checkbox"/>				
Seepage		<input checked="" type="checkbox"/>				
Sand Boils (indicate if flowing and color)		<input checked="" type="checkbox"/>				
Erosion Rills		<input checked="" type="checkbox"/>				

East berm, 3rd Rip rap apron from North rip rap movement, continue to monitor.

CCR Impoundment Weekly Inspection

35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Baldwin Power Plant
 Impoundment Name: East Fly Ash Pond
 IEPA Number: W1578510001-02

Date: 12-7-22
 Time: 1100a - 230p
 Inspector(s): [Signature]

Sky: cloudy Temp.: 48°F Precip. (last 48 hrs): 0 Pool Elev.: _____

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM) . Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
CREST General Condition: <u>Good</u> / Fair / Poor				Repairs:	Date:	
Cracking		<input checked="" type="checkbox"/>				
Settlement		<input checked="" type="checkbox"/>				
Erosion Rills		<input checked="" type="checkbox"/>				
Animal Burrows		<input checked="" type="checkbox"/>				
Misalignment		<input checked="" type="checkbox"/>				
Vegetation (greater than 12")		<input checked="" type="checkbox"/>				
UPSTREAM EMBANKMENT General Condition: <u>Good</u> / Fair / Poor				Repairs:	Date:	
Cracking		<input checked="" type="checkbox"/>				
Sloughing / Bulging		<input checked="" type="checkbox"/>				
Seepage		<input checked="" type="checkbox"/>				
Sink Holes		<input checked="" type="checkbox"/>				
Animal Burrows		<input checked="" type="checkbox"/>				
Erosion Rills		<input checked="" type="checkbox"/>	repair @ SE RR apron in good condition, monitoring ✓			
Slope Protection / Rip Rap		<input checked="" type="checkbox"/>	New RR aprons on North ditch running E/W working ✓			
Vegetation (greater than 12")		<input checked="" type="checkbox"/>	vegetation sparse along north ditch that runs ✓			

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
DOWNSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Sand Boils (indicate if flowing and color)		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Vegetation (greater than 12")		✓				
SPILLWAY(S)	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Actively Flowing (provide depth)		✓				
Obstructions Present		✓				
Seepage		✓				
Sand Boils (indicate if flowing and color)		✓				
Erosion Rills	✓		Rip Rap apron by creek crossing, erosion in grass area after the apron. Repair when weather permits. Minor erosion along north rip rap ditch that runs East/West from lack of good vegetation cover.			

CCR Impoundment Weekly Inspection

35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Baldwin Power Plant
 Impoundment Name: West Fly Ash Pond
 IEPA Number: W1578510001-03

Date: 12-7-22
 Time: 1100am - 230pm
 Inspector(s): [Signature]

Sky: cloudy Temp.: 48°F Precip. (last 48 hrs): ∅ Pool Elev.: _____

"YES" responses require description (size, depth, extants, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
CREST (General Condition: <u>Good</u>) Fair / Poor						
Cracking		<input checked="" type="checkbox"/>				
Settlement		<input checked="" type="checkbox"/>				
Erosion Rills		<input checked="" type="checkbox"/>				
Animal Burrows		<input checked="" type="checkbox"/>				
Misalignment		<input checked="" type="checkbox"/>				
Vegetation (greater than 12")		<input checked="" type="checkbox"/>				
UPSTREAM EMBANKMENT (General Condition: <u>Good</u>) Fair / Poor						
Cracking		<input checked="" type="checkbox"/>				
Sloughing / Bulging		<input checked="" type="checkbox"/>				
Seepage		<input checked="" type="checkbox"/>				
Sink Holes		<input checked="" type="checkbox"/>				
Animal Burrows		<input checked="" type="checkbox"/>				
Erosion Rills	<input checked="" type="checkbox"/>		South RR ditch, erosion NW corner, needs repair		<input checked="" type="checkbox"/>	
Slope Protection / Rip Rap	<input checked="" type="checkbox"/>		Repair to NE corner in fair condition, need repair		<input checked="" type="checkbox"/>	
Vegetation (greater than 12")		<input checked="" type="checkbox"/>	space vegetation along north ditch		<input checked="" type="checkbox"/>	

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
DOWNSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs:	Date:		
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Sand Boils (indicate if flowing and color)		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Vegetation (greater than 12")		✓				
SPELLWAY(S)	General Condition: <u>Good</u> / Fair / Poor		Repairs:	Date:		
Actively Flowing (provide depth)		✓				
Obstructions Present		✓				
Seepage		✓				
Sand Boils (indicate if flowing and color)		✓				
Erosion Rills	✓		North RR ditch that runs E/W on south side of ditch has erosion entire length of ditch, lack of vegetation growth. Deer runs also causing erosion.			✓

CCR Impoundment Weekly Inspection

35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Baldwin Power Plant
 Impoundment Name: Bottom Ash Pond
 IEPA Number: W1578510001-06

Date: 12-7-22
 Time: 1100am - 230pm
 Inspector(s): [Signature]

Sky: cloudy Temp.: 48°F Precip. (last 48 hrs): ∅ Pool Elev.: 6 1/2" above weir

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
CREST General Condition: <u>Good</u> / Fair / Poor Repairs: _____ Date: _____						
Cracking		<input checked="" type="checkbox"/>				
Settlement		<input checked="" type="checkbox"/>				
Erosion Rills		<input checked="" type="checkbox"/>				
Animal Burrows		<input checked="" type="checkbox"/>				
Misalignment		<input checked="" type="checkbox"/>				
Vegetation (greater than 12")		<input checked="" type="checkbox"/>				
UPSTREAM EMBANKMENT General Condition: <u>Good</u> / Fair / Poor Repairs: _____ Date: _____						
Cracking		<input checked="" type="checkbox"/>				
Sloughing / Bulging		<input checked="" type="checkbox"/>				
Seepage		<input checked="" type="checkbox"/>				
Sink Holes		<input checked="" type="checkbox"/>				
Animal Burrows		<input checked="" type="checkbox"/>				
Erosion Rills		<input checked="" type="checkbox"/>				
Slope Protection / Rip Rap		<input checked="" type="checkbox"/>				
Vegetation (greater than 12")		<input checked="" type="checkbox"/>				

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
DOWNSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs:	Date:		
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Sand Boils (indicate if flowing and color)		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Vegetation (greater than 12")		✓				
SPILLWAY(S)	General Condition: <u>Good</u> / Fair / Poor		Repairs:	Date:		
Actively Flowing (provide depth)	✓		6 1/2" above weir			
Obstructions Present		✓				
Seepage		✓				
Sand Boils (indicate if flowing and color)		✓				
Erosion Rills		✓				

CCR Impoundment Weekly Inspection

Station: Baldwin Power Plant

Date: 12-7-22

Impoundment Name: Final Pond

Time: 1100am - 230pm

IEPA Number: _____

Inspector(s): [Signature]

Sky: cloudy

Temp.: 48°F

Precip. (last 48 hrs): 0

Pool Elev.: 2" above weir

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
CREST	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		✓				
Settlement		✓				
Erosion Rills		✓				
Animal Burrows		✓				
Misalignment		✓				
Vegetation (greater than 12")		✓				
UPSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Slope Protection / Rip Rap		✓				
Vegetation (greater than 12")		✓				

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
DOWNSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
Sloughing / Bulging	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
Seepage	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
Sink Holes	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
Sand Boils (indicate if flowing and color)	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
Animal Burrows	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
Erosion Rills	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
Vegetation (greater than 12")	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
SPILLWAY(S)	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Actively Flowing (provide depth)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>2" above weir</i>			
Obstructions Present	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
Seepage	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
Sand Boils (indicate if flowing and color)	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
Erosion Rills	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

CCR Impoundment Weekly Inspection

Station: Baldwin Power Plant
 Impoundment Name: Secondary Pond
 IEPA Number: _____

Date: 12-7-22
 Time: 11:00am - 2:30pm
 Inspector(s): RA

Sky: cloudy Temp.: 48°F Precip. (last 48 hrs): Ø Pool Elev.: 20" above weir

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
CREST	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		<input checked="" type="checkbox"/>				
Settlement		<input checked="" type="checkbox"/>				
Erosion Rills		<input checked="" type="checkbox"/>				
Animal Burrows		<input checked="" type="checkbox"/>				
Misalignment		<input checked="" type="checkbox"/>				
Vegetation (greater than 12")		<input checked="" type="checkbox"/>				
UPSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		<input checked="" type="checkbox"/>				
Sloughing / Bulging		<input checked="" type="checkbox"/>				
Seepage		<input checked="" type="checkbox"/>				
Sink Holes		<input checked="" type="checkbox"/>				
Animal Burrows		<input checked="" type="checkbox"/>				
Erosion Rills		<input checked="" type="checkbox"/>				
Slope Protection / Rip Rap		<input checked="" type="checkbox"/>				
Vegetation (greater than 12")		<input checked="" type="checkbox"/>				

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
DOWNSTREAM EMBANKMENT	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Sand Boils (indicate if flowing and color)		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Vegetation (greater than 12")		✓				
SPILLWAY(S)	General Condition: <u>Good</u> / Fair / Poor		Repairs: _____ Date: _____			
Actively Flowing (provide depth)	✓		<i>20" above weir</i>			
Obstructions Present		✓				
Seepage		✓				
Sand Boils (indicate if flowing and color)		✓				
Erosion Rills		✓				