



Illinois Power Resources Generating, LLC
1500 Eastport Plaza Dr.
Collinsville, IL 62234

January 28, 2022

Illinois Environmental Protection Agency
1021 North Grand Avenue East
P.O. Box 19276
Springfield, IL 62794-9276

Re: Duck Creek Ash Pond No. 1 and No. 2 (IEPA ID: W0578010001-01, 02) Annual Consolidated Report

Dear Mr. LeCrone:

In accordance with 35 IAC § 845.550, Illinois Power Resources Generating, LLC (IPRG) is submitting the annual consolidated report for the Duck Creek Ash Pond No. 1 and No.2 (IEPA ID: W0578010001-01, 02), as enclosed.

Sincerely,

A handwritten signature in blue ink that reads 'Dianna Tickner'.

Dianna Tickner
Director Decommissioning & Demolition

Enclosures

Annual Consolidated Report
Illinois Power Resources Generating, LLC
Duck Creek Power Plant
Ash Pond No. 1 and No. 2; IEPA ID: **W0578010001-01, 02**

In accordance with 35 IAC § 845.550, Illinois Power Resources Generating, LLC (IPRG) has prepared the annual consolidated report. The report is provided in two sections as follows:

Section 1

1) Annual Inspection Report (Section 845.540(b))

Section 2

2) Annual Groundwater Monitoring and Corrective Action Report (Section 845.610(e))

Section 1

Annual Inspection Report

ANNUAL INSPECTION BY A QUALIFIED PROFESSIONAL ENGINEER

35 IAC § 845.540

(b)(1) The CCR surface impoundment must be inspected on an annual basis by a qualified professional engineer to ensure that the design, construction, operation, and maintenance of the CCR surface impoundment is consistent with recognized and generally accepted engineering standards. The inspection must, at a minimum, include:

- A) A review of available information regarding the status and condition of the CCR surface impoundment, including files available in the operating record (e.g., CCR surface impoundment design and construction information required by Sections 845.220(a)(1) and 845.230(d)(2)(A), previous structural stability assessments required under Section 845.450, the results of inspections by a qualified person, and results of previous annual inspections);
- B) A visual inspection of the CCR surface impoundment to identify signs of distress or malfunction of the CCR surface impoundment and appurtenant structures;
- C) A visual inspection of any hydraulic structures underlying the base of the CCR surface impoundment or passing through the dike of the CCR surface impoundment for structural integrity and continued safe and reliable operation;
- D) The annual hazard potential classification certification, if applicable (see Section 845.440);
- E) The annual structural stability assessment certification, if applicable (see Section 845.450);
- F) The annual safety factor assessment certification, if applicable (see Section 845.460); and
- G) The inflow design flood control system plan certification (see Section 845.510(c)).

SITE INFORMATION

Site Name / Address / Date of Inspection	Duck Creek Power Station Fulton County, Illinois 61520 10/19/2021
Operator Name / Address	Luminant Generation Company LLC 6555 Sierra Drive, Irving, TX 75039
CCR unit	Ash Pond No. 1

INSPECTION REPORT 35 IAC § 845.540

Date of Inspection 10/19/2021

(b)(1)(D) The annual hazard potential classification certification, if applicable (see Section 845.440).	Based on a review of the CCR unit's annual hazard potential classification, the unit is classified as a Class II CCR surface impoundment.
(b)(2)(A) Any changes in geometry of the structure since the previous annual inspection.	Cap and closure of Ash Pond No. 1 completed.
(b)(2)(B) The location and type of existing instrumentation and the maximum recorded readings of each instrument since the previous annual inspection	See the attached.
b)(2)(C) The approximate minimum, maximum, and present depth and elevation of the impounded water and CCR since the previous annual inspection;	See the attached.
b)(2)(D) The storage capacity of the impounding structure at the time of the inspection	Cap and closure of Ash Pond No. 1 completed.
(b)(2)(E) The approximate volume of the impounded water and CCR contained in the unit at the time of the inspection.	Approximately 2500 acre-feet of CCR material capped and closed.
(b)(2)(F) Any appearances of an actual or potential structural weakness of the CCR unit, in addition to any existing conditions that are disrupting or have the potential to disrupt the operation and safety of the CCR unit	Based on a review of the CCR unit's records and visual observation during the on-site inspection, there was no appearance of an actual or potential structural weakness of the CCR unit, nor an existing condition that is disrupting or would disrupt the operation and safety of the unit.

INSPECTION REPORT 35 IAC § 845.540

Date of Inspection 10/19/2021

(b)(2)(G) Any other changes that may have affected the stability or operation of the impounding structure since the previous annual inspection.	Based on a review of the CCR unit's records and visual observation during the on-site inspection, no other changes which may have affected the stability or operation of the CCR unit have taken place since the previous annual inspection.
(b)(1)(G) The inflow design flood control system plan certification (see Section 845.510(c))	Based on a review of the CCR unit's records, the CCR unit is designed, operated, and maintained to adequately manage the flow from the CCR impoundment and control the peak discharge from the inflow design flood.

35 IAC § 845.540 - Annual inspection by a qualified professional engineer.

I, James Knutelski, P.E., certify under penalty of law that the information submitted in this report was prepared by me or under my direct supervision and that I am a duly Registered Professional Engineer under the laws of the state of Illinois. The information submitted, is to the best of my knowledge and belief, true, accurate and complete. Based on the annual inspection, the design, construction, operation, and maintenance of the CCR Unit is consistent with recognized and generally accepted good engineering standards. Based on a review of the records for the CCR unit, the hazard potential classification was conducted in accordance with the requirements of Section 845.440 and the Safety Factor Assessment was conducted in accordance with the requirements of Section 845.460.



James Knutelski, PE

Illinois PE No. 062-054206, Expires: 11/30/2023

Date: 01/05/2022

Site Name: Duck Creek Power Station

CCR Unit: Ash Pond No. 1

35 IAC § 845.540 (b)(2)(B)		
Instrument ID #	Type	Maximum recorded reading since previous annual inspection (ft)
PZ1	Piezometer	abandoned
B5	Piezometer	abandoned

35 IAC § 845.540 (b)(2)(C)						
	Approximate Depth / Elevation					
Since previous inspection:	Elevation (ft)			Depth (ft)		
	Minimum	Present	Maximum	Minimum	Present	Maximum
Impounded Water		0			0	
CCR	622		655	52		85

ANNUAL INSPECTION BY A QUALIFIED PROFESSIONAL ENGINEER

35 IAC § 845.540

(b)(1) The CCR surface impoundment must be inspected on an annual basis by a qualified professional engineer to ensure that the design, construction, operation, and maintenance of the CCR surface impoundment is consistent with recognized and generally accepted engineering standards. The inspection must, at a minimum, include:

A) A review of available information regarding the status and condition of the CCR surface impoundment, including files available in the operating record (e.g., CCR surface impoundment design and construction information required by Sections 845.220(a)(1) and 845.230(d)(2)(A), previous structural stability assessments required under Section 845.450, the results of inspections by a qualified person, and results of previous annual inspections);

B) A visual inspection of the CCR surface impoundment to identify signs of distress or malfunction of the CCR surface impoundment and appurtenant structures;

C) A visual inspection of any hydraulic structures underlying the base of the CCR surface impoundment or passing through the dike of the CCR surface impoundment for structural integrity and continued safe and reliable operation;

D) The annual hazard potential classification certification, if applicable (see Section 845.440);

E) The annual structural stability assessment certification, if applicable (see Section 845.450);

F) The annual safety factor assessment certification, if applicable (see Section 845.460); and

G) The inflow design flood control system plan certification (see Section 845.510(c)).

SITE INFORMATION

Site Name / Address / Date of Inspection	Duck Creek Power Station Fulton County, Illinois 61520 10/19/2021
Operator Name / Address	Luminant Generation Company LLC 6555 Sierra Drive, Irving, TX 75039
CCR unit	Ash Pond No. 2

INSPECTION REPORT 35 IAC § 845.540

Date of Inspection 10/19/2021

(b)(1)(D) The annual hazard potential classification certification, if applicable (see Section 845.440).	Based on a review of the CCR unit's annual hazard potential classification, the unit is classified as a Class II CCR surface impoundment.
(b)(2)(A) Any changes in geometry of the structure since the previous annual inspection.	Cap and Closure activities substantially completed at time of inspection.
(b)(2)(B) The location and type of existing instrumentation and the maximum recorded readings of each instrument since the previous annual inspection	See the attached.
b)(2)(C) The approximate minimum, maximum, and present depth and elevation of the impounded water and CCR since the previous annual inspection;	See the attached.
b)(2)(D) The storage capacity of the impounding structure at the time of the inspection	Cap and closure substantially completed at time of inspection.
(b)(2)(E) The approximate volume of the impounded water and CCR contained in the unit at the time of the inspection.	Approximately 3750 acre-feet of CCR capped and closed.
(b)(2)(F) Any appearances of an actual or potential structural weakness of the CCR unit, in addition to any existing conditions that are disrupting or have the potential to disrupt the operation and safety of the CCR unit	Based on a review of the CCR unit's records and visual observation during the on-site inspection, there was no appearance of an actual or potential structural weakness of the CCR unit, nor an existing condition that is disrupting or would disrupt the operation and safety of the unit.

INSPECTION REPORT 35 IAC § 845.540

Date of Inspection 10/19/2021

(b)(2)(G) Any other changes that may have affected the stability or operation of the impounding structure since the previous annual inspection.	Based on a review of the CCR unit's records and visual observation during the on-site inspection, no other changes which may have affected the stability or operation of the CCR unit have taken place since the previous annual inspection.
(b)(1)(G) The inflow design flood control system plan certification (see Section 845.510(c))	Based on a review of the CCR unit's records, the CCR unit is designed, operated, and maintained to adequately manage the flow from the CCR impoundment and control the peak discharge from the inflow design flood.

35 IAC § 845.540 - Annual inspection by a qualified professional engineer.

I, James Knutelski, P.E., certify under penalty of law that the information submitted in this report was prepared by me or under my direct supervision and that I am a duly Registered Professional Engineer under the laws of the state of Illinois. The information submitted, is to the best of my knowledge and belief, true, accurate and complete. Based on the annual inspection, the design, construction, operation, and maintenance of the CCR Unit is consistent with recognized and generally accepted good engineering standards. Based on a review of the records for the CCR unit, the hazard potential classification was conducted in accordance with the requirements of Section 845.440 and the Safety Factor Assessment was conducted in accordance with the requirements of Section 845.460.



James Knutelski, PE

Illinois PE No. 062-054206, Expires: 11/30/2023

Date: 01/05/2022

Site Name: Duck Creek Power Station

CCR Unit: Ash Pond No. 2

35 IAC § 845.540 (b)(2)(B)

Instrument ID #	Type	Maximum recorded reading since previous annual inspection (ft)
OM31	Piezometer	abandoned
PZ2	Piezometer	621.5'

35 IAC § 845.540 (b)(2)(C)

Approximate Depth / Elevation						
Since previous inspection:	Elevation (ft)			Depth (ft)		
	Minimum	Present	Maximum	Minimum	Present	Maximum
Impounded Water		0			0	
CCR	628		635	58		65

Section 2

Annual Groundwater and Corrective Action Report

Prepared for
Illinois Power Resources Generating, LLC

Date
January 31, 2022

Project No.
1940100711-005

2021 ANNUAL GROUNDWATER MONITORING AND CORRECTIVE ACTION REPORT


ASH POND NO. 1 AND ASH POND NO. 2 DUCK CREEK POWER PLANT CANTON, ILLINOIS

**2021 ANNUAL GROUNDWATER MONITORING AND
CORRECTIVE ACTION REPORT
DUCK CREEK POWER PLANT ASH POND NO. 1 AND ASH
POND NO. 2**


Project name **Duck Creek Power Plant Ash Pond No. 1 and Ash Pond No. 2**
Project no. **1940100711-005**
Recipient **Illinois Power Resources Generating, LLC**
Document type **Annual Groundwater Monitoring and Corrective Action Report**
Version **FINAL**
Date **January 31, 2022**
Prepared by **Terra A. Dalton**
Checked by **Lauren Cook**
Approved by **Brian Hennings**
Description **Annual Report in Support of Part 845**

Ramboll
234 W. Florida Street
Fifth Floor
Milwaukee, WI 53204
USA

T 414-837-3607
F 414-837-3608
<https://ramboll.com>



Terra A. Dalton
Senior Scientist



Brian Hennings, PG
Senior Managing Hydrogeologist

CONTENTS

EXECUTIVE SUMMARY	3
1. Introduction	4
2. Monitoring and Corrective Action Program Status	6
3. Key Actions Completed in 2021	7
4. Problems Encountered and Actions to Resolve the Problems	9
5. Key Activities Planned for 2022	10
6. References	11

TABLES (IN TEXT)

Table A Proposed Part 845 Monitoring Well Network

FIGURES

Figure 1 Proposed 845 Groundwater Monitoring Well Network

APPENDICES

Appendix A *History of Potential Exceedances*, Duck Creek, Ash Pond No. 1 and Ash Pond No. 2, Canton, Illinois.

ACRONYMS AND ABBREVIATIONS

§	Section
35 I.A.C.	Title 35 of the Illinois Administrative Code
AP1	Ash Pond No. 1
AP2	Ash Pond No. 2
bgs	below ground surface
CCR	coal combustion residuals
DCPP	Duck Creek Power Plant
GMP	Addendum to the Groundwater Monitoring Plan
GWPS	groundwater protection standard
ID	identification
IEPA	Illinois Environmental Protection Agency
IPRG	Illinois Power Resources Generating, LLC
MS	mine spoils
NID	National Inventory of Dams
No.	number
Part 845	35 I.A.C. § 845: Standards for the Disposal of Coal Combustion Residuals in Surface Impoundments
Ramboll	Ramboll Americas Engineering Solutions, Inc.
SI	surface impoundment
SSI	statistically significant increase
UA	uppermost aquifer

EXECUTIVE SUMMARY

This report has been prepared to provide the information required by Title 35 of the Illinois Administrative Code (35 I.A.C.) Section (§) 845.610(e) (*Annual Groundwater Monitoring and Corrective Action Report*) for Ash Pond Number (No.) 1 (AP1) and Ash Pond No. 2 (AP2) located at Duck Creek Power Plant (DCPP) near Canton, Illinois.

An operating permit application for AP1 and AP2 was submitted by Illinois Power Resources Generating, LLC (IPRG) to the Illinois Environmental Protection Agency (IEPA) by October 31, 2021 in accordance with the requirements specified in 35 I.A.C. § 845.230(d), and is pending approval. AP1 is recognized by Vistra identification (ID) No. 201, IEPA ID No. W0578010001-01, and National Inventory of Dams (NID) No. IL50715. AP2 is recognized by Vistra ID No. 202, IEPA ID No. W0578010001-02, and NID No. IL50014.

An Addendum to the Groundwater Monitoring Plan (GMP; Ramboll Americas Engineering Solutions, Inc. [Ramboll], 2021a), which included a Statistical Analysis Plan, was developed and submitted as part of the operating permit application to propose a monitoring well network and monitoring program specific to AP1 and AP2 that will comply with 35 I.A.C. § 845: Standards for the Disposal of Coal Combustion Residuals in Surface Impoundments (Part 845; IEPA, 2021).

Groundwater concentrations observed from 2015 to 2021 were evaluated in the presentation of the History of Potential Exceedances (Ramboll, 2021b) included in the operating permit application, as required by 35 I.A.C. § 845.230(d). Groundwater concentrations from 2015 to 2021 that exceeded the groundwater protection standard (GWPS) set forth in 35 I.A.C. § 845.600(a) are considered potential exceedances because the methodology used to determine them is proposed in the Statistical Analysis Plan, which is pending IEPA approval. The determination of potential historical exceedances of 35 I.A.C. § 845.600(a) and a summary of potential historical exceedances of proposed GWPS are shown in **Appendix A**.

Evaluation of background groundwater quality was presented in the GMP (Ramboll, 2021a), and compliance with Part 845 will be determined after the first round of groundwater sampling following IEPA's issuance of an operating permit.

This report summarizes only the information presented in the operating permit application for AP1 and AP2, submitted to IEPA by October 31, 2021, which is pending IEPA approval.

1. INTRODUCTION

This report has been prepared by Ramboll on behalf of IPRG, to provide the information required by 35 I.A.C. § 845.610(e) for AP1 and AP2 located at DCPD near Canton, Illinois. The owner or operator of a coal combustion residuals (CCR) surface impoundment (SI) must prepare and submit to IEPA by January 31st of each year an Annual Groundwater Monitoring and Corrective Action Report for the preceding calendar year as part of the Annual Consolidated Report required by 35 I.A.C. § 845.550. The Annual Groundwater Monitoring and Corrective Action Report shall document the status of the groundwater monitoring and corrective action plan for the CCR SI, summarize key actions completed, including the status of permit applications and Agency approvals, describe any problems encountered and actions to resolve the problems, and project key activities for the upcoming year. At a minimum, the annual report must contain the following information, to the extent available:

1. A map, aerial image, or diagram showing the CCR SI and all background (or upgradient) and downgradient monitoring wells, including the well ID Nos., that are part of the groundwater monitoring program for the CCR SI, and a visual delineation of any exceedances of the GWPS.
2. Identification of any monitoring wells that were installed or decommissioned during the preceding year, along with a narrative description of why those actions were taken.
3. A potentiometric surface map for each groundwater elevation sampling event required by 35 I.A.C. § 845.650(b)(2).
4. In addition to all the monitoring data obtained under 35 I.A.C. §§ 845.600-680, a summary including the number of groundwater samples that were collected for analysis for each background and downgradient well, and the dates the samples were collected.
5. A narrative discussion of any statistically significant increases (SSIs) over background levels for the constituents listed in 35 I.A.C. § 845.600.
6. Other information required to be included in the annual report as specified in 35 I.A.C. §§ 845.600-680.
7. A section at the beginning of the annual report that provides an overview of the current status of the groundwater monitoring program and corrective action plan for the CCR SI. At a minimum, the summary must:
 - i. Specify whether groundwater monitoring data shows a SSI over background concentrations for one or more constituents listed in 35 I.A.C. § 845.600.
 - ii. Identify those constituents having a SSI over background concentrations and the names of the monitoring wells associated with the SSI(s).
 - iii. Specify whether there have been any exceedances of the GWPS for one or more constituents listed in 35 I.A.C. § 845.600.
 - iv. Identify those constituents with exceedances of the GWPS in 35 I.A.C. § 845.600 and the names of the monitoring wells associated with the exceedance.
 - v. Provide the date when the assessment of corrective measures was initiated for the CCR SI.

- vi. Provide the date when the assessment of corrective measures was completed for the CCR SI.
- vii. Specify whether a remedy was selected under 35 I.A.C. § 845.670 during the current annual reporting period, and if so, the date of remedy selection.
- viii. Specify whether remedial activities were initiated or are ongoing under 35 I.A.C. § 845.780 during the current annual reporting period.

An operating permit application for AP1 and AP2 was submitted by IPRG to IEPA by October 31, 2021 in accordance with the requirements specified in 35 I.A.C. § 845.230(d), and is pending approval. Therefore, the Part 845 groundwater monitoring program has not yet been initiated. This report summarizes the data collected for AP1 and AP2 as it was presented in the operating permit application, and includes the following:

- A map showing the CCR SI and all proposed background (or upgradient) and downgradient monitoring wells, including their identification numbers, that are part of the proposed groundwater monitoring program for the CCR SI presented in the GMP included in the operating permit application (Ramboll, 2021a).
- A summary of the History of Potential Exceedances included in the operating permit application (Ramboll, 2021b), as required by 35 I.A.C. § 845.230(d), summarizing groundwater concentrations from 2015-2021 that exceeded the proposed GWPS.
 - These are considered potential exceedances because the methodology used to determine them is proposed in the Statistical Analysis Plan (Appendix A of the GMP), which is pending IEPA approval.

2. MONITORING AND CORRECTIVE ACTION PROGRAM STATUS

The Part 845 groundwater monitoring program will commence the quarter following IEPA approval and issuance of the operating permit for AP1 and AP2.

3. KEY ACTIONS COMPLETED IN 2021

The proposed Part 845 monitoring well network is presented in **Figure 1** and summarized below in **Table A**. The proposed Part 845 monitoring well network includes wells previously installed for other programs.

Table A. Proposed Part 845 Monitoring Well Network

Well ID	Monitored Unit	Well Screen Interval (feet bgs)	Well Type ¹
BA06	UA	32.3 – 41.9	Background
OM01	MS	15.3 – 20.3	Compliance
OR02	MS	10.2 – 20.2	Compliance
OR03D	MS	66.7 – 76.7	Compliance
OM04S	MS	22.8 – 32.8	Compliance
OR04D	MS	54.8 – 64.8	Compliance
OR06A	MS	15.6 – 24.6	Compliance
OM07	MS	18.4 – 28.4	Compliance
OR11	MS	31.6 – 41.6	Compliance
OM12	MS	29.8 – 39.8	Compliance
OR13D	MS	37.3 – 47.3	Compliance
OR13S	MS	16.2 – 26.2	Compliance
OR14D	MS	36.2 – 45.2	Compliance
OM16	MS	30.4 – 40.4	Background
OM17	MS	4.2 – 14.3	Background
OR19	MS	41.7 – 51.7	Compliance
OR20	MS	44.6 – 54.6	Compliance
OM21	MS	47.2 – 57.2	Compliance
OM22D	MS	58.1 – 63.1	Compliance
OM23D	MS	70.4 – 79.4	Compliance
OM24D	MS	10.9 – 19.9	Compliance
OM25S	MS	52.0 – 61.0	Compliance

¹ Well type refers to the role of the well in the monitoring network.

bgs = below ground surface

MS = mine spoils

UA = uppermost aquifer

A summary of the samples collected from background and compliance monitoring wells during 2021 is included in **Table B** below. All analytical results obtained in 2021 are presented in the presentation of the History of Potential Exceedances (Ramboll, 2021b).

Table B. Summary of Groundwater Samples Collected

Sampling Dates	Parameters Collected ¹	Monitoring Wells Sampled ²
February 22 to March 4, 2021	Boron, Chloride, pH	OM01, OM04S, OM07, OM12, OM21, OM22D, OM23D, OM24D, OM25S, OR02, OR03D, OR04D, OR06A, OR11, OR13S, OR13D, OR14D, OR19, and OR20
May 13 - 14, 2021	Boron, Chloride, pH	OM01, OM04S, OM07, OM12, OM21, OM22D, OM23D, OM24D, OM25S, OR02, OR03D, OR04D, OR06A, OR11, OR13S, OR13D, OR14D, OR19, and OR20
August 11 - 13, 2021	Boron, Chloride, pH	OM01, OM04S, OM07, OM12, OM21, OM22D, OM23D, OM24D, OM25S, OR02, OR03D, OR04D, OR06A, OR11, OR13S, OR13D, OR14D, OR19, and OR20
November 19, 2021	Boron, Chloride, pH	OM01, OM04S, OM07, OM12, OM21, OM22D, OM23D, OM24D, OM25S, OR02, OR03D, OR04D, OR06A, OR11, OR13S, OR13D, OR14D, OR19, and OR20

¹ Boron and chloride measured as dissolved.

² In general, one sample was collected per monitoring well per event.

Evaluation of background groundwater quality will be determined following IEPA's issuance of the operating permit for AP1 and AP2.

Groundwater concentrations from 2015 to 2021 were evaluated in the presentation of the History of Potential Exceedances included in the operating permit application. Groundwater concentrations that exceeded the proposed GWPS are considered potential exceedances because the methodology used to determine them is proposed in the Statistical Analysis Plan, which is pending IEPA approval. Tables summarizing how potential historical exceedances were determined and the potential exceedances themselves are provided in **Appendix A**.

4. PROBLEMS ENCOUNTERED AND ACTIONS TO RESOLVE THE PROBLEMS

The first round of groundwater sampling for compliance with the Part 845 groundwater monitoring program will commence the quarter following IEPA approval and issuance of the operating permit for AP1 and AP2, and in accordance with the GMP.

5. KEY ACTIVITIES PLANNED FOR 2022

The following key activities are planned for 2022:

- Groundwater sampling and reporting for compliance will be initiated the quarter following issuance of the operating permit at all monitoring wells in the approved monitoring well network as presented in the GMP and required by 35 I.A.C. § 845.610(b)(3), including:
 - Monthly groundwater elevations.
 - Quarterly groundwater sampling.


6. REFERENCES

Illinois Environmental Protection Agency (IEPA), 2021. *In the Matter of: Standards for the Disposal of Coal Combustion Residuals in Surface Impoundments: Title 35 Illinois Administration Code 845, Addendum*. April 15, 2021.

Ramboll Americas Engineering Solutions, Inc. (Ramboll), 2021a. *Addendum to the Groundwater Monitoring Plan. Duck Creek Power Plant, Ash Pond No. 1 and Ash Pond No. 2, Canton, Illinois*. Illinois Power Resources Generating, LLC. October 25, 2021.

Ramboll Americas Engineering Solutions, Inc. (Ramboll), 2021b. *History of Potential Exceedances Duck Creek Power Plant, Ash Pond No. 1 and Ash Pond No. 2, Canton, Illinois*. Illinois Power Resources Generating, LLC. October 25, 2021.

FIGURES



- BACKGROUND WELL
- COMPLIANCE WELL
- PART 845 REGULATED UNIT (SUBJECT UNIT)
- PROPERTY BOUNDARY

PROPOSED PART 845 GROUNDWATER
MONITORING WELL NETWORK

FIGURE 1

APPENDIX A

HISTORY OF POTENTIAL EXCEEDANCES

HISTORY OF POTENTIAL EXCEEDANCES

This presentation of the History of Potential Exceedances, and any corrective action taken to remediate groundwater, is provided to meet the requirements of Title 35 of the Illinois Administrative Code (35 I.A.C.) § 845.230(d)(2)(M) for the Duck Creek Power Plant Ash Pond No. 1 and Ash Pond No. 2, Illinois Environmental Protection Agency (IEPA) ID Nos. W0578010001-01 and W0578010001-02.

Note

Groundwater concentrations observed from 2015 to 2021 have been evaluated and summarized in the following table and are considered potential exceedances because the methodology used to determine them is proposed in the Statistical Analysis Plan (Appendix A to Groundwater Monitoring Plan [GMP]), which has not been reviewed or approved by IEPA at the time of submittal of the 35 I.A.C. § 845 Operating Permit application.

As noted in the GMP, background concentrations will be calculated after the first eight sampling events following IEPA approval of the GMP. Consequently, for this presentation of potential exceedances, available data (total or dissolved concentrations in groundwater) have been compared to the standards in 35 I.A.C. § 845.600(a)(1). The results are considered potential exceedances because they were compared directly to the standard and did not include an evaluation of background groundwater quality or apply the statistical methodologies proposed in the GMP. Exceedances will be determined following IEPA approval of the GMP and collection of background data. Further, alternate sources for potential exceedances as allowed by 35 I.A.C. § 845.650(e) have not yet been evaluated. These will be evaluated and presented in future submittals to IEPA as appropriate.

Table 1 summarizes the potential exceedances.

Corrective Action

A Closure and Post-Closure Care Plan for Duck Creek Ash Ponds Nos. 1 and 2 (Closure Plan) was submitted to IEPA in March 2016 and approved on November 23, 2016. The Closure Plan indicated that Ash Ponds Nos. 1 and 2 would be closed in place with a final cover system of earthen material. Closure construction was completed on December 22, 2020.

TABLE 1. DETERMINATION OF POTENTIAL EXCEEDANCES

HISTORY OF POTENTIAL EXCEEDANCES
DUCK CREEK POWER PLANT
ASH POND NO. 1 AND ASH POND NO. 2
CANTON, ILLINOIS

Location	Sample Date	Boron, dissolved (mg/L)	Chloride, dissolved (mg/L)	pH (field) (SU)	Sulfate, dissolved (mg/L)	Specific Conductance (micromhos/cm)	Temperature (°F)
35 I.A.C. 845.600	Lower	0	0	6.5	0	NA	NA
	Upper	2	200	9.0	400	NA	NA
Class IV Standard		2	SEC	SEC	SEC	NA	NA
OM01	04/17/2015	0.74	22	6.6	1600	3390	56.8
OM01	09/14/2015	0.19	21	6.3	1800	1765	63
OM01	04/26/2016	1.1	31	--	600	--	--
OM01	10/25/2016	0.22	22	--	1500	--	--
OM01	04/27/2017	0.23	25	--	2000	--	--
OM01	10/20/2017	0.44	90	--	1800	--	--
OM01	01/31/2018	0.2	28	--	--	--	--
OM01	04/16/2018	0.21	23	--	--	--	--
OM01	07/23/2018	0.19	25	--	--	--	--
OM01	10/22/2018	0.21	30	--	--	--	--
OM01	01/28/2019	0.21	26	--	--	--	--
OM01	04/02/2019	0.49	46	--	--	--	--
OM01	07/05/2019	0.23	29	--	--	--	--
OM01	11/15/2019	0.21	38	--	--	--	--
OM01	01/09/2020	0.21	31	--	--	--	--
OM01	04/15/2020	0.17	27	--	--	--	--
OM01	08/13/2020	0.19	28	--	--	--	--
OM01	11/17/2020	0.94	27	6.4	--	3531	55.4
OM01	02/24/2021	0.19	31	6.6	--	3545	51.6
OM01	05/13/2021	0.33	32	7.0	--	3346	59.9
OM01	08/12/2021	0.21	31	6.3	--	3343	60.6
OM04S	04/17/2015	1.2	14	6.8	150	1171	56.5
OM04S	09/15/2015	1	13	7.0	160	880	57
OM04S	04/30/2016	0.98	<50	--	220	--	--
OM04S	10/25/2016	0.19	16	--	130	--	--
OM04S	04/28/2017	0.13	18	--	170	--	--
OM04S	10/19/2017	0.063	14	--	140	--	--
OM04S	02/02/2018	0.16	20	--	--	--	--
OM04S	04/16/2018	0.85	15	--	--	--	--
OM04S	07/24/2018	0.16	16	--	--	--	--
OM04S	10/26/2018	0.13	15	--	--	--	--
OM04S	01/28/2019	0.074	16	--	--	--	--
OM04S	04/02/2019	0.14	16	--	--	--	--
OM04S	07/02/2019	0.22	17	--	--	--	--
OM04S	11/15/2019	0.059	15	--	--	--	--
OM04S	01/09/2020	0.094	15	--	--	--	--
OM04S	04/15/2020	0.078	14	--	--	--	--
OM04S	08/13/2020	0.096	14	--	--	--	--
OM04S	11/17/2020	0.047	15	6.7	--	1225	52.7
OM04S	02/23/2021	0.077	18	6.7	--	1156	56.1
OM04S	05/14/2021	0.063	18	7.0	--	1163	61.3
OM04S	08/11/2021	52	630	6.9	--	1174	56.1
OM07	04/17/2015	1	19	7.0	280	1338	58.5
OM07	09/14/2015	0.43	13	6.9	240	957	64
OM07	04/27/2016	0.39	7.2	--	280	--	--
OM07	10/25/2016	0.37	14	--	270	--	--
OM07	04/27/2017	0.34	14	--	250	--	--
OM07	10/19/2017	0.35	11	--	230	--	--
OM07	02/02/2018	0.43	12	--	--	--	--
OM07	04/16/2018	0.69	13	--	--	--	--
OM07	07/24/2018	0.49	14	--	--	--	--
OM07	10/25/2018	0.53	11	--	--	--	--
OM07	01/28/2019	0.47	10	--	--	--	--
OM07	04/01/2019	0.87	14	--	--	--	--
OM07	07/02/2019	0.67	11	--	--	--	--
OM07	11/15/2019	0.71	11	--	--	--	--
OM07	01/10/2020	0.61	10	--	--	--	--
OM07	04/16/2020	0.47	10	--	--	--	--
OM07	08/17/2020	0.48	9	--	--	--	--
OM07	11/17/2020	0.49	11	7.0	--	1286	53.2
OM07	02/22/2021	1.2	14	7.0	--	1837	50
OM07	05/13/2021	1.2	15	7.0	--	1877	55.8
OM07	08/12/2021	1	13	7.0	--	1174	61.7
OM12	04/17/2015	0.16	6.4	6.6	480	1790	55.8
OM12	09/14/2015	0.074	5.4	6.7	400	1669	64
OM12	04/30/2016	0.15	9.9	--	470	--	--
OM12	10/31/2016	0.24	7.9	--	540	--	--
OM12	04/28/2017	0.14	<10	--	560	--	--

TABLE 1. DETERMINATION OF POTENTIAL EXCEEDANCES

HISTORY OF POTENTIAL EXCEEDANCES
DUCK CREEK POWER PLANT
ASH POND NO. 1 AND ASH POND NO. 2
CANTON, ILLINOIS

Location	Sample Date	Boron, dissolved (mg/L)	Chloride, dissolved (mg/L)	pH (field) (SU)	Sulfate, dissolved (mg/L)	Specific Conductance (micromhos/cm)	Temperature (°F)
35 I.A.C. 845.600	Lower	0	0	6.5	0	NA	NA
	Upper	2	200	9.0	400	NA	NA
Class IV Standard		2	SEC	SEC	SEC	NA	NA
OM12	10/20/2017	6.4	320	--	420	--	--
OM12	02/01/2018	8	83	--	--	--	--
OM12	04/17/2018	0.13	6.5	--	--	--	--
OM12	07/25/2018	4	20	--	--	--	--
OM12	10/25/2018	0.17	6.6	--	--	--	--
OM12	02/04/2019	3.6	41	--	--	--	--
OM12	04/09/2019	0.18	16	--	--	--	--
OM12	07/08/2019	0.086	5.9	--	--	--	--
OM12	11/14/2019	0.22	5.1	--	--	--	--
OM12	01/09/2020	0.16	6.2	--	--	--	--
OM12	04/14/2020	12	5.2	--	--	--	--
OM12	08/17/2020	0.061	3.5	--	--	--	--
OM12	11/17/2020	0.19	6.1	6.6	--	2055	52.9
OM12	02/22/2021	0.22	4	6.7	--	1923	54.7
OM12	05/13/2021	0.13	6	6.8	--	1951	55.2
OM12	08/13/2021	0.11	2.9	6.6	--	1914	55.7
OM21	04/17/2015	16	500	7.0	1300	4010	56.3
OM21	09/15/2015	15	460	6.4	1300	1758	56
OM21	04/30/2016	13	510	--	1300	--	--
OM21	10/31/2016	15	470	--	1500	--	--
OM21	04/28/2017	13	450	--	1200	--	--
OM21	10/20/2017	14	360	--	1200	--	--
OM21	02/01/2018	12	390	--	--	--	--
OM21	04/16/2018	13	460	--	--	--	--
OM21	07/25/2018	13	360	--	--	--	--
OM21	10/25/2018	16	180	--	--	--	--
OM21	01/28/2019	12	300	--	--	--	--
OM21	04/01/2019	14	660	--	--	--	--
OM21	07/02/2019	1	330	--	--	--	--
OM21	11/15/2019	10	390	--	--	--	--
OM21	01/09/2020	12	380	--	--	--	--
OM21	04/14/2020	0.064	320	--	--	--	--
OM21	08/17/2020	10	280	--	--	--	--
OM21	11/17/2020	8.3	290	6.7	--	3682	52.9
OM21	02/23/2021	9.5	310	6.6	--	3503	50
OM21	05/14/2021	11	290	6.7	--	3763	57.2
OM21	08/11/2021	11	33	6.8	--	3572	58.9
OM22D	04/17/2015	16	460	6.9	570	2580	62.2
OM22D	09/28/2015	16	480	6.9	540	1986	60
OM22D	04/26/2016	17	440	--	490	--	--
OM22D	10/31/2016	21	490	--	650	--	--
OM22D	04/27/2017	19	500	--	650	--	--
OM22D	10/20/2017	20	450	--	750	--	--
OM22D	01/31/2018	18	500	--	--	--	--
OM22D	04/17/2018	19	490	--	--	--	--
OM22D	07/23/2018	27	550	--	--	--	--
OM22D	10/22/2018	13	350	--	--	--	--
OM22D	01/28/2019	0.27	29	--	--	--	--
OM22D	04/02/2019	43	910	--	--	--	--
OM22D	07/03/2019	20	410	--	--	--	--
OM22D	11/14/2019	25	570	--	--	--	--
OM22D	01/08/2020	44	660	--	--	--	--
OM22D	04/15/2020	36	720	--	--	--	--
OM22D	08/17/2020	25	450	--	--	--	--
OM22D	11/18/2020	33	680	6.7	--	3481	53.4
OM22D	02/24/2021	50	1000	6.8	--	4461	53.4
OM22D	05/14/2021	51	1000	6.7	--	4300	63.7
OM22D	08/13/2021	48	710	5.7	--	3610	56.7
OM23D	04/17/2015	2.3	37	6.8	520	1668	63.3
OM23D	09/28/2015	22	560	6.9	720	1545	61
OM23D	04/26/2016	12	250	--	550	--	--
OM23D	10/31/2016	22	550	--	760	--	--
OM23D	04/27/2017	19	460	--	770	--	--
OM23D	10/20/2017	19	430	--	780	--	--
OM23D	01/31/2018	21	580	--	--	--	--
OM23D	04/17/2018	2.2	37	--	--	--	--
OM23D	07/23/2018	29	580	--	--	--	--
OM23D	10/22/2018	1	51	--	--	--	--

TABLE 1. DETERMINATION OF POTENTIAL EXCEEDANCES

HISTORY OF POTENTIAL EXCEEDANCES
DUCK CREEK POWER PLANT
ASH POND NO. 1 AND ASH POND NO. 2
CANTON, ILLINOIS

Location	Sample Date	Boron, dissolved (mg/L)	Chloride, dissolved (mg/L)	pH (field) (SU)	Sulfate, dissolved (mg/L)	Specific Conductance (micromhos/cm)	Temperature (°F)
35 I.A.C. 845.600	Lower	0	0	6.5	0	NA	NA
	Upper	2	200	9.0	400	NA	NA
Class IV Standard		2	SEC	SEC	SEC	NA	NA
OM23D	01/28/2019	2.2	190	--	--	--	--
OM23D	04/03/2019	1.9	27	--	--	--	--
OM23D	07/08/2019	2.6	29	--	--	--	--
OM23D	11/14/2019	2.2	32	--	--	--	--
OM23D	01/08/2020	1.9	28	--	--	--	--
OM23D	04/15/2020	2	26	--	--	--	--
OM23D	08/13/2020	2	26	--	--	--	--
OM23D	11/17/2020	2.1	30	6.9	--	1757	54.7
OM23D	02/24/2021	1.9	27	6.9	--	1786	52.5
OM23D	05/13/2021	2.1	39	6.9	--	1694	62.4
OM23D	08/13/2021	2	27	5.8	--	1697	57.6
OM24D	04/17/2015	23	540	6.7	910	3160	60.4
OM24D	09/28/2015	20	440	6.7	770	2507	61
OM24D	04/26/2016	20	450	--	870	--	--
OM24D	10/31/2016	20	520	--	1000	--	--
OM24D	04/27/2017	20	500	--	1000	--	--
OM24D	10/20/2017	20	400	--	780	--	--
OM24D	01/31/2018	39	960	--	--	--	--
OM24D	04/17/2018	28	660	--	--	--	--
OM24D	07/23/2018	29	600	--	--	--	--
OM24D	10/22/2018	29	660	--	--	--	--
OM24D	01/28/2019	12	330	--	--	--	--
OM24D	04/02/2019	24	550	--	--	--	--
OM24D	07/08/2019	25	450	--	--	--	--
OM24D	11/14/2019	27	590	--	--	--	--
OM24D	01/08/2020	26	500	--	--	--	--
OM24D	04/15/2020	19	350	--	--	--	--
OM24D	08/13/2020	19	350	--	--	--	--
OM24D	11/17/2020	20	390	6.6	--	3028	52.7
OM24D	03/04/2021	20	370	6.8	--	2897	49.6
OM24D	05/13/2021	18	340	6.9	--	2614	60.1
OM24D	08/12/2021	21	310	6.6	--	2643	60.4
OM25S	04/17/2015	19	440	6.7	750	3010	61.3
OM25S	09/28/2015	22	630	6.7	770	2281	60
OM25S	04/26/2016	20	470	--	650	--	--
OM25S	10/31/2016	25	600	--	940	--	--
OM25S	04/27/2017	23	570	--	770	--	--
OM25S	10/20/2017	17	380	--	700	--	--
OM25S	01/31/2018	29	720	--	--	--	--
OM25S	04/17/2018	23	510	--	--	--	--
OM25S	07/23/2018	25	490	--	--	--	--
OM25S	10/22/2018	2.8	140	--	--	--	--
OM25S	01/28/2019	21	490	--	--	--	--
OM25S	04/02/2019	8.2	180	--	--	--	--
OM25S	07/03/2019	21	430	--	--	--	--
OM25S	11/14/2019	18	420	--	--	--	--
OM25S	01/08/2020	23	520	--	--	--	--
OM25S	04/15/2020	24	480	--	--	--	--
OM25S	08/13/2020	27	460	--	--	--	--
OM25S	11/17/2020	23	530	6.6	--	3249	54
OM25S	02/24/2021	30	220	6.5	--	3235	53.6
OM25S	05/13/2021	41	610	6.8	--	3362	63.9
OM25S	08/12/2021	33	560	6.5	--	3228	60.3
OR02	04/17/2015	6.3	280	6.8	340	2710	53.2
OR02	09/14/2015	4.6	230	6.5	300	1289	66
OR02	04/26/2016	5	180	--	240	--	--
OR02	10/31/2016	5	220	--	270	--	--
OR02	04/27/2017	3.9	210	--	380	--	--
OR02	10/20/2017	4.7	180	--	240	--	--
OR02	02/02/2018	3.9	220	--	--	--	--
OR02	04/16/2018	3.1	43	--	--	--	--
OR02	07/23/2018	4.1	220	--	--	--	--
OR02	10/22/2018	4.5	230	--	--	--	--
OR02	01/28/2019	2.3	210	--	--	--	--
OR02	04/02/2019	2.6	250	--	--	--	--
OR02	07/05/2019	4.4	210	--	--	--	--
OR02	11/15/2019	4.2	200	--	--	--	--
OR02	01/09/2020	4	200	--	--	--	--

TABLE 1. DETERMINATION OF POTENTIAL EXCEEDANCES

HISTORY OF POTENTIAL EXCEEDANCES
DUCK CREEK POWER PLANT
ASH POND NO. 1 AND ASH POND NO. 2
CANTON, ILLINOIS

Location	Sample Date	Boron, dissolved (mg/L)	Chloride, dissolved (mg/L)	pH (field) (SU)	Sulfate, dissolved (mg/L)	Specific Conductance (micromhos/cm)	Temperature (°F)
35 I.A.C. 845.600	Lower	0	0	6.5	0	NA	NA
	Upper	2	200	9.0	400	NA	NA
Class IV Standard		2	SEC	SEC	SEC	NA	NA
OR02	04/15/2020	4	210	--	--	--	--
OR02	08/13/2020	3.9	210	--	--	--	--
OR02	11/17/2020	4.9	210	6.8	--	1942	54.5
OR02	02/24/2021	4.1	4.1	6.7	--	2009	54.5
OR02	05/13/2021	3.8	240	7.0	--	1987	57.6
OR02	08/12/2021	5.3	220	6.6	--	1884	59.4
OR03D	04/17/2015	3.1	82	6.9	390	1653	59
OR03D	09/14/2015	5	150	6.6	350	1617	63
OR03D	04/26/2016	2.5	78	--	330	--	--
OR03D	10/31/2016	2.7	79	--	390	--	--
OR03D	04/27/2017	2.5	77	--	380	--	--
OR03D	10/20/2017	2.1	88	--	420	--	--
OR03D	02/02/2018	2.1	73	--	--	--	--
OR03D	04/16/2018	2.6	67	--	--	--	--
OR03D	07/23/2018	2.6	74	--	--	--	--
OR03D	10/25/2018	2.5	65	--	--	--	--
OR03D	01/28/2019	0.47	20	--	--	--	--
OR03D	04/03/2019	2	65	--	--	--	--
OR03D	07/05/2019	5.9	230	--	--	--	--
OR03D	11/15/2019	5.9	240	--	--	--	--
OR03D	01/10/2020	14	560	--	--	--	--
OR03D	04/14/2020	34	890	--	--	--	--
OR03D	08/13/2020	28	660	--	--	--	--
OR03D	11/17/2020	27	600	6.6	--	2915	49.1
OR03D	02/25/2021	49	1100	6.5	--	4745	54.5
OR03D	05/14/2021	45	1200	6.8	--	4855	64.4
OR03D	08/13/2021	48	1100	6.6	--	4541	58.5
OR04D	04/17/2015	18	210	8.7	610	1474	57
OR04D	09/15/2015	11	130	6.4	690	1280	56
OR04D	04/30/2016	9.6	250	--	1400	--	--
OR04D	10/25/2016	8.6	100	--	540	--	--
OR04D	04/28/2017	7.5	98	--	460	--	--
OR04D	10/19/2017	5.6	76	--	400	--	--
OR04D	02/02/2018	7.6	86	--	--	--	--
OR04D	04/16/2018	11	120	--	--	--	--
OR04D	07/24/2018	7.2	72	--	--	--	--
OR04D	10/26/2018	9.5	99	--	--	--	--
OR04D	01/28/2019	26	310	--	--	--	--
OR04D	04/02/2019	36	500	--	--	--	--
OR04D	07/02/2019	50	330	--	--	--	--
OR04D	11/15/2019	54	670	--	--	--	--
OR04D	01/09/2020	47	560	--	--	--	--
OR04D	04/15/2020	30	360	--	--	--	--
OR04D	08/13/2020	44	490	--	--	--	--
OR04D	11/17/2020	87	840	6.6	--	4647	54.9
OR04D	02/25/2021	88	990	6.8	--	5114	56.1
OR04D	05/14/2021	44	620	7.0	--	3876	63.7
OR04D	08/11/2021	0.089	16	6.8	--	4215	58
OR06A	04/17/2015	1.5	32	6.8	380	1488	60.8
OR06A	09/14/2015	1.4	31	6.8	320	900	65
OR06A	04/27/2016	1.1	31	--	340	--	--
OR06A	10/25/2016	1.3	32	--	320	--	--
OR06A	04/27/2017	1.2	33	--	310	--	--
OR06A	10/19/2017	1.1	31	--	270	--	--
OR06A	02/02/2018	1.2	35	--	--	--	--
OR06A	04/17/2018	1	33	--	--	--	--
OR06A	07/24/2018	1.3	34	--	--	--	--
OR06A	10/25/2018	1.3	34	--	--	--	--
OR06A	01/28/2019	0.72	16	--	--	--	--
OR06A	04/09/2019	0.74	15	--	--	--	--
OR06A	07/03/2019	0.64	15	--	--	--	--
OR06A	11/15/2019	1.6	33	--	--	--	--
OR06A	01/10/2020	0.72	15	--	--	--	--
OR06A	04/16/2020	0.55	12	--	--	--	--
OR06A	03/04/2021	0.82	30	6.8	--	1524	54.1
OR06A	05/14/2021	0.98	65	7.2	--	1555	62.1
OR06A	08/12/2021	17	210	6.7	--	1919	62.2
OR11	04/17/2015	4.1	27	7.2	140	880	62.2

TABLE 1. DETERMINATION OF POTENTIAL EXCEEDANCES

HISTORY OF POTENTIAL EXCEEDANCES
DUCK CREEK POWER PLANT
ASH POND NO. 1 AND ASH POND NO. 2
CANTON, ILLINOIS

Location	Sample Date	Boron, dissolved (mg/L)	Chloride, dissolved (mg/L)	pH (field) (SU)	Sulfate, dissolved (mg/L)	Specific Conductance (micromhos/cm)	Temperature (°F)
35 I.A.C. 845.600	Lower	0	0	6.5	0	NA	NA
	Upper	2	200	9.0	400	NA	NA
Class IV Standard		2	SEC	SEC	SEC	NA	NA
OR11	09/14/2015	5.8	46	7.1	140	916	62
OR11	04/30/2016	3.4	27	--	140	--	--
OR11	10/31/2016	3.9	30	--	200	--	--
OR11	04/28/2017	4	26	--	160	--	--
OR11	10/20/2017	0.19	17	--	360	--	--
OR11	02/01/2018	0.34	6	--	--	--	--
OR11	04/17/2018	5.6	53	--	--	--	--
OR11	07/25/2018	0.087	5.5	--	--	--	--
OR11	10/25/2018	5.8	39	--	--	--	--
OR11	02/04/2019	0.12	57	--	--	--	--
OR11	04/09/2019	2.8	13	--	--	--	--
OR11	07/05/2019	5.4	28	--	--	--	--
OR11	11/14/2019	6.3	48	--	--	--	--
OR11	01/09/2020	7.6	44	--	--	--	--
OR11	04/14/2020	4.7	33	--	--	--	--
OR11	08/17/2020	6.6	39	--	--	--	--
OR11	11/17/2020	7.3	59	7.1	--	1132	53.2
OR11	02/22/2021	8.4	74	7.1	--	1147	50.7
OR11	05/14/2021	5.1	58	7.1	--	793	55.6
OR11	08/12/2021	6.3	39	7.2	--	916	58.3
OR13S	04/17/2015	4.6	120	7.0	290	1778	60.3
OR13S	09/14/2015	9	170	7.0	290	1800	62
OR13S	04/27/2016	3.6	120	--	270	--	--
OR13S	10/25/2016	3.9	110	--	260	--	--
OR13S	04/28/2017	4	130	--	320	--	--
OR13S	10/19/2017	3.5	110	--	250	--	--
OR13S	02/01/2018	3.9	120	--	--	--	--
OR13S	04/17/2018	3.4	91	--	--	--	--
OR13S	07/24/2018	2.4	40	--	--	--	--
OR13S	10/25/2018	2.4	110	--	--	--	--
OR13S	01/28/2019	4.1	110	--	--	--	--
OR13S	04/01/2019	3.7	89	--	--	--	--
OR13S	07/02/2019	4.1	120	--	--	--	--
OR13S	11/15/2019	4.4	140	--	--	--	--
OR13S	01/10/2020	4.5	140	--	--	--	--
OR13S	04/15/2020	4	130	--	--	--	--
OR13S	08/17/2020	3.7	140	--	--	--	--
OR13S	11/17/2020	3.9	140	6.9	--	2024	54.9
OR13S	02/23/2021	4.1	150	6.8	--	2113	54
OR13S	05/14/2021	4.5	140	6.9	--	2358	54.7
OR13S	08/11/2021	4.2	130	7.0	--	2032	58
OR13D	04/17/2015	3	41	7.3	330	1597	59
OR13D	09/14/2015	2.3	34	7.3	290	1460	63
OR13D	04/27/2016	3.2	48	--	330	--	--
OR13D	10/25/2016	2.5	37	--	330	--	--
OR13D	04/28/2017	2.4	37	--	310	--	--
OR13D	10/19/2017	1.9	32	--	300	--	--
OR13D	02/01/2018	2.3	40	--	--	--	--
OR13D	04/17/2018	2	35	--	--	--	--
OR13D	07/24/2018	3.8	99	--	--	--	--
OR13D	10/25/2018	4.4	36	--	--	--	--
OR13D	01/28/2019	2.1	35	--	--	--	--
OR13D	04/01/2019	2.2	42	--	--	--	--
OR13D	07/02/2019	2.3	34	--	--	--	--
OR13D	11/15/2019	2.3	39	--	--	--	--
OR13D	01/10/2020	2.1	43	--	--	--	--
OR13D	04/16/2020	2	37	--	--	--	--
OR13D	08/17/2020	1.9	38	--	--	--	--
OR13D	11/17/2020	1.8	40	7.0	--	1882	54.1
OR13D	02/23/2021	1.9	45	6.9	--	1878	54.5
OR13D	05/13/2021	2	63	7.0	--	1896	59.3
OR13D	08/11/2021	2	40	7.1	--	1907	58.4
OR14D	04/17/2015	7.1	<100	7.3	690	1631	57.4
OR14D	09/15/2015	6.3	92	6.6	650	1237	60
OR14D	04/27/2016	5.9	100	--	690	--	--
OR14D	10/25/2016	5.6	61	--	920	--	--
OR14D	04/28/2017	5.3	89	--	570	--	--
OR14D	10/20/2017	4.6	79	--	680	--	--

TABLE 1. DETERMINATION OF POTENTIAL EXCEEDANCES

HISTORY OF POTENTIAL EXCEEDANCES
DUCK CREEK POWER PLANT
ASH POND NO. 1 AND ASH POND NO. 2
CANTON, ILLINOIS

Location	Sample Date	Boron, dissolved (mg/L)	Chloride, dissolved (mg/L)	pH (field) (SU)	Sulfate, dissolved (mg/L)	Specific Conductance (micromhos/cm)	Temperature (°F)
35 I.A.C. 845.600	Lower	0	0	6.5	0	NA	NA
	Upper	2	200	9.0	400	NA	NA
Class IV Standard		2	SEC	SEC	SEC	NA	NA
OR14D	02/01/2018	5.3	92	--	--	--	--
OR14D	04/16/2018	4.7	88	--	--	--	--
OR14D	07/25/2018	5.4	90	--	--	--	--
OR14D	10/26/2018	4.1	72	--	--	--	--
OR14D	01/28/2019	5.7	63	--	--	--	--
OR14D	04/01/2019	5.9	70	--	--	--	--
OR14D	07/02/2019	6.2	68	--	--	--	--
OR14D	11/15/2019	4.2	36	--	--	--	--
OR14D	01/10/2020	4.2	40	--	--	--	--
OR14D	04/16/2020	3.9	37	--	--	--	--
OR14D	08/17/2020	3.2	38	--	--	--	--
OR14D	11/17/2020	3.3	34	6.9	--	1918	54.9
OR14D	02/23/2021	21	550	6.7	--	3425	61.2
OR14D	05/14/2021	17	420	6.8	--	3115	59.1
OR14D	08/12/2021	18	290	6.6	--	2648	60.1
OR19	04/17/2015	20	240	6.8	990	2870	63.1
OR19	09/14/2015	14	130	6.7	730	1939	63
OR19	04/30/2016	12	150	--	750	--	--
OR19	10/31/2016	14	150	--	990	--	--
OR19	04/28/2017	15	170	--	740	--	--
OR19	10/20/2017	13	290	--	840	--	--
OR19	02/01/2018	13	170	--	--	--	--
OR19	04/17/2018	13	140	--	--	--	--
OR19	07/25/2018	15	140	--	--	--	--
OR19	10/26/2018	11	340	--	--	--	--
OR19	02/04/2019	19	260	--	--	--	--
OR19	04/09/2019	15	160	--	--	--	--
OR19	07/08/2019	13	100	--	--	--	--
OR19	11/14/2019	13	160	--	--	--	--
OR19	01/09/2020	15	170	--	--	--	--
OR19	04/14/2020	12	130	--	--	--	--
OR19	08/17/2020	13	120	--	--	--	--
OR19	11/17/2020	13	140	6.6	--	2659	52.9
OR19	02/22/2021	19	200	6.8	--	2845	54
OR19	05/13/2021	14	180	6.8	--	2605	61.1
OR19	08/12/2021	16	140	6.7	--	2551	56.4
OR20	04/17/2015	74	740	6.9	620	3520	60.1
OR20	09/14/2015	65	730	6.9	550	2231	63
OR20	04/30/2016	55	760	--	570	--	--
OR20	10/31/2016	36	770	--	720	--	--
OR20	04/28/2017	76	780	--	570	--	--
OR20	10/20/2017	66	640	--	490	--	--
OR20	02/01/2018	72	910	--	--	--	--
OR20	04/17/2018	86	790	--	--	--	--
OR20	07/25/2018	57	590	--	--	--	--
OR20	10/25/2018	70	590	--	--	--	--
OR20	02/04/2019	57	95	--	--	--	--
OR20	04/09/2019	56	620	--	--	--	--
OR20	07/05/2019	65	590	--	--	--	--
OR20	11/14/2019	51	550	--	--	--	--
OR20	01/09/2020	56	560	--	--	--	--
OR20	04/14/2020	47	550	--	--	--	--
OR20	08/17/2020	46	530	--	--	--	--
OR20	11/17/2020	38	480	6.9	--	2943	54.1
OR20	02/22/2021	42	530	6.9	--	2978	52.3
OR20	05/14/2021	40	460	7.0	--	2795	58.3
OR20	08/12/2021	46	440	7.0	--	2737	56.5

TABLE 1. DETERMINATION OF POTENTIAL EXCEEDANCES

HISTORY OF POTENTIAL EXCEEDANCES
DUCK CREEK POWER PLANT
ASH POND NO. 1 AND ASH POND NO. 2
CANTON, ILLINOIS

Location	Sample Date	Boron, dissolved (mg/L)	Chloride, dissolved (mg/L)	pH (field) (SU)	Sulfate, dissolved (mg/L)	Specific Conductance (micromhos/cm)	Temperature (°F)
35 I.A.C. 845.600	Lower	0	0	6.5	0	NA	NA
	Upper	2	200	9.0	400	NA	NA
Class IV Standard		2	SEC	SEC	SEC	NA	NA

Notes:

1. AP1 and AP2 are located within a previously mined area and monitoring has demonstrated that the groundwater is not capable of consistently meeting the standards for Class I - Potable Resource Groundwater (35 I.A.C. § 620.410) or Class II - General Resource Groundwater (35 I.A.C. § 620.420). Therefore, the applicable classification of groundwater at AP1 and AP2 is Class IV - Other Groundwater (35 I.A.C. § 620.420(g))

2. Potential Exceedances presented on this table were determined by comparing dissolved or total concentration results directly to 35 I.A.C. § 845.600 Groundwater Protection Standards (GWPS). The results are considered potential exceedances because concentrations were compared directly to the standard, background data are not available which did not allow for the application of statistical methodologies in accordance with 35 I.A.C 845.640, and potential alternative sources have not been presented. Following Illinois Environmental Protection Agency approval, exceedances will be determined in accordance with the Addendum to the Groundwater Monitoring Plan Ash Pond No. 1 and Ash Pond No. 2 (Ramboll, 2021) included in the Operating Permit to which this history of potential exceedances is attached.

Detected at concentration greater than the GWPS and applicable Class IV Standard.

Detected at concentration greater than the 845.600 GWPS

-- = data not available

< = concentration is less than the concentration shown, which corresponds to the reporting limit for the method.

Estimated concentrations below the reporting limit and associated qualifiers are not provided since they are not utilized in statistics to determine exceedances above Part 845 standards.

°F = degrees Fahrenheit

35 I.A.C. 845.600 = Residuals in Surface Impoundments: Title 35 of the Illinois Administrative Code § 845

Class IV Standard = Groundwater Quality: Title 35 of the Illinois Administrative Code § 620.440

cm = centimeter

mg/L = milligrams per liter

NA = no standard applicable

SEC = Standard is the existing concentrations

SU = standard units