## **CCR Impoundment Weekly Inspection** 35 ILL. ADM. Code 845 / 40 CFR Part 257

Station:	Edwards		Date:	12/29/2021	
Impoundment Name:	Ash Pond		Time:	10:00 AM	
IEPA Number:	W1438050005-01		Inspector(s):	Rick Kelley	
Mostly  Chercast Temp.:	30°F P	recip. (last 48 hrs):	0.29 "		447.41

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM		NO	DESCRIPTION		ACTION			
					INVESTIGATE	SENT TO DSM		
CREST General Cond	litio (:	Good	/ Fair / Poor Repairs: Date:					
Cracking		V						
Settlement		V						
Erosion Rills		V						
Animal Burrows		V						
Misalignment		V						
Vegetation (greater than 12")		V						
UPSTREAM EMBANKMENT General Cond	litiop.	Good	Fair / Poor Repairs: Date:					
Cracking		~						
Sloughing / Bulging		V						
Seepage		V						
Sink Holes			,					
Animal Burrows		~						
Erosion Rills								
Slope Protection / Rip Rap		V						
Vegetation (greater than 12")		V						
DOWNSTREAM EMBANKMENT General Cond	lition	Good	PFair / Poor Repairs: Date:		13:11			
Cracking		V						
Sloughing / Bulging								
Seepage								
Sink Holes		1						
Sand Boils (indicate if flowing and color)		V						
Animal Burrows		V						
Erosion Rills		V						
Vegetation (greater than 12")								
SPILLWAY(S) General Cond	lition:	Good	Pair / Poor Repairs: Date:	Win X				
Actively Flowing (provide depth)	V		≈ 1.5"					
Obstructions Present			Beaver brush File - Current river level is high					
Seepage			Beaver brush File - Current river level is high  (Not visible at this time)					
Sand Boils (indicate if flowing and color)		V						
Erosion Rills								