CCR Impoundment Weekly Inspection 35 ILL. ADM. Code 845 / 40 CFR Part 257

Station:	Edwards			C	Date: 4/20/20	22		
Impoundment Name:	Ash Pond	l		Т	ime: 12:300	-	•	
IEPA Number: W143805		5-01	•	Inspecto	or(s): Pick k	0110.		
Sky: Heavy Temp.:	47°F	_ F	recip. (last 48 hrs):).16"		l Elev.:	44	7.4
"YES" responses require description at the time of inspection. If "ACTION additional sheets as necessary. Circle	N" selected is "INVE	STIGA	E", please indicate date forwa	ON" section. "No	O" response indicates no to Dam Safety Manager	o issues o	were ol Attach	bserved
77						ACTION		
ITEM		NO	DE	ESCRIPTION		MONITOR	INVESTIGATE	SENT TO DSM
CREST	General Condition	: Good	/ Fair / Poor Repa	airs:	Date:		la de	
Cracking		V					asstr	
Settlement								
Erosion Rills								
Animal Burrows								
Misalignment		1						
Vegetation (greater than 12")								
UPSTREAM EMBANKMENT	General Condition	G 000	Fair / Poor Repa	iirs:	Date:			
Cracking								
Sloughing / Bulging								
Seepage								
Sink Holes								
Animal Burrows							i	
Erosion Rills								
Slope Protection / Rip Rap								
Vegetation (greater than 12")								
DOWNSTREAM EMBANKMENT	General Condition	: Good	Fair / Poor Repa	irs:	Date:			
Cracking		/						
Sloughing / Bulging								
Seepage								
Sink Holes								
Sand Boils (indicate if flowing and color)		/						
Animal Burrows								
Erosion Rills		1	·					
Vegetation (greater than 12")								
SPILLWAY(S)	General Condition	Good	Fair / Poor Repa	irs:	Date:			
Actively Flowing (provide dep	oth) X		F 1.5-2.0"					
Obstructions Present		1	,					
Cooper								

Sand Boils (indicate if flowing and color)

Erosion Rills