CCR Impoundment Weekly Inspection 35 ILL. ADM. Code 845 / 40 CFR Part 257

 Station:
 Edwards
 Date:
 9/28/22

 Impoundment Name:
 Ash Pond
 Time:
 9:45 Am

 IEPA Number:
 W1438050005-01
 Inspector(s):
 RICK Keller

Sky: <u>Clear</u> Temp.: <u>51°F</u> Precip. (last 48 hrs): <u>0.0"</u> Pool Elev.: <u>447.3</u>

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

additional sneets as necessary. Circle General Con		10. 68					ACTIO	N
ITEM		NO	DESCRIPTION			MONITOR	INVESTIGATE	SENT TO DSM
CREST General Con-	ditio y :	Good	Fair / Poor	Repairs:	Date:			Biro
Cracking		V						
Settlement		V						
Erosion Rills		V						
Animal Burrows		V	,					
Misalignment		V	/					
Vegetation (greater than 12")		V						
UPSTREAM EMBANKMENT General Con-	dition:	6600	Fair / Poor	Repairs:	Date:			
Cracking		V						
Sloughing / Bulging		V						
Seepage								
Sink Holes		V	,					
Animal Burrows		V	,					
Erosion Rills		N				†		
Slope Protection / Rip Rap			-			†		
Vegetation (greater than 12")		V						
DOWNSTREAM EMBANKMENT General Cond	dition	900d	Fair / Poor	Repairs:	Date:			
Cracking		V			1/2/2			
Sloughing / Bulging		V	,	· · · · · · · · · · · · · · · · · · ·				
Seepage					· · · · · · · · · · · · · · · · · · ·			
Sink Holes		/				1		
Sand Boils (indicate if flowing and color)					· · · · · · · · · · · · · · · · · · ·			
Animal Burrows		V						
Erosion Rills		V						
Vegetation (greater than 12")								\vdash
SPILLWAY(S) General Cond	dition:	Sood	Fair / Poor	Repairs:	Date:			
Actively Flowing (provide depth)			The state of the s	11				
Obstructions Present								
Seepage		V						
Sand Boils (indicate if flowing and color)			,					\vdash
Erosion Rills		/				\vdash		
PERIMTER FENCING/GATES General Conc	dition	1000	/ Fair / Poor	Repairs:	Date:			
Evidence of damage or tampering		N					-	
Evidence of unauthorized access								\vdash
Gates closed and locked								