CCR Impoundment Weekly Inspection
35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Edwards
Impoundment Name: Ash Pond
IEPA Number: W1438050005-01

Date: 5/10/23
Time: 0920
Inspector(s): M. Davis

Sky: Sun   **Temp.:** 66°   **Precip. (last 48 hrs):** ~~1'~~   **Pool Elev.:** 437.1'

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION		MONITOR	INVESTIGATE	SENT TO DSM
CREST General Condition: (Good) / Fair / Poor			Repairs:	Date:			
Cracking		✓					
Settlement		✓					
Erosion Rills		✓					
Animal Burrows		✓					
Misalignment		✓					
Vegetation (greater than 12")		✓	Mowing expected this week				
UPSTREAM EMBANKMENT General Condition: (Good) / Fair / Poor			Repairs:	Date:			
Cracking		✓					
Sloughing / Bulging		✓					
Seepage		✓					
Sink Holes		✓					
Animal Burrows		✓					
Erosion Rills		✓					
Slope Protection / Rip Rap		✓					
Vegetation (greater than 12")		✓					
DOWNSTREAM EMBANKMENT General Condition: (Good) / Fair / Poor			Repairs:	Date:			
Cracking		✓					
Sloughing / Bulging		✓					
Seepage		✓					
Sink Holes		✓					
Sand Boils (indicate if flowing and color)		✓					
Animal Burrows		✓					
Erosion Rills		✓					
Vegetation (greater than 12")		✓					
SPILLWAY(S) General Condition: (Good) / Fair / Poor			Repairs:	Date:			
Actively Flowing (provide depth)	✓		little flow - due to recent rain				
Obstructions Present		✓					
Seepage	✓		small amount of seepage in Discharge pipe				
Sand Boils (indicate if flowing and color)		✓					
Erosion Rills		✓					
PERIMTER FENCING/GATES General Condition: (Good) / Fair / Poor			Repairs:	Date:			
Evidence of damage or tampering		✓					
Evidence of unauthorized access	✓	✓					
Gates closed and locked	✓						

Revised 09-13-22