CCR Impoundment Weekly Inspection 35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Edwards

Impoundment Name: Ash Pond

IEPA Number: W1438050005-01

Date: 6 - 5 - 24

Time: 0 740

Inspector(s): M. Davi S

Sky: Cloudy Temp.: 66 Precip. (last 48 hrs): 59" Pool Elev.: 439.3'

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM						ACTION		
		NO	DESCRIPTION		MONITOR	INVESTIGATE	SENT TO	
CREST General (Condition:	600d	Fair / Poor Repairs: Date				n va	
Cracking		~						
Settlement		~						
Erosion Rills		~						
Animal Burrows		~						
Misalignment			600000 - C - 7500000000000000000000000000000000000					
Vegetation (greater than 12")		V						
UPSTREAM EMBANKMENT General G	Condition:	6000	Fair / Poor Repairs: Date					
Cracking		レ						
Sloughing / Bulging		V						
Seepage		~						
Sink Holes		V						
Animal Burrows		V						
Erosion Rills		_						
Slope Protection / Rip Rap		L						
Vegetation (greater than 12")		L						
DOWNSTREAM EMBANKMENT General	Condition:	6000	Fair / Poor Repairs: Date	2:				
Cracking		~						
Sloughing / Bulging		V						
Seepage		1						
Sink Holes		~						
Sand Boils (indicate if flowing and color)	V						
Animal Burrows		V						
Erosion Rills	V	<u> </u>	mall amount of erosion bottom o	levee		,		
Vegetation (greater than 12")		-						
SPILLWAY(S) General	Condition:	Good	Fair / Poor Repairs: Date	:				
Actively Flowing (provide depth)	V		~ 1/2" water I lowing over 1/2 +	he disch	mae			
Obstructions Present		~	0		0			
Seepage		r						
Sand Boils (indicate if flowing and color)	2					\top	
Erosion Rills		V						
PERIMTER FENCING/GATES General	Condition:	6 00d	Fair / Poor Repairs: Date	2:		AT.		
Evidence of damage or tampering	-	1 .	South gods on River level will be	replaced				
Evidence of unauthorized access		1	The state of the s	THINK				
Gates closed and locked								