CCR Impoundment Weekly Inspection 35 ILL. ADM. Code 845 / 40 CFR Part 257

Station:	Edwards	Date: 8-28-24
Impoundment Name:	Ash Pond	Time: 1330
IEPA Number:	W1438050005-01	Inspector(s): M. Davis

Sky: Ptly Chy	Temp.: 76°	Precip. (last 48 hrs):	.70"	Pool Elev.: 429.7
---------------	------------	------------------------	------	-------------------

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

additional sheets as necessary. Circle General Conc		YES					A	CTIO	N
			NO	DESCRIPTION			MONITOR	INVESTIGATE	SENT TO
CREST	General Condit	tion:	Good	/ Fair / Poor	Repairs:	Date:			
Cracking			V						
Settlement									
Erosion Rills			~						
Animal Burrows			~	Verce stay (Fig.					
Misalignment			/						
Vegetation (greater than 12")		V						
UPSTREAM EMBANKMENT	General Condit	tion:(Good	/ Fair / Poor	Repairs:	Date:			
Cracking			V		1/40-0-0-				
Sloughing / Bulging			-	76					
Seepage			~						
Sink Holes			-						
Animal Burrows			~	N .					
Erosion Rills			~			10000			
Slope Protection / Rip Rap			~			***************************************			
Vegetation (greater than 12"	')		-		75 - 75 - 75 - 75 - 75				
DOWNSTREAM EMBANKMENT	General Condi	tion:	600	/ Fair / Poor	Repairs:	Date:			
Cracking				4					
Sloughing / Bulging			-					-	
Seepage			4	14	288-10-11111-11	1175			
Sink Holes			~						
Sand Boils (indicate if flowing and color)			V						
Animal Burrows			V		NI	-0 -000			
Erosion Rills			V						
Vegetation (greater than 12")									
SPILLWAY(S)	General Condi	tion:	6000	/ Fair / Poor	Repairs:	Date:			
Actively Flowing (provide d	epth)	V		Barely Flo	ruina over top	of discharge-	< 1/0		
Obstructions Present			~)	0	0	12		
Seepage		/		small se	eper inside	discharge			
Sand Boils (indicate if flowing and color)			~			0			
Erosion Rills			L						
PERIMTER FENCING/GATES General Cond		tion:	6000	/ Fair / Poor	Repairs:	Date:			
Evidence of damage or tampering			V				-0		
Evidence of unauthorized access			1		Manager State Stat	CONTRACTOR NO.			
Gates closed and locked		1							

N. Fond water level - 449.3' S. Pond water level - 447.6

Revised 09-13-22