CCR Impoundment Weekly Inspection 35 ILL. ADM. Code 845 / 40 CFR Part 257

 Station:
 Edwards
 Date:
 10 - 23 - 24

 Impoundment Name:
 Ash Pond
 Time:
 12:30

 IEPA Number:
 W1438050005-01
 Inspector(s):
 M. Davi S

Sky: Loudy Temp.: 55° Precip. (last 48 hrs): Trace Pool Elev.: 429.9

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM		NO	DESCRIPTION			ACTION		
						MONITOR	INVESTIGATE	SENT TO
CREST	General Condition:	6 00d	Y Fair / Poor	Repairs:	Date:			
Cracking		V						
Settlement		1						
Erosion Rills		~						
Animal Burrows		~						
Misalignment		1						
Vegetation (greater than 12")		V						
UPSTREAM EMBANKMENT		Good	Fair / Poor	Repairs:	Date:			
Cracking		V						
Sloughing / Bulging		1						
Seepage								
Sink Holes		V						
Animal Burrows		1			-20			
Erosion Rills		V						
Slope Protection / Rip Rap		V						
Vegetation (greater than 12")		V						
DOWNSTREAM EMBANKMENT		Good	Fair / Poor	Repairs:	Date:			
Cracking		V		The most list				
Sloughing / Bulging		V						
Seepage		V						
Sink Holes		V						
Sand Boils (indicate if flowing and color)		V						
Animal Burrows		V			14.04			
Erosion Rills		1						
Vegetation (greater than 12")		V						
SPILLWAY(S)	General Condition:	Good	Fair / Poor	Repairs:	Date:			
Actively Flowing (provide de		V		w level is				
Obstructions Present		V	Torre War					
Seepage			Small son	per in dischar	A 2			
Sand Boils (indicate if flowing and color)		V	1		7			
Erosion Rills		1./	1					
PERIMTER FENCING/GATES	General Condition:	Good	Fair / Poor	Repairs:	Date:		1 -7	
Evidence of damage or tar	The second second	1	7					
Evidence of unauthorized access		1						
Gates closed and locked		1		315			+	

N. Pond water level - ~ 448.8' S. Donal mater level - ~ 446.8'