## CCR Impoundment Weekly Inspection 35 ILL. ADM. Code 845 / 40 CFR Part 257

	Station:	Edwards		Date:	3/19/25			
Impoundment Name:		Ash Pond		Time: 1320				
IEPA I	Number:	W1438050005-03	1	Inspector(s):	M. Davis			
sky: cldy	Temp.:	<b>63</b>	Precip. (last 48 hrs):	-11"	Pool Elev.: <u>435.9</u>			

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

		NO			A	CTIO	N
ITEM	YES		DESCRIPTION			INVESTIGATE	SENT TO DSM
CREST General C	Condition:	Good	/ Fair / Poor Repairs:	Date:			
Cracking		V		·			<b>├</b>
Settlement		~		<u> </u>			-
Erosion Rills		~		·	-		-
Animal Burrows		~					-
Misalignment		1			-		-
Vegetation (greater than 12")		<u></u>					
UPSTREAM EMBANKMENT General G	Condition:	Good	/ Fair / Poor Repairs:	Date:	865		486
Cracking					<u> </u>		<del> </del>
ughing / Bulging					ļ		<u> </u>
Seepage					ļ		
Sink Holes		~					-
Animal Burrows		V			<del>                                     </del>		-
Erosion Rills							_
Slope Protection / Rip Rap							<del> </del>
Vegetation (greater than 12")		V					
DOWNSTREAM EMBANKMENT General	Condition	(OOO	Y Fair / Poor Repairs:	Date:			
Cracking					-	-	-
Sloughing / Bulging					-	<del>                                     </del>	-
Seepage		/					
Sink Holes		1				1_	
Sand Boils (indicate if flowing and colo	r)	/					
Animal Burrows		1				- 1	
Erosion Rills		/				ļ	1_
Vegetation (greater than 12")		V					
SPILLWAY(S) General	Condition	: <b>G</b> oo	/ Fair / Poor Repairs:	Date:			
Actively Flowing (provide depth)	V	1	Pond water a 82" be/	or top of Di	sc ha	ige	<del> </del>
Activety Howall & (blosing achter)							
Obstructions Present		V			-6		
	V	V			V		
Obstructions Present	V	V	Leak in Discharge Pipe		V		
Obstructions Present Seepage	V	\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \			V		
Obstructions Present Seepage Sand Boils (indicate if flowing and colo	r)	(G00	Leak in Discharge Pipe	Date:	V		
Obstructions Present Seepage Sand Boils (indicate if flowing and colo Frosion Rills P. MTER FENCING/GATES General	r) Condition	(G00	Leak in Discharge Pipe		V		
Obstructions Present Seepage Sand Boils (indicate if flowing and colo	r) Condition		Leak in Discharge Pipe				