

CCR Impoundment Weekly Inspection
35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Edwards
 Impoundment Name: Ash Pond
 IEPA Number: W1438050005-01

Date: 10/29/25
 Time: 10:00 AM
 Inspector(s): Kevin Largent

Sky: Clear Temp.: 46° F Precip. (last 48 hrs): .37" Pool Elev.: 431.3'

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
CREST	General Condition: <u>Good</u> Fair / Poor		Repairs: _____ Date: _____			
Cracking	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Settlement	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Erosion Rills	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Animal Burrows	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Misalignment	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Vegetation (greater than 12")	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
UPSTREAM EMBANKMENT	General Condition: <u>Good</u> Fair / Poor		Repairs: _____ Date: _____			
Cracking	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Sloughing / Bulging	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Seepage	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Sink Holes	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Animal Burrows	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Erosion Rills	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Slope Protection / Rip Rap	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Vegetation (greater than 12")	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
DOWNSTREAM EMBANKMENT	General Condition: <u>Good</u> Fair / Poor		Repairs: _____ Date: _____			
Cracking	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Sloughing / Bulging	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Seepage	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Sink Holes	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Sand Boils (indicate if flowing and color)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Animal Burrows	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Erosion Rills	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Vegetation (greater than 12")	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
SPILLWAY(S)	General Condition: <u>Good</u> Fair / Poor		Repairs: _____ Date: _____			
Actively Flowing (provide depth)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<u>No discharge from either pond</u>			
Obstructions Present	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Seepage	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Sand Boils (indicate if flowing and color)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Erosion Rills	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
PERIMTER FENCING/GATES	General Condition: <u>Good</u> Fair / Poor		Repairs: _____ Date: _____			
Evidence of damage or tampering	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Evidence of unauthorized access	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				
Gates closed and locked	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				

N Pond < 449 - Below staff gauge
No water flow in or out of north pond. Inflow retained in south SW pond.