CCR Impoundment Weekly Inspection
35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Joppa   Date: 8·31·22
Impoundment Name: East Ash Pond   Time: 13:05
IEPA Number: W127010004-02   Inspector(s): R Faughn

Sky: Clear   Temp.: 92°F   Precip. (last 48 hrs): 0"   Pool Elev.: 4.54'

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	MONITOR	INVESTIGATE	SENT TO DSM
CREST General Condition: ⓐGood / Fair / Poor			Repairs: Date:			
Cracking		✓				
Settlement		✓				
Erosion Rills		✓				
Animal Burrows		✓				
Misalignment		✓				
Vegetation (greater than 12")		✓				
STREAM EMBANKMENT General Condition: ⓐGood / Fair / Poor			Repairs: Date:			
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Slope Protection / Rip Rap		✓				
Vegetation (greater than 12")	✓		Dead vegetation at water line.			
DOWNSTREAM EMBANKMENT General Condition: ⓐGood / Fair / Poor			Repairs: Date:			
Cracking		✓				
Sloughing / Bulging		✓				
Seepage		✓				
Sink Holes		✓				
Sand Boils (indicate if flowing and color)		✓				
Animal Burrows		✓				
Erosion Rills		✓				
Vegetation (greater than 12")	✓		Grass on slope.			
SPILLWAY(S) General Condition: ⓐGood / Fair / Poor			Repairs: Date:			
Actively Flowing (provide depth)	✓		4.5" water flow at outfall.			
Obstructions Present		✓				
Seepage		✓				
Sand Boils (indicate if flowing and color)		✓				
Erosion Rills		✓				