

CCR Impoundment Weekly Inspection
35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Joppa
Impoundment Name: East Ash Pond
IEPA Number: W1270100004-02

Date: 8-12-25
Time: 14:30
Inspector(s): R Faughn

Sky: Clear Temp.: 90°F Precip. (last 48 hrs): 0.1" Pool Elev.: 383.7'

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	ACTION		
				MONITOR	INVESTIGATE	SENT TO DSM
CREST			General Condition: <u>Good</u> / Fair / Poor			
Cracking		☒	Repairs: _____ Date: _____			
Settlement		☒				
Erosion Rills		☒				
Animal Burrows		☒				
Misalignment		☒				
Vegetation (greater than 12")	☒		<u>weeds on levee roadway</u>			
STREAM EMBANKMENT			General Condition: <u>Good</u> / Fair / Poor			
Cracking		☒	Repairs: _____ Date: _____			
Sloughing / Bulging		☒				
Seepage		☒				
Sink Holes		☒				
Animal Burrows		☒				
Erosion Rills		☒				
Slope Protection / Rip Rap		☒				
Vegetation (greater than 12")	☒		<u>Vegetation on slope</u>			
DOWNSTREAM EMBANKMENT			General Condition: <u>Good</u> / Fair / Poor			
Cracking		☒	Repairs: _____ Date: _____			
Sloughing / Bulging		☒				
Seepage		☒				
Sink Holes		☒				
Sand Boils (indicate if flowing and color)		☒				
Animal Burrows		☒				
Erosion Rills		☒				
Vegetation (greater than 12")	☒		<u>Vegetation on slope</u>			
SPILLWAY(S)			General Condition: <u>Good</u> / Fair / Poor			
Actively Flowing (provide depth)	☒		Repairs: _____ Date: _____			
Obstructions Present		☒	<u>1/16" water flow at weir</u>			
Seepage		☒				
Sand Boils (indicate if flowing and color)		☒				
Erosion Rills		☒				