## CCR Impoundment Weekly Inspection 35 ILL. ADM. Code 845 / 40 CFR Part 257

Station:	Kincaid	aid			Date: 12/29/202	12/29/2021		
Impoundment Name: ACH POND					Time: 12:45			
IEPA Number: WOZ181400			01	Inspector(s): Tim Arno		d		
Sky: Praway Temp.: 35F			recip. (last 48 hrs):	0.65 " Pool		l Elev.: - 14 "		
/ES" responses require description	Isize denth extents	colo	r) and location in "DESC	PIDTION" section "	NO" response indicates no	lections		
bserved at the time of inspection.								)_,_
ttach additional sheets as necessar					,		· · · ·	
ITEM						ACTION		<u>N</u>
		NO		DESCRIPTION		MONITOR	INVESTIGATE	SENT TO DSM
CREST	General Condition:	Good	/ Fair / Poor	Repairs:	Date:			
Cracking	<u>'</u>	V		•				
Settlement		7						
Erosion Rills		V.						
Animal Burrows		1						
Misalignment		V,			· . ·			
Vegetation (greater than 12")		<b>√</b> _						
UPSTREAM EMBANKMENT	General Condition:	Goog	/ Fair / Poor	Repairs:	Date:	17:35		
Cracking		7		•				
Sloughing / Bulging		V						
Seepage		V						
Sink Holes		LZ				].		
Animal Burrows		V						
Erosion Rills		V					<u> </u>	
Slope Protection / Rip Rap		V						
Vegetation (greater than 12")		V						
OWNSTREAM EMBANKMENT	General Condition:	GGOO	/ Fair / Poor	Repairs:	Date:			
Cracking								
Sloughing / Bulging		<u></u>						
Seepage		V						
Sink Holes		V				ļ		<u> </u>
Sand Boils (indicate if flowing and color)		V		, ,		<u> </u>		<u> </u>
Animal Burrows		<u> </u>	Dff embankmen	t, nepr/provok	i will mark pipe		<u> </u>	<u> </u>
Erosion Rills		V		· · · · · · · · · · · · · · · · · · ·		<u> </u>	<u> </u>	<u> </u>
Vegetation (greater than 12"		1/	<b>5</b>	•		↓		
SPILLWAY(S)	General Condition:	<b>6609</b>	Fair / Poor	Repairs:	Date:			
Actively Flowing (provide de	epth)	V				<u> </u>	<u> </u>	<u> </u>
Obstructions Present		V/			<del> </del>		<u> </u>	<u> </u>
Seepage		V,	<u> </u>				Ь—	<u> </u>
Sand Boils (indicate if flowing and color)		V				<del> </del>	<u>.</u>	<b></b>
Erosion Rills		1					1	