## CCR Impoundment Weekly Inspection 35 ILL. ADM. Code 845 / 40 CFR Part 257

Station:	Kincaid	Da	ate: 02/14/24
Impoundment Name:	Ash Pond	Tin	me: 1300
IEPA Number:	W0218140002-01	Inspector(	r(s): D. Husur
Sky: Suny Temp.:	45° P	p. (last 48 hrs):	1) Pool Elev.: -12"

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM		NO	DESCRIPTION		ACTION			
					MONITOR	INVESTIGATE	SENT TO DSM	
CREST General Co	ndition:	Good	Fair / Poor Repairs:	Date:		1	1	
Cracking		V						
Settlement		V						
Erosion Rills		V						
Animal Burrows		V						
Misalignment		v						
Vegetation (greater than 12")		V						
UPSTREAM EMBANKMENT   General Co	ndition:	Good	Fair / Poor Repairs:	Date:				
Cracking		V						
Sloughing / Bulging		V						
Seepage		V						
Sink Holes		V						
Animal Burrows		v						
Erosion Rills		V						
Slope Protection / Rip Rap		V						
Vegetation (greater than 12")		V						
DOWNSTREAM EMBANKMENT General Co	ndition	Good	/ Fair / Poor Repairs:	Date:				
Cracking		V						
Sloughing / Bulging		V						
Seepage		V						
Sink Holes		V						
Sand Boils (indicate if flowing and color)		V	•					
Animal Burrows			MONITORING		V			
Erosion Rills		V	0		•			
Vegetation (greater than 12")		1						
SPILLWAY(S) General Co	ndition:	Good	Fair / Poor Repairs:	Date:	4			
Actively Flowing (provide depth)		V						
Obstructions Present		V						
Seepage		V						
Sand Boils (indicate if flowing and color)		V						
Erosion Rills		V						