CCR Impoundment Weekly Inspection 35 ILL. ADM. Code 845 / 40 CFR Part 257

Station:	Kincaid		Date:	10/30	24
Impoundment Name:	Ash Pond		Time:	10:00	OAM
IEPA Number:	W0218140002-0		Inspector(s):	1). Hu	ber
Sky: PCLOY Temp.:	65°F	Precip. (last 48 hrs):	0.00"	Po	ool Elev.: -16.0

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM		NO		ACTION			
			DESCRIPTION		INVESTIGATE	SENT TO DSM	
CREST General Con	dition:	Good	Fair / Poor Repairs: Date:				
Cracking		7					
Settlement		V					
Erosion Rills		V					
Animal Burrows		V					
Misalignment		1					
Vegetation (greater than 12")		1/					
UPSTREAM EMBANKMENT General Con	dition:	Good	Fair./ Poor Repairs: Date:				
Cracking		V					
Sloughing / Bulging		V					
Seepage		V					
Sink Holes		1	·				
Animal Burrows		V					
Erosion Rills		V				-	
Slope Protection / Rip Rap		V					
Vegetation (greater than 12")		又					
DOWNSTREAM EMBANKMENT General Con	dition.	Good	// Fair / Poor Repairs: Date:				
Cracking		7					
Sloughing / Bulging		ν					
Seepage		1					
Sink Holes		V					
Sand Boils (indicate if flowing and color)		V					
Animal Burrows	V		MONITORING	V	**************************************		
Erosion Rills		7	U				
Vegetation (greater than 12")							
SPILLWAY(S) General Con	dition:	Sood	Fair / Poor Repairs: Date:				
Actively Flowing (provide depth)	T	7					
Obstructions Present		7	100 100 100 100 100 100 100 100 100 100				
Seepage		V					
Sand Boils (indicate if flowing and color)		V.					
Erosion Rills		1					