CCR Impoundment Weekly Inspection 35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Kincaid		_	Date:	12/18/24	
Impoundment Nam	e: Ash Pond		Time:	11:00 AM	
IEPA Numbe	er: W0218140002-01	_	Inspector(s):	D. Husca	
Sky: Cloudy Temp	o.: 29°F	Precip. (last 48 hrs):	0.09"	Pool Elev.:	-b.0"

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

ITEM		NO	DESCRIPTION		ACTION		
					INVESTIGATE	SENT TO DSM	
CREST General Con	dition:	Good	/ Fair / Poor Repairs: Date:				
Cracking		V					
Settlement		V					
Erosion Rills		1					
Animal Burrows		1					
Misalignment		1					
Vegetation (greater than 12")		V					
UPSTREAM EMBANKMENT General Cor	dition:	Good	Fair / Poor Repairs: Date:				
Cracking		V					
Sloughing / Bulging		V					
Seepage		V					
Sink Holes		1					
Animal Burrows		1					
Erosion Rills							
Slope Protection / Rip Rap		V					
Vegetation (greater than 12")		1					
DOWNSTREAM EMBANKMENT General Cor	dition	Good	Fair / Poor Repairs: Date:				
Cracking		V					
Sloughing / Bulging		V					
Seepage		V					
Sink Holes		V					
Sand Boils (indicate if flowing and color)		V	•		1		
Animal Burrows			MONITONING	V			
Erosion Rills		1					
Vegetation (greater than 12")		V					
SPILLWAY(S) General Cor	dition:	Good	Fair / Poor Repairs: Date:				
Actively Flowing (provide depth)	1						
Obstructions Present							
Seepage							
Sand Boils (indicate if flowing and color)							
Erosion Rills							