CCR Impoundment Weekly Inspection 35 ILL. ADM. Code 845 / 40 CFR Part 257

| Station: | Newton | Date: | 9/20/2023 |
|-------------------|-------------------|---------------|----------------|
| Impoundment Name: | Primarry Ash Pond | Time: | 7:15 AM |
| IEPA Number: | W0780700001-01 | Inspector(s): | Terry Hanratty |
| | | | |

Precip. (last 48 hrs):

Sky: Clear

Temp.:

55

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

Pool Elev.:

534.5

| ITEM | | NO | | ACTION | | | |
|--|---------|------|--|--------|-------------|----------------|--|
| | | | DESCRIPTION | | INVESTIGATE | SENT TO DSM | |
| CREST General Cond | lition: | Good | / Fair / Poor Repairs: Date: | | | | |
| Cracking | | Χ | | | | | |
| Settlement | | Χ | | | | | |
| Erosion Rills | | Χ | | | | | |
| Animal Burrows | | Χ | | | | | |
| Misalignment | | Χ | | | | | |
| Vegetation (greater than 12") | | Χ | Blankenship mowing this week of August 28th. | | | | |
| UPSTREAM EMBANKMENT General Condi | | Good | / Fair / Poor Repairs: Date: | | | | |
| Cracking | | Χ | | | | | |
| Sloughing / Bulging | | | Minor sloghing on south side-continuing to monitor | Χ | | | |
| Seepage | | Χ | | | | | |
| Sink Holes | | Χ | | | | | |
| Animal Burrows | | Χ | | | | | |
| Erosion Rills | | Χ | | | | | |
| Slope Protection / Rip Rap | | Χ | | | | | |
| Vegetation (greater than 12") | | Χ | Blankenship mowing this week of August 28th. | | | | |
| DOWNSTREAM EMBANKMENT General Cond | lition: | Good | / Fair / Poor Repairs: Date: | | | | |
| Cracking | | Χ | | | | | |
| Sloughing / Bulging | | Χ | | | | | |
| Seepage | | Χ | | | | | |
| Sink Holes | | Χ | | | | | |
| Sand Boils (indicate if flowing and color) | | Χ | | | | | |
| Animal Burrows | | Χ | | | | | |
| Erosion Rills | | Χ | | | | | |
| Vegetation (greater than 12") | | Χ | Blankenship mowing this week of August 28th. | | | | |
| SPILLWAY(S) General Cond | lition: | Good | · | | | | |
| Actively Flowing (provide depth) | | Χ | Removed 1 stop log 11/16/22 | | | | |
| Obstructions Present | | Χ | | | | | |
| Seepage | | Χ | | | | | |
| Sand Boils (indicate if flowing and color) | | Χ | | | | | |
| Erosion Rills | | Χ | | | | | |