## CCR Impoundment Weekly Inspection 35 ILL. ADM. Code 845 / 40 CFR Part 257

	11/9/2023	Date:		Newton	Station:	
	10:30 AM	Time:	Pond	Primarry Ash	nt Name:	Impoundme
	Terry Hanratty	Inspector(s):	01-01	W078070000	Number:	IEPA
534.5	Pool Elev.:	0	Precip. (last 48 hrs):	60	Temp.:	Sky: Partly Clou

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM). Attach additional sheets as necessary. Circle General Condition for each section.

					ACTION				
ITEM		YES	NO		DESCRIPTION	N	MONITOR	INVESTIGATE	SENT TO DSM
CREST	General Cond	ition:	Good	/ Fair / Poor	Repairs:	Date:			
Cracking			Х						
Settlement			Х						
Erosion Rills			Х						
Animal Burrows			Х						
Misalignment			Х						
Vegetation (greater than 12")			Х	Blankensh	ip mowing this wee	ek of August 28th.			
UPSTREAM EMBANKMENT	General Cond	ition:	Good	/ Fair / Poor	Repairs:	Date:			
Cracking			Х						
Sloughing / Bulging		Х		Minor sloghi	ng on south side-co	ontinuing to monitor	Х		
Seepage			Х						
Sink Holes			Х						
Animal Burrows			Х						
Erosion Rills			Х						
Slope Protection / Rip Rap			Х						
Vegetation (greater than 12")			Х	Blankensh	ip mowing this wee	ek of August 28th.			
DOWNSTREAM EMBANKMENT	General Cond	ition:	Good	/ Fair / Poor	Repairs:	Date:			
Cracking			Х						
Sloughing / Bulging			Х						
Seepage			Х						
Sink Holes			Х						
Sand Boils (indicate if flowing a	and color)		Х						
Animal Burrows			Х						
Erosion Rills			Х						
Vegetation (greater than 12")			Х	Blankensh	ip mowing this wee	ek of August 28th.			
SPILLWAY(S)	General Cond	ition:	Good	/ Fair / Poor	Repairs:	Date:			
Actively Flowing (provide dep	oth)		Х	Re	emoved 1 stop log 2	11/16/22			
Obstructions Present			Х						
Seepage			Х						
Sand Boils (indicate if flowing and color)			Х						
Erosion Rills			Х						