CCR Impoundment Weekly Inspection
35 ILL. ADM. Code 845 / 40 CFR Part 257

Station: Edwards
Impoundment Name: Ash Pond
IEPA Number: W1438050005-01

Date: 6/30/21
Time: 14:00
Inspector(s): Rick Kelley

Sky: Cloudy **Temp.:** 81°F **Precip. (last 48 hrs):** ~~0.61~~ 1.01" (4R) **Pool Elev.:** 447.4'

"YES" responses require description (size, depth, extents, color) and location in "DESCRIPTION" section. "NO" response indicates no issues were observed at the time of inspection. If "ACTION" selected is "INVESTIGATE", please indicate date forwarded via email to Dam Safety Manager (DSM) . Attach additional sheets as necessary. Circle General Condition for each section.

ITEM	YES	NO	DESCRIPTION	ACTION: MONITOR	ACTION: INVESTIGATE	ACTION: SENT TO DSM
CRESTS General Condition: (Good) / Fair / Poor	Repairs:	Date:				
Cracking		X				
Settlement		X				
Erosion Rills		X				
Animal Burrows		X				
Misalignment		X				
Vegetation (greater than 12")		X				
UPSTREAM EMBANKMENT General Condition: (Good) / Fair / Poor	Repairs:	Date:				
Cracking		X				
Sloughing / Bulging		X				
Seepage		X				
Sink Holes		X				
Animal Burrows		X				
Erosion Rills		X				
Slope Protection / Rip Rap		X				
Vegetation (greater than 12")		X				
DOWNSTREAM EMBANKMENT General Condition: (Good) / Fair / Poor	Repairs:	Date:				
Cracking		X				
Sloughing / Bulging		X				
Seepage		X				
Sink Holes		X				
Sand Boils (indicate if flowing and color)		X				
Animal Burrows		X				
Erosion Rills		X				
Vegetation (greater than 12")		X				
SPILLWAY(S) General Condition: (Good) / Fair / Poor	Repairs:	Date:				
Actively Flowing (provide depth)	X		≈ 2.0"			
Obstructions Present		X				
Seepage		X				
Sand Boils (indicate if flowing and color)		X				
Erosion Rills		X				